

**Schedule B**

<b>Sr. No.</b>	<b>Description</b>	<b>Unit</b>	<b>Quantity</b>	<b>Rate without GST (Rs.)</b>	<b>Amount without GST (Rs.)</b>
1	SITC of Addressable Smoke detector with base with soft addressing facility and Drift Compensation, low current consumption. Dual LED's for 360 visibility, compact profile housing design, regular 100mm base. IP Rating : IP - 42. Approval: EN-54,	Nos	93	3325	309225
2	SITC of Addressable Manual Call Point - Resettable type - with back box with soft addressing Facility with Status LED for 360° visibility - IP :50 Rating	Nos	31	3510	108810
3	Providing, fixing, testing & commissioning of 15mm dia quartzoid bulb type sprinklers of rating 68 degree centigrade with required accessories : Pendent sprinkler	Nos	130	660	85800
4	Providing Refilling and Servicing of ABC Type 6 kg Fire Extinguisher Refilling.	Nos	55	800	44000
5	Providing Refilling and Servicing of Co2 Type 4.5 kg Fire Extinguisher Refilling.	Nos	27	950	25650
6	Providing & Fixing ABC Discharge valve with Pressure gauge	Nos	12	650	7800
7	Providing Servicing and Maintenance of Main Fire Pump	Nos	3	19000	57000
8	Providing Servicing and Maintenance of Jockey Fire	Nos	1	14000	14000
9	Providing Servicing and Maintenance of Diesel Fire	Nos	1	28500	28500
10	Providing Servicing and Maintenance Of Addressable Fire Alarm System with all hardware and Software updation and full system Checking as required	Nos	1	28500	28500
11	Providing Servicing and Maintenance of Addressable Smoke Detector as required	Nos	369	220	81180
12	Supply, Erection, Testing and Commissioning of Horizontal, Monoblock type fire pump with all required accessories for the following data 20 hp	Nos	1	147250	147250
13	Supply, Erection, Testing and Commissioning of Horizontal, Monoblock type fire pump with all required accessories for the following data 7.5 hp	Nos	1	85500	85500

14	(a) Providing and Fixing of pressure switch in M.S Pipe Line including connection etc. as required	Nos	4	2800	11200
15	Supply, and fixing First Aid Hose Reel with MS construction spray painted with P red, conforming to IS 884 complete with the following as required. 20mm nominal internal dia water hose thermoplastic (textile reinforced) type-2 as per IS 12585 20mm nominal internal dia gun metal globe valve and nozzle. drum and brackets for fixing the equipment on the wall. Connection from riser with 25mm dia stop gun metal valve & MS pipe	Nos	9	6650	59850
16	Supplying and fixing 63mm dia, 15 m long RRL hose pipe with 63mm dia male and female couplings duly bound with GI wire, rivets etc. conforming to IS 636 (type A) as required : Stainless Steel	Rmt	7	4275	29925
17	Supply, installation, testing and commissioning of ABC type 6 kg conform to IS: I 5683, with ISI marked /TAC approved fitted with required accessories including wall suspension brackets. (NEW)	No	5	2850	14250
18	FIRE EXTINGUISHER Supply, installation, testing and commissioning of Carbon Dioxide (CO2) type Fire Extinguisher of 4.5 kg conform to IS: 15683, with ISI marked /TAC approved 1 NOS fitted with required accessories including wall suspension brackets.	No	5	8550	42750
19	Supplying Installation Testing Commissioning of Conventional type Smoke detector with base as	No	10	1050	10500
20	Providing Fixing photo luminescent signages as per IS standard in block / small letters on rigid sheet with necessary wall or ceiling fittings as specified sizes : for fire extinguisher, exit, do not to do etc.	Sqinch	9408	12	112896
				Total	<b>13,04,586.00</b>

I/We am/are willing to carry out the work at.....% above/below percent (Should be written in figures and words) of the estimated rate mentioned above. Amount of my /our tender works out as under.

Estimated amount put to tender

Deduct.....% below

Net

In words

Estimated amount put to tender

Add.....% Above

Net

In words