



NOTES:

1. NO. OF RISER PER SUPPORT - 3 NOS. (RISER FOR 66KV 50X6MM GI FLAT, FOR 132KV, 220KV & 400KV 75X10MM GI FLAT & FOR 765KV 75X12 MM GI FLAT)
2. NO.OF UNTREATED ROD ELECTRODE - 1NO.
3. CLEAT TYPE CLAMP SHALL NOT BE MOUNTED ON STR. JOINTS.
4. NOS. OF CLEAT TYPE CLAMPS SHALL BE PROVIDED AT AN INTERVAL OF 2 MTR.
5. NO OF PAD TYPE CLAMP REQD. - 1NO.
6. T- CONNECTOR FOR 7/3.66 OR 7/3.15MM GI EARTH WIRE - 1NOS.

EXECUTION PURPOSE



GUJARAT ENERGY TRANSMISSION CORPN.LTD.

S.P.VIDYUT BHAVAN, RACE COURSE,
VADODARA - 390 007

Typical Earthing Arrangement for Tower with Peak

		DRAWN:	CHECKED:	APPD:	SIZE:
R1	UPDATED FOR 765KV SYSTEM	JE (ENGG)	DE (ENGG) EE (ENGG)	I/C ACE (ENGG)	A4
R0	FIRST PREPARATION	SCALE:	DATE:	DRG. NO:	SHEET:
REV:	DESCRIPTION:	N.T.S.	22-12-25	GETCO / E / STD / P-012	13 OF 24
					REV:
					R1