


**TYP. PLAN**

**NOTE:-**

1. RISER FOR 66KV 50X6MM GI FLAT, FOR 132KV, 220KV & 400KV 75X10MM GI FLAT & FOR 765KV 75X12 MM GI FLAT)

R1	UPDATED FOR 765KV SYSTEM
R0	FIRST PREPARATION
REV:	DESCRIPTION:

EXECUTION PURPOSE			
 <b>GUJARAT ENERGY TRANSMISSION CORPN.LTD.</b> S.P.VIDYUT BHAVAN, RACE COURSE, VADODARA - 390 007			
Typical Earthing Arrangement of Cable Trench			
DRAWN:	CHECKED:	APPD:	SIZE:
JE (ENGG)	DE (ENGG) EE (ENGG)	I/C ACE (ENGG)	A4
SCALE:	DATE:	DRG. NO:	SHEET: REV:
N.T.S.	23.12.2025	GETCO / E / STD / P-012	19 OF 24 R1