



NOTES:-

1. NO. OF CU.FLEXIBLE BRAID REQD. 2 PER GATE POST.
2. EVERY ALTERNATE POST OF THE FENCE SHALL BE CONNECTED TO EARTH MAT THROUGH A RISER.

EXECUTION PURPOSE



GUJARAT ENERGY TRANSMISSION CORPN.LTD.

S.P.VIDYUT BHAVAN, RACE COURSE,
VADODARA - 390 007

Typical Earthing Arrangement for Switch Yard Gate

		DRAWN:	CHECKED:	APPD:		
		N.P.P.	P.B.M.	EE (ENGG)	ACE (ENGG)	SIZE: A4
R0	FIRST PREPARATION	SCALE:	DATE:	DRG. NO:	SHEET:	REV:
REV:	DESCRIPTION:	N.T.S.	01-06-08	GETCO / E / STD / P-012	21 OF 24	R0