



ALL THE PROTECTIONS & CONFIGURATIONS SHOWN FOR 220KV VIRAMGAM-1 LINE ,220/66KV TRF - 1, 66KV LINE NO. 10 ARE APPLICABLE TO ALL OTHER RESPECTIVE BAYS.

LINE DIFFERENTIAL PROTECTION SHALL BE APPLICABLE TO 220KV MSIL LINE No.- 1 & 2 BAY.

MFM SHALL BE PROVIDED, IF BCPU IS NOT HAVING SUFFICIENT ANALOGUE INPUTS FOR METERING AS WELL AS PROTECTION CORE OF CT.