

**Addendum - I for technical specification for
Bay Control and Protection Relays(IEDs) (GETCO / E / TS- 3605 / R2 July, 2022)**

For technical specifications of **Bay Control and Protection Relays(IEDs) (GETCO / E / TS- 3605 / R2 July, 2022)** technical requirements shall be considered as follow.

SN	Clause no.	Description	Changes to be considered
1	5.2.4, c) (Pg. 7)	Numerical Bay Control and Protective Relays scope: The relay shall be capable of supporting IEC 61850-8-1 protocols	Numerical Bay Control and Protective Relays scope: The relay shall be capable of supporting IEC 61850-8-1 protocols <u>Edition 2</u>
2	6.0.1 & 6.0.3 k) (Pg. 8 & 10)	Type test: IEC 61850	To consider: a. IEC 61850 <u>Edition 2</u> b. <u>Cyber security NERC CIP/IEC 52351 / IEEE 1686/ IEC 62443</u>
4	Annexure-III (1, D (3)) (2, D (3))	Numerical relay communication capability for: Directional O/C & E/F Protection Non-Directional O/C & E/F Protection IEC 61850-8-1	Numerical relay communication capability for: Directional O/C & E/F Protection Non-Directional O/C & E/F Protection IEC-61850 -8-1 <u>Edition 2</u> .