

## ***Amendment Distribution Transformer – 1***

=====

Following revision/amendment shall be considered in Technical Specification No: GETCO/E/TS – ATFRS/63-500 KVA/ R5 AUG'22 for 03 Phase, 11,000/415V – 240V, Level 1 (STAR1) as per IS 1180, 63KVA to 500KVA with CRGO/Amorphous Core Sub-Station Distribution Transformers.

- a) **Clause No: 6.0 Tests:**  
6.3 – Acceptance Tests  
Sub-clause: 6.3.F.6 (Page: 32 of 44)

***To be read as:***

*“Collection of oil samples from any transformer, to be sent for testing at NABL lab to comply with IS 1866. **Testing charges will be borne by supplier**”.*