



Amendment

(GETCO/E/06TS – ISO 011/R6 June 22)

For technical specifications of 66 kV Isolator (GETCO/E/06TS – ISO 011/R6 June 22) clause 2.4.1-5 of specific technical requirements shall be considered as follow.

TECHNICAL SPECIFICATION FOR 66 kV Isolator SECTION – II TECHNICAL REQUIREMENTS

Clause 2.4.1 - The isolator and isolator-cum –earthing switches shall comply with the following technical requirements

2.4.1-5. Rated current (Amp):630/1250/1600/2000/2500Amp instead of 630/1250/1600/2000Amp