

**Annexure - 4**

Sr. No.	Location	Avg Illuminati on level Required in LUX	AC 1.5 T Split	AC 3 T Split	15 A Plug	5 A Plug	Fan	Ex Fan	DC Point	DC Plug	Portable Emergen cy Lighting	Bell	3 ph.wtih neutral 15A test plug	Occupancy Sensor	Light Level Sensor
<b>A</b>	<b>Control room Building</b>														
1	Control Room	300	0	3	4	3	2	0	2	1	1	1	1	1	1
2	Battery Room	100	0	0	0	3	2	4	1	0	0	0	0	0	1
3	LV Room	150	0	0	2	2	2	0	1	0	1	0	1	0	0
4	PLCC Room	300	0	2	2	2	2	0	1	0	1	1	1	0	0
5	Store Room	100	0	0	2	2	1	0	0	0	0	0	0	1	0
6	Ramp Slope	100	0	0	1	1	0	0	0	0	0	0	0	0	0
7	Veranda	70	0	0	0	2	0	0	0	0	0	0	0	0	0
8	Office	300	2	0	2	2	1	0	0	0	0	2	0	0	0
9	Meeting Room	300	2	0	2	2	1	0	0	0	0	2	0	0	0
10	Toilet Gens	70	0	0	0	1	0	1	0	0	0	0	0	0	0
11	WC	70	0	0	0	1	0	1	0	0	0	0	0	0	0
12	Toilet Ladies	70	0	0	0	1	0	1	0	0	0	0	0	0	0
13	Passage (Corridor)	70	0	0	0	2	0	0	0	0	1	0	0	0	0
14	Ramp Slope	100	0	0	1	1	0	0	0	0	0	0	0	0	0
15	Veranda	70	0	0	0	2	0	0	0	0	0	0	0	0	0
<b>B</b>	<b>Security Building</b>														
1	Sec. Cabin	300	0	0	1	2	1	0	0	0	1		0	0	0
2	Toilets	70	0	0	0	1	0	1	0	0	0	0	0	0	0
<b>C</b>	<b>Store Building</b>	100	0	0	3	3	1	1	0	0	0	0	1	1	0