

'Amendment - 1' to the Technical Specifications
(Specification ID : GETCO / E / TS – CRP 3601 / R8 September, 2022)
for 400, 220, 132 kV Control & Relay Panels

Date: 18.04.2023

S/N	Clause No.	Item	Existing Specification	Amended Specification
1	6.1.1 (A)	Type Test of Control & Relay Panels	i. Degree of Protection IP54	<i>To modify as below;</i> i. Degree of Protection IP54 <i>A valid type test report with all the components mounted in the panel and showing complete details of door and gaskets profiles, gasket material and size, door hinges and locking arrangement, etc. shall be submitted. Incomplete report without above details will not be accepted.</i>