



NOTES:-

- 1. RISER FOR 66KV 50X6MM GI FLAT FOR 10KA FAULT CURRENT AND 50X8MM GI FLAT FOR 25KA FAULT CURRENT & ABOVE CLASS 75X10MM GI FLAT.**

NO	FIRST PREPARATION				
REV:	DESCRIPTION :				

 GUJARAT ENERGY TRANSMISSION CORPN.LTD. S.P.VIDYUT BHAVAN, RACE COURSE, VAODDARA - 380 007					
EXECUTION PURPOSE					

Typical Earthing Arrangement for Sliding Gate

DRAWN:	CHECKED:	APPD:	SIZE:	REV:
N.P.P.	P.S.M.	EE (ENG)	AA	
SCALE:	DATE:	DRG. NO:	SHEET:	
N.T.S.	01-08-08	GETCO / E / STD / P-612	22 OF 24	NO