



GUJARAT ENERGY TRANSMISSION
CORPORATION LTD.

SARADAR PATEL VIDYUT BHAVAN,
RACE COURSE, BARODA – 390 007.

TECHNICAL SPECIFICATION
FOR

33, 22 & 11 kV Motor operated
ISOLATORS
& ISOLATOR – CUM – EARTHING
SWITCHES

GETCO/E/3,2,1TS ISO/R4 June-22

Blank

Blank

TECHNICAL SPECIFICATION FOR 33, 22 & 11 kV ISOLATORS & ISOLATOR – CUM – EARTHING SWITCHES

SECTION – I

GENERAL TECHNICAL REQUIREMENTS

1.1 SCOPE :

- 1.1.1 This Section covers the General Technical Requirements such as design, manufacture, testing, dispatch to destination, installation etc. for the outdoor Isolators (Motor and manual operated) and Isolator-cum-earthling switches (Manual) *along with terminal connectors. The scope also covers to design & supply of M.S. hot dip galvanised (HDG) lattice structure, if stated in schedule – A of respective tender. The rating of isolator shall be as stated in schedule – A of respective tender.*

1.2 STANDARDS :

- 1.2.1 The isolators and isolator-cum-earthling switches shall comply with the requirements of the latest edition of IEC 62271-102 and IS 9921 (as amended up to date). The Insulators shall comply with the requirement of latest edition of IS 2544/1973 and IEC 60168/1988 (as amended up to date)

1.3 DRAWING :

- 1.3.1 Following drawing (in duplicate) shall be submitted by the Bidder for the purpose of preliminary study. The offer without following drawings shall not be considered for acceptance.

- (a) General outline dimensional drawings.
- (b) Sectional view showing the general constructional features of the isolators with / without earthing Switches.

- 1.3.2 The supplier shall submit the following drawings for the approval of the Purchaser.

- (i) Assembly drawing showing plan, side view and elevation of isolators and earthing switch incorporating mounting dimensions, detailed dimensions, shipping weight, net weight etc.

- (ii) Schematic control wiring diagram and interlocking scheme.
- (iii) Dimensional control for the line and earth side terminals of the isolator. Also, dimensional drawing of the clamps and connectors.
- (iv) Location and mounting details of operating handle and operating devices.
- (v) Drawing giving details of guides and guide bearings (Type, designation, number, make) to be mounted on isolator supporting structure.
- (vi) Details of contacts and main isolator blades.
- (vii) Details of terminal stud.
- (viii) Drawing & necessary design and fabrication of isolators supporting structure, if structures are included in the scope of supply.
- (ix) Drawing showing various positions (close and open) of the isolator.
- (x) Drawing for support structure.
- (xi) Drawings of supporting insulators & operating rods insulators.
- (xii) Name plat details.
- (xiii) Bill of materials.

Supplier shall furnish of three sets of all the drawings pertaining to the equipment along with ***soft copy*** for each item as the final submission ***for approval***.

1.4 GENERAL DESIGN FEATURES OF ISOLATORS AND ISOLATOR-CUM-EARTHING SWITCHES:

- 1.4.1 The Isolators shall be of double break, outdoor, gang operated type, with blades rotating in horizontal plane. **It should be centre post rotating Turn N Twist type mounted on lattice HDG structure.** The design shall allow for upright mounting, if required, and the Isolators shall be convertible for right or left hand control with minimum labor and replacement of parts. The live parts shall be so designed that as far as possible, sharp points, edges and other corona producing surface are eliminated. Except for the Insulator caps and bases, all other live parts

shall be of anti-rusting and non-corrosive metal. Current carrying parts shall be non-ferrous. Bolts, Screws and Pins shall be provided with locking arrangement and shall be of the best materials.

- 1.4.2 Each pole shall have three Pedestal types of insulators' stacks. Necessary arrangements shall be provided for proper alignment of the contacts. Gang operated links shall be so designed that all phases shall make and break simultaneously.
- 1.4.3 The design of the isolators and isolator-cum-earthing switches shall be provided for positive control of blades in all positions with minimum mechanical stress on the insulators. Fixed guides shall be so provided that proper fitting of contacts shall be obtained, when a blade is out of alignment even by 25mm in either direction. All movable parts which may be in correct path shall be shunted by flexible copper conductor of adequate cross-section and strength.
- 1.4.4 The length of the handle for manual operation shall not be more than one meter. The rotating parts shall have a smooth movement.
- 1.4.5 The clearance of 3700 mm from terminal (Live part) to ground (**up to plinth level**) shall be considered while manufacturing of isolators & to decide location of operating mechanism box.
- 1.4.6 ***Same pole (phase) live part to live part clearance shall be 800 mm minimum.***
- 1.4.7 The isolators/ earthing switch shall be completed with all parts that are necessary or essential for efficient & safe operation. Such part shall be deemed to be within the scope of supply, whether specifically mentioned or not.
- 1.4.8 All similar parts shall be interchangeable.
- 1.4.9 1.4.8 The design of isolator shall be such that no lubrication of any part is required except at vary infrequent intervals i.e. after every 1000 operations or after 5 years whichever is earlier. All joint in link mechanism exposed directly to external environment shall be such materials that they do not call for any periodic lubrication and will not create jamming or excessive play which can result into loss of setting of complete isolator or deformation in links and levers.

1.4.10 Terminal head/stud of isolator arms where conductor will be terminated shall be strong, robust and shall be adequate to carry rated current and short-circuit rating of isolator. It should have built in cover to eliminate deposition of dust or foreign particles.

1.5 TEMPERATURE RISE:

1.5.1 The maximum temperature rise of any part of the isolator and isolator-cum-earthing switch when in service under continuous full load conditions and exposed continuously to the direct sun-rays and air having maximum temperature (as specified in Clause 2.2.1 Section-II of this Specification) shall not exceed the values given below :

SR NO	PART	MAX. TEMP. (°C)
1)	Copper contacts in air a) Silver faced b) Bare	105 75
2)	Terminals of dis-connectors or earthing switches to be connected to external conductors by screws or bolts: a) Silver faced b) Bare	105 90
3)	Metal parts acting as springs.	The temperature shall not reach a value when the elasticity of the material is impaired. For pure copper, this implies as temperature limit of 75 ⁰ C .
4)	Woven wire braids	75
5)	Metal Parts in contacts with insulation of the following classes: a) 'A' (for impregnated material) b) 'Y' (for non-impregnated material) c) 'E' (in air) d) 'B' (in air) e) 'F' (in air)	100 90 120 130 165
6)	Enamel : a) Oil base b) Synthetic in air	100 120

1.6 CONTACTS :

- 1.6.1 The contacts shall be made of hard drawn electrolytic copper strips and shall be heavy duty self-aligning & high pressure contact preferably of the type which apply pressure to the contact surface after the blades are fully closed and release the pressure before they start to open. High pressure type contacts shall wipe the contact surface, when opening and closing. The contacts shall be so designed that wiping action shall not cause scouring or abrasion on the contact surface. The wiping action shall be sufficient to remove oxide film formed during the operation of the switches. The pressure shall be developed by rotation of the entire blade.

The temperature rise due to the flow of rated short circuit current for a period of three seconds shall not cause any annealing or welding of the contacts.

The moving contacts shall be capable of withstanding the highest short circuit current during service. The surface of the contacts shall be smooth and silver plated, with adequate thickness of silver plating.

Current Density:

Current density to be adopted for all part of the Isolator and terminal connector shall not exceed the following limits:

- | | | |
|-----|--------------------------------------|------------------------------------|
| (a) | Hollow tube section | : Copper – 2.0 A/mm ² |
| | | : Aluminum–1.25 A/mm ² |
| (b) | Other sections & terminal connectors | : Copper – 1.60A/mm ² |
| | | : Aluminum – 1.0 A/mm ² |

- 1.6.2 The moving contacts shall be capable of withstanding the highest short circuit current during service. The surface of the contacts shall be smooth and silver plated.
- 1.6.3 The arcing contacts, where provided, shall close first and open last so that no damage due to arcing what so ever shall be caused to the main contacts. The Bidder shall give full details of such contacts with necessary drawings.
- 1.6.4 The female contact and its tensioning by spring shall be such that there will, always, be a positive contact with adequate pressure to give enough contact surfaces for the passing of the current. The springs provided

should not go out of alignment or get entangled with the male contact during operation.

1.6.5 The jaw contacts shall be of copper with silver plating of Min. 20 micron. The contacts shall be accurately machined and self-aligned. Contacts & spring shall be so designed that readjustment in contact pressure shall not be necessary throughout the life of Isolator or earthing switch. The jaw contacts shall be with reverse loop fingers design such that springs shall not carry current & shall not lose their characteristics due to heating effect. The contacts shall be backed by Stainless Steel spring and shall be such that there will always be a positive contact with adequate pressure to give enough contact surfaces for the passing of the current. The springs provided should not go out of alignment or get entangled with the male contact during operation. The details of springs shall be furnished on the G.A. drawing.

1.6.6 The contact shall be self-aligning & self-cleaning & so designed that binding cannot occur after remaining closed for prolonged period of time in a heavily polluted atmosphere.

1.6.7 No undue wear or stuffing shall be evident during mechanical endurance tests.

1.7 OPERATING MECHANISM:

1.7.1 The isolators shall be electrical motor operated and manually operated. The earthing switches shall be manually operated. The mechanism shall provide quick, simple & effective operation. Single person shall be able to operate the isolator, earthing switch without undue effort. The height of the handle above the plinth shall be 1000 mm. This will be stated in the drawing. The operating mechanism shall have smooth movement and shall be so designed that all the three blades are in positive control throughout the entire cycle of operation.

1.7.2 The minimum size of box shall be as follow:

i) Motor operated mechanism box: H550 x W500 x D350 mm

ii) Manual operated mechanism box: H400 x W300 x D200 mm

1.7.3 The operating mechanism shall have smooth movement and shall be designed for simultaneous manual operation of all three phases through

single operating rod of adjustable length and operating mechanism mounted on one end of switch only. Operating mechanism of main switch and earth switch shall be on opposite ends.

- 1.7.4 Position indicators shall be provided near the operating mechanism for 'open' and 'close' position.
- 1.7.5 Provision shall be made for pad locking the mechanism of isolator and earthing switches in both, the 'close' and 'open' position.
- 1.7.6 The isolator and isolator-cum-earthing switch shall be provided with "over center" device in the operating mechanism to prevent accidental opening by such that its stack position will not be affected by wind pressure, vibration, reasonable shocks, short circuit forces, movement of structure, etc.
- 1.7.7 The isolator and isolator-cum-earthing switch shall be such that its set-position will not be affected by wind pressure, vibration, reasonable shocks etc.
- 1.7.8 The operating pipe shall be properly earthed by 25 x 10 mm, 2 nos. of copper flexible strips with box and structure.
- 1.7.9 Auxiliary switches shall be mounted in weather proof housing which shall have provision of entry of conduits of proper size and for fixing of cable glands.
- 1.7.10 The Bidder shall offer the operating mechanism as specified. The design of operating mechanism shall be such that minimum energy is required for operation.
- 1.7.11 The isolator shall be provided with positive continuous control throughout the entire cycle of operation. The operating pipes end rods shall be sufficiently rigid to maintain positive control under the most adverse conditions and when operated in tension or compression for isolator closing. They shall also be capable of withstanding all torsion and bending stresses due to operation of the isolator. Wherever supported the operating rods/pipes shall be provided with bearings. The operating rods/pipes shall be provided with suitable Universal couplings to account for any angular misalignment.
- 1.7.12 After final adjustment has been made there should not be any displacement at any point to allow improper functioning of the isolator during opening and closing operation at any speed. All holes in cranks, linkages and drives through shafts of MOM should be provided with bearing to minimize

slack and lost motion in the entire mechanism. All the linkages rods between poles shall be adjustable eye bolt type only.

- 1.7.13 The design shall be such as to provide maximum reliability under all service conditions. All operating linkages carrying mechanical loads shall be designed for negligible deflection. The length of inter insulator and interpole operating rods shall be capable of adjustments, by means of screw thread which can be locked with a lock nut after an adjustment has been made.
- 1.7.14 All isolators and earth switches shall be provided with detachable type operating handles with padlocking arrangements.
- 1.7.15 All brackets, angles or other members necessary for attaching the operating mechanism to the isolator supporting structure shall be supplied.
- 1.7.16 The control cabinet / mechanism housing shall be stainless steel/aluminum with powder coating and shall be dust, water and vermin proof. The minimum thickness shall be 3.0 mm and properly braced to prevent wobbling. Control cabinet shall be with double hinged single door with padlocking arrangement. Control cabinet shall be of structure mounting type.
- 1.7.17 All doors, removable covers and plates shall be gasketed all round with continuous neoprene gaskets to maintain degree of protection.
- 1.7.18 Cable entries shall be from bottom. Suitable removable cable gland plate of 3 mm thickness shall be provided on the cabinet for this purpose. Necessary number of cable glands shall be supplied fitted on to this gland plate. Cable gland shall be made of Brass.
- 1.7.19 Suitable heaters shall be mounted in the cabinet to prevent condensation. Heaters shall be controlled by differential thermostat so that required temperature is always maintained. ON/OFF switch and fuse shall be provided. Heater shall be suitable for 240 V AC supply voltage.
- 1.7.20 The terminals shall be so staggered that the connection of external cable to any terminal block should be possible without disturbing the rest of the connections. The terminals blocks arrangements shall be such as to provide maximum accessibility to all conductor terminals and any arrangement preventing ready access to other terminal. Only Stud type terminals shall be provided.
- 1.7.21 The terminal blocks to be provided shall be fully enclosed with removable covers and made of molded, non-inflammable plastic material with boxes and barriers molded integrally. Such block shall have washer and binding screws for external circuit wire connections.

- 1.7.22 The arrangement shall be such that it is possible to safely connect or disconnect terminals on live circuits and replace fuse-links when the cabinet is live.
- 1.7.23 The enclosure of the control cabinets shall provide a degree of protection of not less than IP:55 (as per IS:2147).
- 1.7.24 A 'local/remote' selector switch and a set of open/close push buttons shall be provided on the control cabinet of the isolator to permit its operation through local or remote push buttons. Electrical ON / OFF indications shall be provided.
- 1.7.25 Provision shall be made in the control cabinet to disconnect power supply to prevent local/remote power operation.
- 1.7.26 All cabling from operating mechanism and auxiliary contacts to control cabinet shall be in the scope of supply and shall be carried out using 1100 V grade, 2.5 mm² stranded copper conductor, PVC insulated, armored, multi-core cables or single core wires.
- 1.7.27 The control cabinet shall be provided with a 240 V, 1- ϕ , 50 Hz, 40 W lighting for interior illumination controlled by a ON/OFF switch. Power source for this interior lighting shall be completely independent of control power source.

1.8 Motor Operating Mechanism:

- 1.8.1 The motor shall be squirrel cage induction motor/Permanent Magnet DC Motor (PMDC Motor) and shall be totally enclosed, weather proof, outdoor type conforming to the latest edition of IS:325.
- 1.8.2 Suitable reduction gear shall be provided between the motor and the drive shaft of the isolator. The mechanism shall come to standstill immediately on switching OFF the power supply to the motor. If necessary, electromechanical brake shall be fitted on the higher speed shaft to effect rapid breaking.
- 1.8.3 Limit switches for motor control shall be fitted on the isolator shaft, within the cabinet, to sense the open and close positions of the isolator.
- 1.8.4 Motor operating mechanism to be supplied with the isolator shall be of reputed make to assure trouble free performance of the operating mechanism. Bidder should confirm to attend the defects if any without any extra charge within the guarantee period.

1.9 TERMINAL ADOPTERS AND EARTHING TERMINALS:

- 1.9.1 The isolator & isolator-cum-earthing switches shall be with the bimetallic clamp type terminal connectors suitable for ACSR PANTHER / *MOOSE* Conductor as per Schedule A of tender bus connections. The connectors shall be as per IS: 5561 (as amended up to date).
- 1.9.2 Each isolator and isolator-cum-earthing switch shall be with at least two numbers of grounding terminals and clamps for receiving ground connections.
- 1.9.3 Nut bolts shall be of nonmagnetic stainless steel along with two nos of washers & check nuts. The size of nut bolts shall not be less than 12 mm.
- 1.9.4 Terminal connector bimetallic copper plate shall be of 2mm thickness.
- 1.9.5 The drawings of the terminal connectors shall be submitted with the technical bid.
- 1.9.6 The frame of each disconnecter and earthing switch shall be provided with two reliable earthing terminals for connection to an earthing conductor suitable for specified earth fault currents. The earthing conductor will be of GI strip of 50 x 6 mm.

1.10 EARTHING BLADES :

- 1.10.1 The isolators controlling the transmission line shall be equipped with earthing blades. The earthing blades shall be counter balanced to ensure ease of operation.
- 1.10.2 Line earth switches shall consist of three earthing links per isolator which will normally rest against the frames when the connected isolator is in closed position. The earthing links of the three phases shall be capable of being fitted on either side of the isolator.
- 1.10.3 The grounding blades shall have same short time withstand current capacity and of the same materials as the main blades or as per Type Test Reports. Each grounding blade shall be provided with the flexible copper connections of not less than 60 mm² area and of adequate length for connection between the operating shaft and the frame.
- 1.10.4 The rated making capacity of earthing switches shall be as specified in the standard.

- 1.10.5 The earthing switches shall be mechanically and electrically interlocked with the isolator so that the earthing switches can be operated only when the isolator is open and vice versa. The constructional interlocks shall be built in construction of isolator & shall be in addition to electrical & mechanical interlocks provided in the operating mechanism.
- 1.10.6 The plane of movement and final position of the earth blades shall be such that adequate electrical clearances are obtained from adjacent live parts in course of its movement between ON & OFF positions.
- 1.10.7 Two independent grounding studs shall be provided on the frame/base channel stationary portion for connection to station ground mat. The stationary and moving portion shall be connected using flexible copper / aluminum of adequate cross section to withstand the short time current same as that of the earth switch.
- 1.10.8 Isolator design shall be such as to permit addition of earth switches at future date. It should be possible to interchange position of earth switch to either side.
- 1.10.9 The earth switches shall also comply with the requirements of IEC- 60129, (amendment up to date) in respect of induced current switching duty as defined for class 'B' earthing switches.

1.11 INSULATORS:

- 1.10.1 The Insulators used for the isolators and isolator –cum-earthing switches shall be of reputed make and made of best electrical porcelain and shall comply with requirements of IS 2544 and IEC 60168 (as amended up to date) and other relevant standards. The insulators shall be fabricated by wet process. The porcelain and metal parts shall be assembled together with such material and in such manner that any terminal expansion of the metal and the porcelain throughout the range of operating temperature shall not loosen the parts or create undue stresses, affecting adversely the mechanical and electrical strength of the insulators.
- 1.10.2 The Bidder shall offer 36 kV Solid core insulators *with Creepage distance of 25 mm/kV for 11 & 22 kV class and 31 mm/kV for 33 kV class isolators.*
- 1.10.3 Insulators, after inspection, shall be dispatched directly to the consignee from the Works, if the product is of third party, but one set of insulators

from the offered inspected insulators, required for isolators *shall* be brought to isolators metallic manufacturer's works to test complete isolator as per IS/IEC.

1.10.4 Insulators shall be offered in proportion to the isolator metallic sets, offered for inspection.

1.10.5 Clearance for dispatch shall be issued after successful inspection and approval of submitted routine and acceptance test reports for metallic parts of isolators and proportionate quantity of insulators.

1.12 INTERLOCKING:

1.12.1 All Isolators & Earthing Switches shall be electrically & mechanically interlocked by providing castle key type inter locking. This arrangement shall be clearly indicated in the drawing of Isolator cum earthing switch. Failure of power supply or connection to electrical interlock shall not produce or permit faulty operation.

1.12.2 Interlocks are required for:

- (i) Prevention of opening of isolator on load.
- (ii) Prevention of closing of earth switch, when line isolator is closed.
- (iii) Prevention of closing of isolator, when earth-switch is closed.

1.12.3 Provision shall be made for interlocking isolators with circuit breakers so that these are closed, before the circuit breaker is closed and opened, after the circuit breaker is opened.

1.12.4 The details of interlocking system shall be furnished by the Bidder and shall be subject to the Purchaser's approval.

1.12.5 Interlocking arrangement shall be fail safe type.

1.13 AUXILIARY SWITCHES:

1.13.1 Auxiliary switches for isolator are to be provided both for main and earth switches and shall be mechanically actuated by the corresponding, operating mechanism. Six (6) number of each normally 'Open' and normally 'Close' contacts along with 2NO + 2NC MBB with One spare shall be provided. Design which permits the change of normally 'close' contact to normally 'open' contact

or vice versa with minimum modification would be preferred. Switches shall be provided with provision for indication of switch position, electrical interlocking, remote semaphores etc.

1.13.2 Each auxiliary switch for earthing switch shall be equipped with four (4) numbers of normally 'Open' & normally 'Closed' spare auxiliary contacts with One MBB spare contact in addition to those mentioned above.

1.13.3 Auxiliary switches shall be mounted in a weatherproof housing, suitable for IP: 55 degree of protection which shall have provision for entry of cables of proper size and for fixing of cable glands.

1.13.4 Isolator's motor operating mechanism shall be equipped with CAM type independently adjustable auxiliary contacts. It shall be possible to field adjust the cams of each micro switch. The regulation of each cam shall be possible without loosening all other cams; other nonadjustable signalization devices (commutators) are not acceptable.

1.13.5 Signaling of the closed position shall not take place unless it is certain that the movable contacts have reached a position in which the rated normal current, the peak withstand current and the short time withstand current can be carried safely. Limit position switches shall be provided for this signaling.

1.13.6 The signalization device shall be housed inside the mechanism to ensure direct and reliable correspondence between the position of the mechanism and the position of disconnecter. On pipe mounted auxiliary contacts are not acceptable.

1.13.7 Signaling of the open position shall not take place unless the movable contacts have reached a position such that the clearance between the contacts is at least 80% of the isolating distance.

1.14 BEARING:

1.14.1 The design and construction of the various bearing shall ensure satisfactory operation for long period under all climatic conditions specified. Bearing housing shall be weather-proof. Facilities shall be provided for lubrication of the bearings. All bearings shall be with first filling of grease.

1.14.2 The rotating insulator stacks shall be provided with double roller or double ball bearings of reputed make and shall be adjustable as per cl.

1.14.1.4 and easily accessible for dismantling in the field. The vertical operating shaft of requisite length shall be supported on ball or roller thrust bearings. Bearing housing shall be weather & dust proof designed to operate without lubrication or maintenance. Nipples for periodical greasing are not allowed. The details of type designation, No & make of bearings shall be stated on the drawing. Bottom bearing assembly of the base frame shall be sealed such that there can not be ingress of Dust / water etc. Whole assembly shall be lubricated for life long service.

1.14.3 All bearings installed in the current path except those specifically designed on higher pressure contacts shall be shunted by flexible copper conductors of adequate cross-section.

1.15 Base:

1.15.1 Each isolator shall be provided with complete galvanized steel based with holes and designed for mounting on a supporting structure.

1.15.2 Base channels and other structural steel members such as operating pipes, phase coupling rods or pipes, bolts etc. shall be hot dip galvanized. All castings accept current carrying parts shall be made of malleable cast iron or cast steel. Grey iron shall not be used in the manufacture of any parts. Manual operating handles shall be of G I pipe of class B.

1.15.3 All the handles shall be covered with high voltage heat shrinkable insulating sleeve (not tape) having insulation of 12 kV min. Necessary type test & routine test report shall be submitted.

1.15.4 Provision of continuous adjustment/alignment of insulator shall be there which is required to compensate permitted tolerances of insulator and structure or base frame assembly. Adjustment / alignment using shim washer is not allowed.

1.16 GALVANISING:

1.16.1 All ferrous parts of the Isolators including mechanism housing shall be hot-dip galvanized as per IS2629 (as amended upto date) and structural parts of Isolators shall be hot-dip galvanized as per IS 4759 (as amended upto date).

1.17 PAD LOCKS:

- 1.17.1 Padlocks or any other locking arrangement shall be provided for locking the operating handle of each isolator and earthing switch in the 'ON' & 'OFF' positions. The locking arrangement shall be of approved design.

1.18 ACCESSORIES:

1.18.1 Position Indicator

A position indicating device shall be provided for each isolator/earthing switch irrespective material at opposite ends, brazed to the channel base for connecting to the grounding system.

1.18.2 Grounding Pads

Each pole of the isolator shall be provided with two grounding studs of non-corrosive material at opposite ends, brazed to the channel base for connecting to the grounding system. Flexible copper ground connector shall be provided for connecting operating handles of isolators and earthing switches, to the grounding system.

1.18.3 Name Plate

A weather-proof and corrosion-proof name plate conforming to the requirement of IEC shall be provided. The name plate shall also include all the details of ratings, year of manufacture, PROPERTY OF GETCO, order reference, Manufacturers name & address, etc. Name plate shall be of stainless steel of 2 mm thickness. All the letters shall be engraved on the name plate.

1.19 TESTS:

The Isolators and Isolator-cum- Earthing Switches shall be subjected to the various type, acceptance and routine tests as per IS 9921 – 1985 (as amended upto date) and IEC 60129 (as amended upto date).

1.19.1 ROUTINE TESTS:

The routine tests shall be conducted at the Works of the Manufacturer of Isolators and Isolators-cum – earthing Switches along with Insulators offered for supply as stipulated in IS 9921 – 1985 and/or IEC 129 (both as amended upto date), including power frequency voltage (dry) test of the main circuit on the offered lot.

- (a) Routine tests / Acceptance tests shall be carried out on insulators & Isolators as per applicable standards, in the presence of GETCO representative.
- (b) The routine test certificates of insulators' manufacturer for offered lot of Isolators shall be submitted along with each inspection call.
- (c) **Mechanical operation test & temperature rise test on selected sample** shall be conducted on isolator (main switch and earth switch) at the supplier's works.

1.19.2 TYPE TESTS:

All the Isolators, earthing switch along with Insulators and Structure offered shall be fully tested for following tests from NABL accredited laboratory shall be carried out in accordance with latest / amended / up to date IS/IEC. The bidder has to submit the all type test reports as stated hereunder for the offered item along with the technical bid. The type test reports from NABL approved laboratory shall not be older than TEN years. Type Test shall be valid as on the last date of submission of bid.

IMPORTANT NOTE: *In case of non-submission/partial submission or type test reports of which validity is over, bidder shall submit pending type test report/s from NABL accredited laboratory, in the event of an order, before commencement of supply without affecting delivery schedule, free of cost to GETCO. Confirmation for above shall be invariably submitted along with technical bid.*

Following Type test reports shall be submitted.

- i) **Lightning Impulse Voltage withstand test**
- ii) **Power Frequency Voltage (Wet) withstand test on main circuit.**
- iii) **Power Frequency Voltage (2 kV) withstand test on auxiliary circuit.**
- iv) **Temperature rise test on main isolator**
- v) **Short Time Current & peak withstand current test on isolator and earthing switch.**
- vi) **Operating and mechanical endurance test on isolator and earthing switch**
- vii) **STC test on terminal connector**
- viii) **Degree of protection test on cubicle**
- ix) **Mech & Elect Endurance test on Auxiliary switch**
- x) **Galvanizing test**
- xi) **Tests on insulator (Dielectric and mechanical load tests)**
 - (1) 1.2/50 microsecond lightning impulse voltage withstand test.
 - (2) 50% impulse voltage flashover test.
 - (3) PF voltage withstand test (Dry & Wet)
 - (4) PF voltage flashover test (Dry & Wet)
 - (5) Visible discharge test
 - (6) Porosity test
 - (7) Mechanical strength test.
 - (8) RIV test
 - (9) Visual inspection & Dimension test.

- 1.19.3 All tests on galvanized components shall be conducted according to IS 2633 – 1972 (as amended upto date)
- 1.19.4 All routine and acceptance test reports in spiral bound volume shall be submitted and got approved from the Purchaser before dispatching the equipment.
- 1.19.5 All the acceptance tests shall be performed on selected isolator/earthing switch after erecting on offered structure or in case of without structure on dummy structure, in the presence of purchaser's representative.
- 1.19.6 The routine tests shall be conducted at the works of manufacturer on isolators and isolators-cum-earthing switches along with insulators offered for supply.
- 1.19.7 Following Routine / Acceptance tests shall be carried out.
- i) Power frequency voltage dry withstand test on main circuit with offered insulators.
 - ii) Voltage tests on control and auxiliary circuits
 - iii) Measurement of resistance of main circuit
 - iv) Mechanical operation test on isolator and earthing switch (50 operating cycles at rated auxiliary supply or hand operated & 10 operating cycles each at maximum and minimum auxiliary supply)
 - v) Block Rotor Test
 - vi) Temperature rise test at rated current on one selected sample out of every offered lot
- 1.19.8 All tests on galvanized components shall be conducted according to IS: 2633 (latest edition).
- 1.19.9 The purchaser reserve right of having at his own expense any other test(s) of responsible nature carried out at supplier's works or at site or in any other place in addition to the aforesaid type and routine tests, to satisfy that the material confirms to with this specification.
- 1.19.10 Successful bidder shall offer PROTO isolator for inspection. On approval of this manufacturing clearance shall be given. Inspections may be carried out at any stage of manufacture at the discretion of the GETCO. If found unsatisfactory, as to workmanship or quality of material,

equipment is liable to be rejected. Bidder shall grant free access to the places of manufacture purchaser's representative at all items when the work is in progress. The bidder shall keep the purchaser informed well in advance about the progress of the manufacture of the equipment under this specification so that urgent can be made for inspection.

1.20 TROPICALISATION:

- 1.20.1 The equipment and its accessories shall, by means of any of dip coating, shall be protected against fungus growth and other harmful effects due to tropical environments.

1.21 SPARE PARTS:

- 1.21.1 The bidder shall furnish an item wise list and quantity of recommended spare parts, if any, with unit price of each part for five years' operation of the air break Isolators. If required, the purchaser will decide the actual quantity of spares to be ordered on the basis of the list and the item wise prices quoted.

1.22 GUARANTEED TECHNICAL PARTICULARS:

- 1.22.1 The bidder shall furnish complete guaranteed technical particulars as per Appendix-I of Section III of this specification. Particulars which are subject to guarantee shall be clearly marked. Bids without this information will not be considered.

1.23 MANUFACTURING QUALITY PLAN AND INSTRUCTION MANUALS:

Three (3) copies of manual of erection, operation and maintenance, MQP & FQP, in English language shall be furnished during drawing approval and to each consignee. The manuals shall be in bound volumes and shall contain all the printed drawings and information required for erection, operation & maintenance and with the following particulars:

- a) Marked prints for details of erection identifying the component parts of Isolators as dispatched with assembly drawings.
- b) Detailed dimensions of assembly and description of all the auxiliaries.
- c) List of spare parts, if any.
- d) Literature / leaflet for offered insulators

1.24 PACKING AND TRANSPORT INSTRUCTIONS:

1.24.1 Bidder shall ensure that all equipment covered by this specification shall be prepared for rail/road transport and be packed in such a manner as to protect it from damage in transits. The Bidder shall be responsible for and make good at his own expense any or all damaged due to improper preparation and packing.

1.24.2 Loose material, e.g. bolts, Nuts etc. shall be packed in gunny bags and sealed in polythene bags with proper tagging.

1.24.3 Components containing glass shall be carefully covered with shock absorbing protective material such as 'Thermocol'.

1.24.4 All opening in the equipment shall be tightly covered, plugged or capped to prevent dust and foreign material from entering in.

1.24.5 Wherever necessary, proper arrangements for attaching slings for lifting shall be provided.

1.24.6 All spare parts shall be packed and treated for long storage conditions at site.

1.24.7 Any material found short inside the intact packing cases shall be supplied by the bidder at no extra cost to the purchaser.

1.24.8 No material shall be dispatched without prior consent of the purchaser or his authorized representative.

1.25 BAR CHART:

The bidder shall furnish a bar chart along with Bid incorporating significant milestone dates, e.g. for completion of engineering and design of procurement of critical raw material of bought out items, of manufacturing and testing and of transportation to site and erection, as may be applicable. The total period for all the above activities as applicable should not exceed the completion period.

SEAL OF THE FIRM

SIGNATURE OF TENDERER

TECHNICAL SPECIFICATION FOR 22 kV ISOLATORS & ISOLATOR – CUM – EARTHING SWITCHES

SECTION – II

SPECIFIC TECHNICAL REQUIREMENTS

2.1 SCOPE:

2.1.1 This section covers the specified technical requirements, climatic and isoceraunic conditions, system particulars etc. for which the isolators and Isolator-cum-Earthing Switches shall be offered.

2.2 CLIMATIC AND ISOCERAUNIC CONDITIONS:

2.2.1 The climatic and Isoceraunic conditions of site are as under:

(a)	Maximum ambient temperature in shade (°C)	:	50
(b)	Minimum ambient temperature in shade (°C)	:	4
(a)	Maximum daily average ambient temp. (°C)	:	40
(b)	Maximum yearly average ambient temp. (°C)	:	30
(c)	Maximum relative humidity (%)	:	95
(d)	Average rainfall per annum (Cm)	:	115
(e)	Average No. of thunder storm (Days per annum)	:	15
(f)	Maximum wind pressure (Kg/m ²)	:	150
(g)	Height above sea level - Not exceeding – Mtrs	:	1000

2.2.2 The equipments offered shall be suitable for continuous operation at their full rated capacity under above conditions.

2.2.3 The equipments offered shall be suitable for heavily polluted atmosphere.

2.3 SYSTEM DETAILS:

2.3.1 The Electrical system data, under which the equipment proposed is supposed to operate, are as under. However, the ratings shall be as specified in this specification.

a.	Nominal voltage	<i>33 kV</i>	22 kV	<i>11 kV</i>
b.	Maximum voltage	<u>36</u>	<u>24</u> kV	12 kV
c.	Frequency	50 Hz		
d.	Number of phases	3		
e.	Neutral Earthing	Solidly earthed		
f.	Auxiliary supply voltage	I - AC→ 240 V, 1 ϕ , 50 Hz II - AC→ 415 V, 3 ϕ , 50 Hz, 4-Wire, III - DC→ 110 V, 2 Wire. IV- AC control for motor operating Mechanism: 415 V, 3-phase, 4 wire, neutral grounded AC supply		

2.3.2 The frequency can vary between $\pm 3\%$ of normal value of 50 Hz and AC voltage would vary from 110% to 85% of the normal value. The DC supply is subject to variation of $\pm 10\%$.

2.3.3 TYPE AND RATING:

The Isolators and Isolator-cum-Earthing Switches shall comply with the following technical requirements:

1	Nominal voltage	<i>33 kV</i>	22 kV	<i>11 kV</i>
2	Highest system voltage	<i>36</i>	24 kV	12 kV
3	Rated Frequency	50 Hz		
4	Number of phases	3		
5	Rated current (Amps.) <i>(as specified in Schedule – A of respective tender)</i>	<i>1250 / 630 / 400 A</i>		
6	Rate short time current (KA rms)	25		
7	Rated duration of short circuit current	3 sec		
8	Basic Insulation level (kV)			
i	Standard impulse withstand voltage + ve and - ve polarity			

a.	Across the Isolating distance (kV peak)	195	195	85
b.	To earth and between poles (kV peak)	170	170	75
ii	One minute power frequency withstand voltage (Dry & Wet)			
a.	Across the Isolating distance (kV peak)	100	100	32
b.	To earth and between poles (kV peak)	75	75	28
9	Minimum total creepage distance, in mm; (suitable for Heavily polluted atmosphere)	1116	900	600
10	Type of Isolators and Isolator-cum-Earthing	Double Break, Outdoor, Triple pole, Mechanically Gang operated(Manual or motor operated) type with or without earthing switch, as specified in schedule – A of respective tender.		
11	Interruption capacity: (i) Magnetizing current: 0.7 Amps. At 0.15 P.F. (ii) Line charging current	0.7 Amps. At 0.15 P.F. 0.7 Amps. At 0.15 P.F.		
12	Safe duration of over load: (a) 150% of rated current: 5 minute (b) 120% of rated current	5 minute 30 minute		
13	Rated ambient temperature for Temperature rise	50 °C		
14	Auxiliary contacts on Isolator	6 NO & 6 NC (Additional 2 NO & NC as spare) MBB contacts: 2 NO & NC (Additional 1 NO & 1 NC)		
15	Auxiliary contacts on earthing switch	6 NO & 6NC (Additional 1 NO & 1 NC)		

2.4 PROTECTION AGAINST EARTHQUAKE AND WIND DESIGN LOAD :

2.4.1 Each Isolator and Isolator-cum-Earthing Switch shall be designed to withstand repeated earthquake acceleration of 0.08 x 2g and wind loads of 150 kg/m² on the projected area (non-simultaneous) without damage and without impairment of operation.

SEAL OF FIRM

SIGNATURE OF TENDERER

SCHEDULE OF GUARANTEED TECHNICAL PARTICULARS OF 33 / 22 / 11 kV ISOLATORS & ISOLATOR-CUM-EARTHING SWITCHES

APPENDIX - I

(TO BE FILLED IN BY THE BIDDER)

1.	Name & address of manufacturer	:	
2.	Type of Isolators (Rotating / turn & twist / horizontal break)	:	
3.	Governing standard	:	
4.	Suitable for Outdoor operation (Yes/No)	:	
5.	(a) Rated normal voltage (KV) (b) Rated Highest system voltage (KV)	:	
6.	Frequency (Hz)	:	
7.	Rated current of isolator (Amps.)	:	
8.	No. of poles	:	
9.	(a) Maximum capacity for interrupting magnetizing current of transformers or charging current of line when equipped with arcing contacts. (b) Maximum capacity for interrupting magnetizing current of transformers or charging current of line when not equipped with arcing contacts.	:	
10.	No. of operations possible without deterioration of contacts	:	
11.	Rated short time current (kA rms) for 3 seconds.	:	

12.	Rated peak short circuit current (kAp)	:
13.	<i>Rated short time current for 3 seconds of earthing switches (kAmps)</i>	:
14.	Type of mounting	:
15.	Phase – Centre - Phase clearance (mm)	:
16.	Minimum phase to phase clearance (mm)	:
17.	a) Minimum phase to ground clearance (mm) (up to plinth level) b) Minimum clearance from base channel to ground (mm) c) Between live parts when switch is open	: : :
18.	No. of solid core post insulators	:
19.	No. of breaks per phase	:
20.	Type of interlock between isolating switch and earth switch	:
21.	Total minimum creepage distance suitable for heavily polluted atmosphere (mm)	:
22.	Main contacts (fixed and moving) a) Type (1) Moving contact (2) Fixed contact (reverse loop type) b) Material & grade c) Whether contacts silver plated (Yes / No) d) Minimum Thickness of silver coating (mm) e) Contact area in sq.mm.	: For Main Isolator For Earth Switch : : : : : : : :

	f) Size of material used: (1) Moving contact (2) Fixed contact g) Cross Sectional area (1) Moving contact (mm^2) (2) Fixed contact (mm^2) h) Current density (at rated current) (1) Moving contact (A/mm^2) (2) Fixed contact (A/mm^2) i) Contact pressure in Kg. 1) Moving contact (A/mm^2) 2) Fixed contact (A/mm^2) j) Current carrying capacity (Amp.)	:
23.	Arcing contacts: a) Type b) Material c) Whether contacts silver plated (Yes / No.) d) Minimum Thickness of silver coating (mm) e) Current carrying capacity (Amps.)	: : : : :
24.	Terminal pad (1) Material (2) Size (3) Current density	: : :
25.	Contact support (main and earth switch) (i) Material and size of channel/block (ii) Material and size of plate	: :
26.	Turn and twist mechanism (i) Material and size of clamp (ii) Material and size of spring (iii) whether springs are enclosed	: : :
27.	Whether bearings as per specification are provided. a) Type b) Make c) Nos.	:

28.	Location and Number of bearing per each phase	:
29.	Weight of one complete pole (kg.)	:
	<u>OPERATING MECHANISM :</u>	
30.	Whether separate operating mechanism provided for operation of main blades and earthing blades.	:
31.	Height of location of operating handle above foundation (mm).	:1000 mm
32.	Length of operating handle (mm)	:
33.	i) Torque required for operation of isolator (kgm) ii) Time required for opening and closing of main & earth switch	: :
34.	Insulation Levels: i) 1.2/50 microsecond dry impulse withstand voltage (Positive and negative polarity) (KV peak) (a) Across the isolating distance (b) To earth and between poles	: : :
35.	i) One-minute power frequency withstands voltage (dry) (KV rms.) (a) Across the isolating distance (b) To earth and between poles ii) One minute power frequency withstands voltage (wet) (KV rms.)	: : : :
36.	Visible corona discharge voltage (KV rms.)	:
37.	Temp. rise of main contact at rated current corresponding to ambient temperature of air in shade ($^{\circ}\text{C}$)	:

38.	Maximum temp. rise of main contact at rated short time current for 3 second ($^{\circ}\text{C}$)	:
39.	Rated mechanical terminal loads (excluding wind loads (Kg.))	:
40.	<u>CONTROL CABINET</u> a) Material b) Thickness c) Size d) Electrical ON/OFF indication e) Type of motor f) Rating of motor g) Degree of protection h) Material & thickness of gasket i) Cable gland plate Material & thickness	: : : : : : : :
	<u>DETAILS OF SOLID CORE POST INSULATORS:</u>	:
41.	Maker's type designation	:
42.	Applicable Standard and Drawing no.	:
43.	i) No. of units per stack ii) Height of stack Diameter of largest & smallest shed	:
44.	Total creepage distance in mm	:
45.	(a) Rated Voltage (b) Highest System Voltage	
46.	1 Minute power frequency withstand voltage (Dry & wet) (KV rms.)	:
47.	1 Minute Power Frequency flash over voltage (Dry and Wet) (KV rms)	:
48.	1.2/50 microsecond lightning impulse withstand voltage (kV peak)	:
49.	Standard dry impulse flashover voltage (kV peak)	:

50.	Minimum visible corona discharge voltage (kV rms)	:
51.	Puncture voltage (kV rms)	:
52.	Tensile and compressive strength (Kg).	:
53.	Torsion and Cantilever strength (Kg).	:
54.	Galvanizing: i) Applicable standard ii) Method of Galvanizing. iii) Weight of zinc coating (gm/cm ²)	:
55.	i) Top PCD ii) Bottom PCD	: :
56.	Provision of continuous adjustment/alignment of insulators	:
57.	Loading details for design of foundation i) For isolator ii) For isolator-cum-earthing switches	: :
58.	Weight, space requirement etc. i) Weight of complete isolator with operating mechanism, supports etc. ii) Weight of complete isolator and isolator-cum-earthing switch with operating mechanism supports etc. iii) Space required for Isolators (L x W x H) iv) Space required for Isolators-cum-earthing switch (L x W x H)	: : : : : : : :
59.	Details of earth blade (a) Material (b) Rated current (c) Size (Diameter – mm)	

60.	<p>BASE Material (Hot dip galvanized)</p> <p>SIZE</p> <p>WEIGHT</p>	<p>:</p> <p>:</p>
61.	<p>Insulating sleeve for operating handle</p> <p>(a) Make</p> <p>(b) Rating</p> <p>(c) Type</p>	<p>:</p> <p>:</p> <p>:</p>
62.	<p>Type of auxiliary contacts</p> <p>(i) For isolator (Normal)</p> <p>(Spare)</p> <p>(ii) For earth switch (Normal) (Spare)</p> <p>(iii) MBB contacts (Normal)</p> <p>(Spare)</p>	
63.	<p>No. of auxiliary contacts</p> <p>(i) For isolator (Normal)</p> <p>(Spare)</p> <p>(ii) For earth switch (Normal) (Spare)</p> <p>(iii) MBB contacts (Normal)</p> <p>(Spare)</p>	
64.	<p>Terminal connectors</p> <p>(a) Material of connector</p> <p>(b) Material of Nut/Bolts</p> <p>(c) Range of diameter of conductors</p>	

	<p>that can be received</p> <p>(d) Maximum temperature rise when carrying rated current at 50 0C ambient temperature</p> <p>(e) Weight of each type of connector (kg)</p> <p>(f) whether horizontal/vertical take-off</p> <p>(g) Flexible/rigid</p>	
65.	<p>RATING/NAME PLATE</p> <p>a) Material</p> <p>b) Thickness</p> <p>c) Size</p> <p>d) Depth of engraving letters</p>	
66.	<p>Type of Interlocks:</p> <p>a) Constructional</p> <p>b) Mechanical</p> <p>c) Electrical</p>	

SEAL OF THE FIRM

SIGNATURE OF TENDERER