

<b>Annexure - 5</b>		
<b>Details of Illumination for Switch yard</b>		
<b>Sr. No.</b>	<b>Location</b>	<b>Details</b>
1	66kV switch Yard	
a	Height of transformer	5
b	Equipments Height from Ground	4.0 Mtr+0.3 Mtr plinth
2	Lux level Required for main Equipments	50
3	Lux level rquired for Other area	20
4	Lux level required for follwing amminities	
a	Parking Area	20
b	Main Roads ( Post Top Lantern)	20
5	Fencing Light and Spare Area ( Street Light)	20