

| EXI. TOWER SCHEDULE | | | | | | | | | | | | | | | | | | | | | |
|---------------------|-------------------------|-----------------|---------------|-----------|----------------|--------------------|-----------------|---|----------------|----------------|-------------|--------------------|-----------------------|--------------------|-----------------------|--------|------------------|------------------------------------|----------------------------------|----------------------|--|
| Sr. No. | Exi. Loc.No. | Deviation Angle | Type Of Tower | Span | Section Length | Type Of Foundation | Isulator Detail | Remarks / Crossing Details | HTLS Conductor | Suspension SRI | Tension SRI | Single Tension H/W | Single Suspension H/W | Double Tension H/W | Double Suspension H/W | PA Rod | Vibration Damper | Mid Span Joints for HTLS Conductor | Repair Sleeve for HTLS Conductor | T connector with pad | Jumper terminal without hole with suitable |
| | | | | (In Mtr.) | | | | | | | | | | | | | | | | | |
| 0 | Exi.220kv Karamsad S.S. | 00°0'00" | Gantry | | 0 | | | | | | 3 | 3 | | | | | 3 | | | 3 | 6 |
| | | | | 85 | | | | Cart Track | 255 | | | | | | | | | | | | |
| 1 | Exi.Loc-01 | 82°49'41"RT | C TYPE DP | | 85 | | 1 | | | 3 | 6 | 6 | 3 | | | 3 | 6 | | | | |
| | | | | 125 | | | | Cart Track | 375 | | | | | | | | | | | | |
| 2 | Exi.Loc-02 | 1°51'50"LT | B TYPE DP | | 125 | | 1 | | | | 9 | 3 | | 3 | | | 6 | | | | |
| | | | | 175 | | | | Exi.220kv Kasor - Karamsad Line | 525 | | | | | | | | | | | | |
| 3 | Exi.Loc-03 | 65°30'49"RT | C TYPE DP | | 175 | | 1 | | | 3 | 9 | 3 | 3 | 3 | | 3 | 6 | | | | |
| | | | | 96 | | | | 11kv Line & Cart Track | 288 | | | | | | | | | | | | |
| 4 | Exi.Loc-04 | | A TYPE DP | | | | 1 | | | 3 | | | 3 | | | 3 | 6 | | | | |
| | | | | 105 | | | | | 315 | | | | | | | | | | | | |
| 5 | Exi.Loc-05 | 24°25'37"LT | B TYPE DP | | 201 | | 2 | | | | 9 | 3 | | 3 | | | 6 | | | | |
| | | | | 132 | | | | Exi.220kv Karamsad - Ranasan Line , Road , Lt Line & 11kv Line 2 Nos. | 396 | | | | | | | | | | | | |
| 6 | Exi.Loc-06 | 2°7'21"LT | B TYPE DP | | 132 | | 2 | | | | 9 | 3 | | 3 | | | 6 | | | | |
| | | | | 181 | | | | Lt Line 2 Nos. , 11kv Line & Road & Cart Track | 543 | | | | | | | | | | | | |
| 7 | Exi.Loc-07 | | A TYPE DP | | | | 1 | | | 3 | | | 3 | | | 3 | 6 | | | | |
| | | | | 148 | | | | 11kv Line 2 Nos. | 444 | | | | | | | | | | | | |
| 8 | Exi.Loc-08 | | A TYPE DP | | | | 1 | | | 3 | | | 3 | | | 3 | 6 | | | | |
| | | | | 168 | | | | Canal | 504 | | | | | | | | | | | | |
| 9 | Exi.Loc-09 | | A TYPE DP | | | | 2 | | | 3 | | | 3 | | | 3 | 6 | | | | |
| | | | | 171 | | | | Road , Lt Line & 11kv Line | 513 | | | | | | | | | | | | |
| 10 | Exi.Loc-10 | 3°16'54"RT | B TYPE DP | | 668 | | 2 | | | | 6 | 6 | | | | | 6 | | | | |
| | | | | 125 | | | | | 375 | | | | | | | | | | | | |
| 11 | Exi.Loc-11 | | A TYPE DP | | | | 1 | | | 3 | | | 3 | | | 3 | 6 | | | | |
| | | | | 127 | | | | 11kv Line | 381 | | | | | | | | | | | | |
| 12 | Exi.Loc-12 | | A TYPE DP | | | | 2 | | | 3 | | | 3 | | | 3 | 6 | | | | |
| | | | | 109 | | | | 11kv Line 2 Nos. , Lt Line & Road | 327 | | | | | | | | | | | | |
| 13 | Exi.Loc-13 | | A TYPE DP | | | | 2 | | | 3 | | | 3 | | | 3 | 6 | | | | |
| | | | | 94 | | | | | 282 | | | | | | | | | | | | |
| 14 | Exi.Loc-14 | 11°12'36"RT | B TYPE DP | | 455 | | 1 | | | | 6 | 6 | | | | | 6 | | | | |
| | | | | 124 | | | | | 372 | | | | | | | | | | | | |
| 15 | Exi.Loc-15 | | A TYPE DP | | | | 1 | | | 3 | | | 3 | | | 3 | 6 | | | | |
| | | | | 152 | | | | Lt Line | 456 | | | | | | | | | | | | |
| 16 | Exi.Loc-16 | | A TYPE DP | | | | 2 | | | | | | | | | | | | | | |

| Exi.66kv H-Frame Karamsad-Vidyanagar Line - 2 | | | | | | | | | | | | | | | | | | | | | | |
|---|--------------------------|-----------------|---------------|-----------|----------------|--------------------|-----------------|----------------------------|----------------|----------------|-------------|--------------------|------------------------|--------------------|------------------------|--------|------------------|------------------------------------|----------------------------------|----------------------|--|--|
| EXI. TOWER SCHEDULE | | | | | | | | | | | | | | | | | | | | | | |
| Sr. No. | Exi. Loc.No. | Deviation Angle | Type Of Tower | Span | Section Length | Type Of Foundation | Isulator Detail | Remarks / Crossing Details | HTLS Conductor | Suspension SRI | Tension SRI | Single Tension H/W | Single Suspendio n H/W | Double Tension H/W | Double Suspendio n H/W | PA Rod | Vibration Damper | Mid Span Joints for HTLS Conductor | Repair Sleeve for HTLS Conductor | T connector with pad | Jumper terminal without hole with suitable | |
| | | | | (In Mtr.) | | | | | | | | | | | | | | | | | | |
| 23 | Exi.Loc-23 | 1°16'54"RT | DR+0 | | 246 | | 2 | | | | 9 | 3 | | 3 | | | 6 | | | | | |
| | | | | 95 | | | | Road | 285 | | | | | | | | | | | | | |
| 0 | Exi.66kv Vidyanagar S.S. | 00°0'00" | Gantry | | 95 | | | | | | 6 | | | 3 | | | 3 | 6 | 6 | 3 | 6 | |
| Total Length in (mt) | | | | | | | | | 3080 | 3080 | | | | | | | | | | | | |
| Total Length in (km) | | | | | | | | | 3.080 | | | | | | | | | | | | | |
| | | | | | | | | | 9240 | 33 | 129 | 51 | 33 | 39 | 0 | 33 | 144 | 6 | 6 | 6 | 12 | |
| | | | | | | | | | 9.24 | | | | | | | | | | | | | |
| | | | | | | | | | 0.0462 | 5 | | 5 | 5 | | | | | | | | | |
| | | | | | | | | Total HTLS Conductor | 9.286 | 38 | 129 | 56 | 38 | 39 | 0 | 33 | 144 | 6 | 6 | 6 | 12 | |