

KARNATAKA POWER TRANSMISSION CORPORATION LIMITED

No. CGM(Tech)/DGM(APCC & Proc)/EE-3/AEE-7/2026-27/1962

Date 20 JUN 2026

PROCEEDINGS OF PRE-TENDER(PRE-BID) MEETING

Proceedings of the Pre-Tender Meeting held on 16.06.2026 @ 12:00Hrs at 11TH Floor , Indhana Bhavan chaired by Chief General Manager(Tech), KPTCL to discuss the issues pertaining to Tender of the following work floated vide Notification CGM(Tech)/DGM(APCC&PROC)/EE-(Proc-3/AEE-7/2026-27/1370-386 dated 05.06.2026 published in News Papers on 06.06.2026 for the Bid enquiry Nos. **KPTCL/2026-27/TL/WORK INDENT3802** - for **Combined package of: Work A:a)** Strengthening of existing 220kV DC line from 220/66/11kV Bidadi R/s to 220/66/11kV Somanahalli R/s by replacing DRAKE conductor to AAAC MOOSE conductor.

b) Strengthening of 220 kV Terminal Bays at 220kV Bidadi R/s for Strengthening of existing 220kV DC line from 220/66/11kV Bidadi R/s to 220/66/11kV Somanahalli R/s by replacing DRAKE conductor to AAAC MOOSE conductor.

c) Strengthening of 220 kV Terminal Bays at 220kV Somanahalli R/s for Strengthening of existing 220kV DC line from 220/66/11kV Bidadi R/s to 220/66/11kV Somanahalli R/s by replacing DRAKE conductor to AAAC MOOSE conductor.

Work B: Estimate for strengthening of existing 220kV Hoody-EPIP & 220kV Hoody-ShobhaDreams double circuit lines by replacing existing Drake to High Performance Conductor (HPC) of Ampacity - 1400 Ampere, Replacing existing 24F OPGW by proposed 48F OPGW and providing 03Nos of Intermediate towers in existing corridor and double circuit towers and Modification of 02No's of terminal bays at 400/220kV Hoody, 01No of terminal bay at 220/66kV EPIP GIS & 01No of terminal bays at 220/66kV Shobha Dreams.

on Total Turnkey Basis including Supply of all matching Materials/Equipments and Erection (Including Civil and dismantling Works) of all Materials/ Equipment, Testing and Commissioning.

KPTCL Officers Present in the meeting:

Sriyuth/Smt.

Sl. No.	Name of the Officer	Designation
1.	Chethan D	Chief General Manager(Tech), Corporate Office
2.	Rajakumar S. Biradar	Deputy General Manager, APCC & Procurement, Corporate Office
3.	K.C. Krishnamurthy	Executive Engineer(Ele) O/o CGM(T)
4.	Basanth kumar	Asst Executive Engineer(Ele) O/o CGM(T)
5.	Nataraj N	Asst Executive Engineer(C) O/o CGM(T)
6.	Hemanth kumar	Asst Engineer(C) O/o CGM(T)

Representatives of the firms participated in the meeting:

Sl no	Name of the representative	Name of the Firms/Tenderers
NIL		

At the outset, the Chief General Manager(Tech), Corporate Office, KPTCL welcomed all the Officers of KPTCL present in the Pre-Tender meeting. No Bidders participated in the Pre-Tender meeting.

Since, none of the Bidders had participated in the Pre-Tender meeting and also it was noted that no queries have been raised in writing by the prospective bidders, the meeting was concluded with vote of thanks.


20/6/26
Chief General Manager (Tech),
KPTCL

Copy to,

1. EA to D(O), KPTCL, Kaveri Bhavan, Bangalore with a request to place before the Director (O).
2. MF.