



# **TENDER BOOKLET**

## **TECHNICAL BID**

<b>TENDER NO.</b>	<b>DGBPS_07_121A_S_76061_IMD RFQ-76061</b>
<b>SECTION</b>	<b>IMD</b>
<b>SUBJECT</b>	<b>SUPPLY OF FLOW METERS FOR CCPP-1, 2, 3 &amp; COLONY AREA FOR GSECL, DGBPS.</b>



**GUJARAT STATE ELECTRICITY CORPORATION LTD**  
Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand - 388610, Ph. 91 2698 242618  
Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmail.com Website: [www.gsecl.in](http://www.gsecl.in)

Sr. No.	Index
01	Tender notice
02	Terms and conditions regarding tender
03	Technical bid
04	Details of bidder
05	Annexure-I
06	Annexure-II
07	Undertaking
08	Annexure-1(Appendix 1) : Undertaking from Third Party Inspection Agency/Statutory Auditor or Practicing CA/CA Firm
09	Integrity pact
10	ANNEXURE-13-UNDERTAKING IN REGARD TO QUOTED PRICE
11	Price bid (separate) schedule - B

Name of Firm	
--------------	--



# GUJARAT STATE ELECTRICITY CORPORATION LTD

Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand - 388610, Ph. 91 2698 242618

Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmail.com Website: [www.gsecl.in](http://www.gsecl.in)

## TENDER NOTICE NO. DGBPS\_07\_121A\_S\_76061\_IMD RFQ-76061

Chief Engineer [Generation] DHUVARAN TPS invites tenders for the supply as mentioned below. **Interested** bidders shall have to submit **ON LINE** bid through <https://tender.nprocure.com> (The Tenders will only be considered, if both bid are submitted online i.e. Technical bid as well as Price bid) by the intending bidders on or before due date of submission as mentioned in the tender notice. **“Technical bid containing all the relevant documents of tender to be submitted through ONLINE process only on (n)Procure. No any documents will be accepted in offline mode or hard copy”.**

All bidders are requested to submit Technical bid & Price-bid on Line through <https://tender.nprocure.com> only and not to submit the Bid in Physical form - this is mandatory. If Bid is submitted in physical form, same will not be opened and only on Line submitted bid will be considered for evaluation.

Name of Work	Tender Fees in Rs. (Non-Refundable)	E.M.D in (Rs.)	Security Deposit	Delivery Period/Time Limit
SUPPLY OF FLOW METERS FOR CAPP-1, 2, 3 & COLONY AREA FOR GSECL, DGBPS.	1770.00 (1500+18 %GST)	33,168.00	05 % of Order Value before placement of order.	14 weeks from the date of LOI

(1)	Last date of Bid down loading up to <b>18.00 Hrs</b>	As per Tender Notice and n-procure site
(2)	Last date for receipt of tender (in online ) up to <b>18.00 Hrs</b>	As per Tender Notice and n-procure site
(3)	Date of Opening of Technical Bid (In presence of willing bidders) At 15:30 Hrs if possible	As per Tender Notice and n-procure site
(4)	Date of Opening of Price Bid At 15:30 Hrs (if possible) (In presence of Qualified bidders)	<b>Will be intimated to technically qualified parties only.</b>
(5)	Validity of Tender from the date of opening of Technical Bid	120 Days

01. Tender Fee and EMD payment details by RTGS/NEFT must be submitted online along with the tender. Technical bid & Price bid should be strictly submitted online only. Otherwise the offer will not be considered and no any further communication in the matter will be entertained. In case of Demand draft/Pay Order /Bank Guarantee, It should be submitted to this office within 5 days from Date of opening of Technical Bid by Registered Post A.D or Speed Post.

02. Further bidders are requested to submit all the relevant documents of tender duly (Notarized or self-attested) [Technical bid in PDF form (with 300 dpi or higher) and Price bid on n-procure only]. All above mentioned documents are requested to be uploaded in PDF form on n-procure portal only as no physical documents will be accepted. Price – bid (Schedule-B) should also requested to submit on-line only (On N-



## GUJARAT STATE ELECTRICITY CORPORATION LTD

Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand - 388610, Ph. 91 2698 242618

Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmail.com Website: [www.gsecl.in](http://www.gsecl.in)

procure portal) and no any financial bid information should be mention in Technical Bid. This is mandatory. Further if the quantity quoted differs in the any of the technical bid forms and in price bid forms, it is at the discretion of CE Committee / ED Committee – GSECL to consider the quoted quantity.

**03.** Any technical questions, information and clarifications that may be required pertaining to this tender enquiry should be referred to the **Chief Engineer (Gen.) Gujarat State Electricity Corporation Ltd., Gas Based Power Station, DHUVARAN – 388 610 (Dist. ANAND)**. GSECL reserve the rights to accept / reject any or all tenders without assigning any reasons thereof.

**04.** It shall be sole responsibility of bidder that the uploaded scanned documents (in PDF format) remain legible and should not be password protected.

**Signature of Contractor with Place /  
Date / Firm Seal / Stamp**

**For, Gujarat State Electricity Corporation Ltd.**

**Chief Engineer(Gen.)  
GSECL, DGBPS.**

**Note:** In case Bidders needs any clarification in the tender, they can contact the following e- mails and cell no.

Sr. No.	Name, Design.& Section	e-mail ID	Mobile No.	Remark
1	Shri B I Parmar, Ex. Engr	dtptech.gsecl@gebmail.com	8128692740	For tender related query
2	Shri.S.L.Sindha. Ex. Engr	dtpsimdccpp.gsecl@gebmail.com	9925209035	For technical query
3	Shri. R.G. Solanki- Dy CAO	<a href="mailto:dtpscoa.gsecl@gebmail.com">dtpscoa.gsecl@gebmail.com</a>	8980031248	For commercial queries. Tender fee/EMD/Bank details etc.



## TERMS AND CONDITIONS REGARDING TENDER

<b>01</b>	<b>TENDER FEE/EMD</b>
<b>A</b>	<p><b>Eligibility for Exemption: Clause No. 4.A of GoG Procurement Policy 2024</b></p> <p>Eligibility for Exemption in criteria for Tender Fee and Earnest Money Deposit (EMD) shall be read as below:  Following categories of sellers shall be exempted from furnishing Bid Security:</p> <ol style="list-style-type: none"> <li>a) Micro &amp; small-scale enterprises which participate directly in tendering process for the product which they are manufacturing/service which they are providing and have Udyam registration for items / service under procurement.</li> <li>b) Start-ups which participate directly in tendering process for the product which they are manufacturing / service which they are providing and recognized by DPIIT under the Start-up India Program and has obtained Udyam registration.</li> <li>c) Organization which has registration certificate for the manufacturing product of the tender, from Gujarat Khadi Gramodyog Board or Khadi and Village Industries Commission (KVIC) or Commissioner of Cottage Industries.</li> <li>d) Board/Corporations/PSUs of the Central/State Government for their own manufactured items.</li> <li>e) State Government recognized organizations like (i) organizations for blinds, dumb and deaf, disabled, mentally disabled persons; (ii), women's self-help group recognized by Gujarat Livelihood Promotion Company, which participate directly in tendering process for the product which they are manufacturing /service which /they are providing.</li> <li>f) In keeping with Gem Guidelines, OEM and service providers rendering services directly or by its own and having annual turnover of INR 500 crore or more.</li> <li>g) In keeping with GeM guidelines, sellers/service providers holding BIS licence for the primary product category whose credentials are validated through BIS database.</li> </ol>
<b>B</b>	Tender Fee (nonrefundable) will be acceptable through Demand draft/Pay Order /RTGS/NEFT/Bank Guarantee.. Bank Account details are given here under. Cheque are not accepted & Tenders submitted without tender fee will not be accepted If not exempted.
<b>02</b>	<b>EARNEST MONEY DEPOSIT</b>
<b>A</b>	Earnest Money Deposit (refundable) is acceptable through Demand draft/Pay Order /RTGS/NEFT/Bank Guarantee/e-BG.
<b>B</b>	Security Deposit will be collected from the successful tenderer at the rates mentioned above. This may be recovered by deduction through running bills of the contractors and /or by treating the Earnest Money Deposit (Bid Security) paid at the time of submission of the tender.
<b>C</b>	<p>As per GOVT OF GUJARAT Finance Department. GR.No.: FD/MSM/e-file/4/2025/2712/DMO Date:01/04/2026</p> <p>(A) Guarantees issued by following banks will be accepted as SD/EMD on permanent basis.</p> <p>1. All Nationalized Banks.</p> <p>(B) Guarantees issued by following Banks will be accepted as SD/EMD for period up to March 31, 2027, the validity cut-off date in GR is with respect to date of issue of Bank Guarantee irrespective of date of termination of Bank Guarantee.</p>



# GUJARAT STATE ELECTRICITY CORPORATION LTD

Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand - 388610, Ph. 91 2698 242618

Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmail.com Website: [www.gsecl.in](http://www.gsecl.in)

	1 Axis Bank 2 Bandhan Bank 3 CSB Bank 4 DCB Bank 5 Equitas Small Finance Bank 6 HDFC Bank 7 ICICI Bank 8 IDFC First Bank 9 Jammu and Kashmir Bank 10 Kamataka Bank 11 Kotak Mahindra Bank 12 South Indian Bank 13 Tamilnad Mercantile Bank 14 Yes Bank 15 Nutan Nagarik Sahakari BankLtd 16 Saraswat Co-Operative Bank Ltd 17 SVC Co-Operative Bank Ltd. 18 The Gujarat State Co-OperativeBank 19 The Surat People's Co-Op. Bank Ltd. 20 The Panchmahal District CooperativeBank 21The Rajkot Commercial CooperativeBank 22 Gujarat Gramin Bank	23 AU Small Finance Bank 24 City Union Bank 25 DBS Bank India Limited 26 Dhanlaxmi Bank 27 FEDERAL Bank 28 HSBC Bank 29 IDBI Bank 30 IndusInd Bank 31 Jana Small Finance Bank 32 Karur Vysya Bank 33 RBL Bank 34 Standard Chartered Bank 35 Ujjivan Small Finance Bank 36 Ahmedabad Mercantile Co-Op Bank 37 Rajkot Nagarik Sahakari Bank Ltd. 38 SBPP Co-Operative Bank Ltd 39 The Cosmos Co-op. Bank Ltd.Baroda 40 The Surat District Co-Op.Bank 41 The Baroda Central Co-operativeBank 42 The Kalupur Commercial Co-Op Bank 43 The Banaskantha Mercantile Cooperative Bank Ltd.
<b>03</b>	<b>SECURITY DEPOSIT</b>	
<b>A</b>	In tender process security deposit will be charged as per the table below. This will also be applicable as e-PBG	
	Category of the Unit	Security Deposit Purchase up to Rs. 5 Lakh      Purchase of more than Rs. 5 Lakh
	Enterprises or Organizations which are exempted from paying EMD as per GOG procurement policy	Exempted      3% of order value
	For other enterprises	5% of order value      5% of order value
<b>B</b>	Eligibility for Exemption: Clause No. 4.A of GoG Procurement Policy 2024 a) Micro & small-scale enterprises which participate directly in tendering process for the product which they are manufacturing / service which they are providing and have Udyam registration for items / service under procurement and having registration with CSPO or National Small Industries Corporation. b) Start-ups which participate directly in tendering process for the product which they are manufacturing / service which they are providing and re-recognized by DPIIT under the Start-up India Program and has obtained Udyam registration & CSPO / NSIC registration as MSE. c) Organization which has registration certificate for the manufacturing product of the tender, from Gujarat Khadi Gramodyog Board or Khadi and Village Industries Commission (K.V.I.C) or Commissioner of Cottage Industries. d) Board/Corporations/PSUs of the Central/State Government for their own manufactured items. e) State Government recognized organizations like (i) organizations for blinds, dumb and deaf, disabled, mentally disabled persons; (ii) women's self-help group recognized by Gujarat Livelihood Promotion Company; which participate directly in tendering process for the product which they are	



	<p>manufacturing / service which /they are providing</p> <p>Note: Security Deposit will be collected from the successful tenderer at the rates mentioned above. This may be recovered by deduction through running bills of the contractors and /or by treating the Earnest Money Deposit (Bid Security) paid at the time of submission of the tender.</p>
04	<p><b>Technical Bid:</b> The technical bid shall comprise of all the technical details of the stores / materials offered in accordance with the Corporation guaranteed technical particulars and conditions, etc. The Technical Bid shall be opened on Due Date as mentioned in tender Notice (If Possible), in the presence of those tenderers who wish to be present.</p> <p><b>If the Authorized Representative is likely to be present then he must submit the authorization letter of the representing company at the time of opening of Bids and this is compulsory. Only One authorized Representative shall be allowed.</b></p> <p>Please note that the required documents should be invariably submitted online with tender. Tender without documents are liable to be ignored.</p>
05	<p><b>Price Bid</b></p> <p>(a) <b>For E-Tender:</b> Bidders are requested to submit Price Bid (Schedule-B) on-line only and not to submit the price bid in physical form. This is mandatory. If price bid is submitted in physical form, same will not be opened and only on-line submitted price bid will be considered for evaluation. Further if the quantity quoted differs in the any of the technical bid forms and in price bid forms, it is discretion of Committee – GSECL to consider the quoted quantity.</p>
06	<p>The tender must be submitted online.</p> <p><b>Bidder has to upload receipt of tender Fee &amp; EMD online along with the tender. In case of E-Tender, It is mandatory to submit tender online only on or before due date and time. If tender submitted in Hard copy, it will not be considered for evaluation Corporation does not take any responsibility for postal delay on both ways and tender fee/EMD details cover received after due date and time will not be accepted by this office.</b></p>
07	<p>Tender fee &amp; EMD if not exempted than details should have to be submitted along with online technical bid, if not found offer may be rejected .</p>
08	<p>Gujarat State Electricity Corporation Ltd. reserves the right to accept/reject/Cancel any or all the offers/tenders, extend dates and / or re-advertise tender, and /or modify the Qty&amp;process at any stage of the process without assigning any reason thereof</p>
09	<p><b>Arbitration clause. combined supply and works orders / tenders</b></p> <p>(1) Amicable Settlement:-  Any dispute, difference, controversy or claim between the Parties arising out of or relating to this contract with reference to the construction, interpretation, breach, termination or validity thereof (hereinafter referred as "the Dispute") shall, upon the written request of either Party be referred to the authorized representatives of the Disputing Parties for resolution. The authorized representatives shall promptly meet and attempt to negotiate in good faith a resolution of the Dispute within thirty days of the service of the request.</p> <p>(2) Arbitration:-  If the Parties fail to amicably resolve the disputes or differences or contrary claims as indicated herewith in sub clause (1) of Clause, arising under or in connection with the present agreement, the same shall be referred to the Arbitration Centre (Domestic and International) High Court of Gujarat at Ahmedabad ("the Centre" for short), currently functioning in the High Court Complex, Sola, Ahmedabad for appointment of arbitrator and thereupon, the Centre shall appoint a sole arbitrator and conduct the arbitration proceedings in accordance with its rules. If the parties unanimously agree to appoint three arbitrators, then in that case, each party shall appoint one arbitrator from the panel of arbitrators of the Centre, and the Centre shall appoint the third arbitrator, who will act as the Presiding Arbitrator. Such arbitration shall be the sole and exclusive remedy between the parties for all disputes arising under or in connection with this agreement. The arbitration shall take place at the Arbitration Centre, Ahmedabad, High Court Complex, Sola, Ahmedabad, Gujarat, in accordance with the provisions of the Arbitration and</p>





# GUJARAT STATE ELECTRICITY CORPORATION LTD

Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand - 388610, Ph. 91 2698 242618

Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmail.com Website: [www.gsecl.in](http://www.gsecl.in)

	Conciliation Act, 1996 as amended from time to time, and the proceedings shall be conducted in English. The arbitration award shall be final and binding on the parties.
10	Any delay that may take place in supply or erection, testing and commissioning activities beyond contractual cutoff date / stipulated period in the order shall be subjected to penalty (not liquidated damages) at the rate of ½% on goods not delivered per week or part thereof subject to a maximum of 10% on delayed portion.
11	<p><b>Payment</b></p> <p>A. <b>For Supply:</b> “ 80% FOR Destination price from the date of receipt of materials against TRC within 30(thirty) days on verifying required documents as per A/T conditions, amount of GST and applicable cess will be kept under retention till submission of documentary proof of payment of GST or till reflection of payment of GST pertain to respective bill amount in GST return for concern order after due verification and balance 20% of FOR Destination price within 45 (Forty Five) days on receipt of Store Receipt (SR) Note from the consignee. Hence you are requested to furnish details of (1)Account Number(2)Type of Account(3)Bank Name(4)Branch Name and address(5)Contact No. of branch(6)IFSC No.”</p> <p>The payment will be made by crossed cheque on BOB DHUVARAN subject to advance stamped receipt received from you. Please send pre-receipted bills so as to effect prompt payment. Payment shall be made through RTGS/NEFT A/C payee cheque after receipt of advance stamp receipt. You are requested to provide the details in the format attached herewith for payment through RTGS/NEFT A/C payee cheque.</p> <p>B. <b>For Works:</b> if there is any work part in supply order, payment shall be made within 30 days from recording of bill.</p>
12	<p><b>Tenders duly filled must be accompanied by the following documents for tech. qualifying criteria.</b> Online tenders are invited from the reputed suppliers with sound engineering back ground, experience and financial capability, fulfilling qualifying requirement stated hereunder at <b>DHUVARAN GBPS, Gujarat.</b></p> <ol style="list-style-type: none"> <li>1. List of recent orders (not more than 5 years old) for similar items executed by the party indicating the names of the organizations, order no and date, performance certificate for their supplied items</li> <li>2. Satisfactory completion certificate of supply orders executed.</li> <li>3. Any additional details regarding technical specifications or any deviation from the specification given by the Corporation in schedule-B, should be indicated clearly and separately in technical bid Annexure-II.</li> <li>4. List of partners/ Directors with their permanent as well as present addresses phone no, Fax no and the name of immediate and authorized contact person.</li> <li>5. GST registration no., date and issuing authority.</li> <li>6. Bidder shall have to submit the PAN No for Income Tax &amp; GST No. with documentary proof.</li> </ol>
13	<p><b>PERFORMANCE GUARANTEE (Applicable):</b> Vendor will have to give Performance Guarantee equivalent to 05 % of total end cost who are not eligible for exemption stated in Clause no. 1(A) &amp; 03% of total end cost who are eligible for exemption as stated in Clause no. 3(A) for order value more than 05 Lakh and Nil for exempted firm for order value up to 05 Lakh of the Order value against any manufacturing defect for the equipment / material supplied by him before claiming payment.</p> <p>This Performance Guarantee can be paid in cash or demand draft on Bank of Baroda, Dhuvaran in favor of Gujarat State Electricity Corporation Ltd. or in the form of an acceptable Bank Guarantee from All Nationalized Banks</p>





# GUJARAT STATE ELECTRICITY CORPORATION LTD

Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand - 388610, Ph. 91 2698 242618

Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmail.com Website: [www.gsecl.in](http://www.gsecl.in)

	1 Axis Bank 2 Bandhan Bank 3 CSB Bank 4 DCB Bank 5 Equitas Small Finance Bank 6 HDFC Bank 7 ICICI Bank 8 IDFC First Bank 9 Jammu and Kashmir Bank 10 Kamataka Bank 11 Kotak Mahindra Bank 12 South Indian Bank 13 Tamilnad Mercantile Bank 14 Yes Bank 15 Nutan Nagarik Sahakari Bank Ltd 16 Saraswat Co-Operative Bank Ltd 17 SVC Co-Operative Bank Ltd. 18 The Gujarat State Co-Operative Bank 19 The Surat People's Co-Op. Bank Ltd. 20 The Panchmahal District Cooperative Bank 21 The Rajkot Commercial Cooperative Bank 22 Gujarat Gramin Bank	23 AU Small Finance Bank 24 City Union Bank 25 DBS Bank India Limited 26 Dhanlaxmi Bank 27 FEDERAL Bank 28 HSBC Bank 29 IDBI Bank 30 IndusInd Bank 31 Jana Small Finance Bank 32 Karur Vysya Bank 33 RBL Bank 34 Standard Chartered Bank 35 Ujjivan Small Finance Bank 36 Ahmedabad Mercantile Co-Op Bank 37 Rajkot Nagarik Sahakari Bank Ltd. 38 SBPP Co-Operative Bank Ltd 39 The Cosmos Co-op. Bank Ltd. Baroda 40 The Surat District Co-Op. Bank 41 The Baroda Central Co-operative Bank 42 The Kalupur Commercial Co-Op Bank 43 The Banaskantha Mercantile Cooperative Bank Ltd.
	<p>As per the Standard Bank Guarantee form prescribed by the GSECL.</p> <p>This Performance Guarantee shall be valid up to completion of Guarantee / Warranty period i.e. 18 months from the last supply made by the vender or 12 months from the date of commissioning whichever is earlier.</p>	
14	<b>GUARANTEE / WARARNTTEE:</b> If the goods, store & equipment are found defective due to bad design / materials or poor workmanship, the same should be replaced by you free of charge, if reported within 18 months of their receipt at site or 12 months from the date of commissioning of goods equipment whichever is earlier and submit certificate regarding this along with supply.	
15	<b>Party has to accept the overall L1 bidder will be considered for placement of order.</b>	
16	<b>Party has to extend validity of offer for further, if required.</b>	
17	<b>Freight will be paid on Execution/proof of documents i.e. on original bill (not more than 2%)</b>	
18	<p>(i) Bidder should read and verify the documents of Commercial Terms &amp; Condition of Tender &amp; Supply (i.e. Clause No.1 to 71) of GSECL, DGBPS and confirm that all the above documents are verified &amp; certify by you as below.</p> <p><b><i>"I/we read the above documents and agree for the Conditions of Tender &amp; Supply (i.e. Clause No.1 to 71) of GSECL, DGBPS and accordingly submitted my / our offer."</i></b></p> <p><u>It is mandatory to accept the Cl. 1 to 71. Bidder may accept the same on a single paper instead of all 37 pages. [Pg. 1 to 37]</u></p> <p>(ii) It is mandatory to submit <b>duly filled, stamped and signed copy</b> of all Annexure - 1 to 15 including Annexure 10 (GSECL-DGBPS), Integrity pact and certificate-A. [Pg. 42 to 57, 58 &amp; 67]</p> <p><b><u>All the above mentioned documents must be submitted failing which the offer will be ignored out rightly.</u></b></p>	
	<b>Note 1: In case of conflict, the terms &amp; conditions, specifications and requirement mentioned under Technical Bid will be considered.</b>	



**GUJARAT STATE ELECTRICITY CORPORATION LTD**  
Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand – 388610, Ph. 91 2698 242618  
Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmail.com Website: [www.gsecl.in](http://www.gsecl.in)

**Signature of Contractor with Place / Date / Firm Seal  
/ Stamp**

**For, Gujarat State Electricity  
Corporation Ltd.**

**Chief Engineer(Gen.)  
GSECL, DGBPS.**



**GUJARAT STATE ELECTRICITY CORPORATION LTD**  
Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand – 388610, Ph. 91 2698 242618  
Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmail.com Website: [www.gsecl.in](http://www.gsecl.in)

**Real Time Gross Settlement (RTGS)/National Electronic funds transfer(NEFT) Mandate Form Detail.**

1. Vendor/customer Name: **GUJARAT STATE ELECTRICITY CORPN.LTD**
2. Vendor/customer Code:
3. Vendor/customer Address: DHUVARAN TPS-388610.ANAND (GUJ)
4. Vendor/customer e-mail id: [dtpscoa.gsecl@gebmail.com](mailto:dtpscoa.gsecl@gebmail.com)
5. **Particulars of bank account**
  - a) Name of Bank: **BANK OF BARODA**
  - b) Name of branch: **DHUVARAN**
  - c) Branch code:
  - d) Address :Market building, GSECL Colony, Dhuvaran:388 610
  - e) Telephone number: 02698 242530.
  - f) Type of account (current/saving etc) Current.
  - g) Account number: **030402-00000-121.**
  - h) RTGS IFSC code of the bank branch: **BARB0DHUVAR.** “0” Zero
  - i) NEEFT IFSC code of the bank branch: **BARB0DHUVAR.** “0” Zero
  - j) 9 digit MICR code : **388012502**

**RTGS DETAILS FOR BIDDERS**

1. NAME OF THE BENEFICIARY :
2. ACCOUNT No. :
3. NAME OF THE BANK :
4. NAME & ADDRESS OF THE BANK BRANCH :
5. TYPE OF ACCOUNT :
6. BANK CODE :
7. RTGS DETAILS :
8. IFSC CODE :
9. ATTACHSCANCOPYOFCANCELEDCHQUE :

**Contact No:-**

(1) Shri. B I PARMAR EX.ENGR(TECH)  
Mobile No. 8128692740  
Mail : [dpstech.gsecl@gebmail.com](mailto:dpstech.gsecl@gebmail.com)



**ANNEXURE-10**

Vendor must fill up below details & should place at the top of the Techno commercial Bid.

1.	PRICE (FIRM ONLY)	
2.	FOR RATES OFFERED F.O.R.: Destination i.e. DHUVARAN TPS ONLY	
3.	GST IN PERCENTAGE FOR EACH ITEMS Please Quote your GST Registration No. Date, it shall be specify in the % of taxes for individual item)	
4.	PENALTY TRMS AGREE (Applicable) (Please Specify YES / NO)	
5.	SECURITY DEPOSIT TERMS AGREE (Please Specify YES / NO)	
6.	P.B.G. TERMS AGREED (Applicable) (P.B.G. – Performance Bank Guarantee) (Please Specify YES / NO)	
7.	GUARANTEE / WARARNTTEE TERMS AGREED	
8.	DELIVRY TERMS (14 weeks from the date of LOI)	
9.	PAYMENT TERMS AGREE (Please Specify YES / NO) -80% FOR Destination price from the date of receipt of materials against TRC within 30(thirty) days on verifying required documents as per A/T conditions, amount of GST and applicable cess will be kept under retention till submission of documentary proof of payment of GST or till reflection of payment of GST pertain to respective bill amount in GST return for concern order after due verification and balance 20% of FOR Destination price within 45 (Forty Five) days on receipt of Store Receipt (SR) Note from the consignee. (Advance payment condition will not be accepted)	
10.	Validity (120 days from the date of opening of Technical Bid)	
11.	ITEMS OFFERED	

Signature of the Tenderer

Date :

Place :



**TECHNICAL BID**  
(No Prices to be furnished in Tech. Bid)

**SUBJECT: SUPPLY OF FLOW METERS FOR CCPP-1, 2, 3 & COLONY AREA FOR GSECL, DGBPS.**

Sr. No.	Description of materials with details of Specifications	HSN CODE	GST Rate With Cess If Any IN %	Quantity Required	UOM
1	ELECTROMAGNETIC WATER FLOW METER 150 MM SIZE			3	Number
2	INTEGRAL TYPE ELECTRO MAGNETIC FLOW METER, SIZE - 100 MM			4	Set
3	ELECTROMAGNETIC WATER FLOW METER 50 MM SIZE			6	Number
4	COMPLETE ERECTION AND COMMISSIONING OF SUPPLIED SYSTEM.			1	Set

**TECHNICAL SPECIFICATIONS AND SCOPE OF SUPPLY**

**A. Material Specifications:**

For Item sr no. 1: Line size: 150 mm

For Item sr no. 2: Line size: 100 mm

For Item sr no. 3: Line size: 50 mm

**Common Technical specifications for Item sr no. 1, 2 & 3.**

1. General

\*Measuring Principle: Electromagnetic

\*Flange material: SS 316

\*Media: Water

\*Measuring Tube Material: SS316

\*Coil Housing: SS316 fully welded

\*Damping adjustment: Yes

\*Flow tube liner: Hard rubber / PTFE /Neoprene

\*Protection class: IP-67 or better

\*Grounding ring: SS 316

\*Instrument Power Supply: 230 VAC | -/+ 15%

\*Flange connection: ANSI B16.5 standard

\*JB on Flow Tube: SS316 Enclosure. Electronics sealed with water proof coating to make it waterproof. \*Cable entry: M20 x 1.5

\*Tag Plate: SS

2. Service / Process conditions

\*Min Operating temp: 7 Deg C

\*Max Operating temp: 50 Deg C

\*Max Operating Pressure: 5-10Bar

3. Process Pipe Details

As per attachment A.



## **GUJARAT STATE ELECTRICITY CORPORATION LTD**

**Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand – 388610, Ph. 91 2698 242618**

**Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmail.com Website: [www.gsecl.in](http://www.gsecl.in)**

### **4. Characteristic**

\*Accuracy: +/- 0.5 % of measured value.

\*Range ability: 100:1

\*Resolution: at least 2 digits after decimal

### **5. Probe:**

\*Sensor Electrode: SS316L/ SS316 / Hast alloy C or better.

\*Sensor Lining: Appropriate to process water with abrasive particles

\*Protection class: IP-67 or better

### **6. Transmitter / Electronic Unit**

\*Type: Microprocessor based

\*Totalizer: Yes

\*Zero Span Adjustments: Yes

\*Measurement Units Configurable at site: m3/hour; m3/day; LPH; LPS; LPM, etc; Volume: m3, tone, etc.

\*Output: 4-20 mA DC, 2 wire

\*Self-diagnostic feature: Yes

\*Display type: LCD with minimum 2 line display (One for instantaneous and one for total flow)

\*Accuracy: +/- 0.5 % (for flow from 10% to 100% of range)

\*Calibration range: As per attachment

\*Enclosure class: IP 67 or better

\*Enclosure Material: Suitable for saline environment and open field installation

\*Communication with transmitter for configuration protocol: HART preferable

### **7. Counter flange**

\*2 number of counter flange shall be provided per flow meter.

\*12 number of SS 316 nut bolts with washers on both sides shall be provided with each flow meter

\*2 number of gaskets shall be provided with each flow meter

\*Material of counter flange shall be as per MOC of process line.

### **8. Accessories**

\*Cable gland double compression type and other accessories to be provided for transmitter and sensors, all accessories should be SS316.

9. Preferred make: Krohne Marshall /BRIX/ ABB / ENDRESS & HAUSER / YOKOGAWA/SWAN/ EMERSON / GE / Honeywell / NAGMAN/ Siemens /Vega / Switzer/AXIS/ Xylem/ CGWA Approved OEM's.

### **10. Cabinet / Panel.**

\*Cabinet shall be totally enclosed, free standing type and shall be constructed with steel frame.

\*All components except primary measuring equipment (flow sensor/flow tube) will be mounted in panel.

\*Concealed hinges, two point door locking arrangement including key lock to prevent tampering.

\*Protection class shall be IP 55 or better.

\*Each and every component installed inside panel shall have item identification tag plate.

\*Provision for field wires and power cables through cable gland on bottom of panel

\*Removable Gland plate.

\*Base frame shall be mounted on Base Stand with legs





## **GUJARAT STATE ELECTRICITY CORPORATION LTD**

**Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand – 388610, Ph. 91 2698 242618**

**Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmail.com Website: [www.gsecl.in](http://www.gsecl.in)**

- \*Height of top of panel from finished floor shall be 1500 mm.
- \*Panel paint color Preference: Siemens Grey RAL 7035.
- \*All cables from field shall be terminated in TB before connecting it to any module inside panel
- \*All wires shall be provided with Lug of suitable size.
- \*Canopy shall be provided on panel top.
- \*Cable dressing Ducts shall be provided for panel cable
- \*Panel shall be suitably sized to manage the heat dissipation of internal components.
- \*Cable gland shall be of proper size. MOC of Cable gland shall be SS316.
- \*Panel shall include all components like, MCB, RCCB, Power TB, Signal TB, Power strips, Power sockets, sealing gaskets etc.
- \*DC wiring should be separate from AC wiring.
- \*All components shall be mounted / installed by agency inside the panel.

**Item sr no. 4:** Complete installation & commissioning of supplied flow meters & associated items with all necessary arrangements by bidder. This also includes removal of installed old flow meters, cutting, welding as well as civil related work.

### **Terms and Conditions:**

1. Guarantee/Warranty: You have to submit guarantee certificate for a period of 12 months from the date of Commissioning or 18 months from the date of dispatch of Materials whichever is earlier against poor Workmanship/ faulty design & any manufacturing defects.
2. Test certificates: Party shall furnish necessary test certificates for flow meters. All units must be calibrated on an NABL-approved rig. If the manufacturer lacks this facility, calibration must be performed at the Fluid Control Research Institute (FCRI). GSECL reserves the right to witness the calibration of all Flow transmitters.
3. Erection and Commissioning: All necessary materials those are required for commissioning of these flow meters shall be in your scope. You have to completely undertake / Commissioning of the flow meter in all respects and put in service.
4. Party shall have to confirm the support for upcoming 15 years along with technical bid.
5. Party has to submit the Authorization letter from OEM if the party is not OEM.
6. All other terms & conditions shall be as per GSECL standard terms & conditions.
7. Overall L1 Bid will be considered from total of all items.



**Attachment- A**

<b>SR NO</b>	<b>LINE SIZE</b>	<b>TAG NAME</b>	<b>LOCATION</b>	<b>FLOW METER TYPE</b>
1	150	CCPP-1&2 SBW	At main gate CCPP I & II	Electro Magnetic
2	50	STP - reuse	For STP discharge line	Electro Magnetic
3	150	CS-1	Near Overhead tank	Electro Magnetic
4	150	CS-2	Near Overhead tank	Electro Magnetic
5	150	CS-3	Near Overhead tank	Electro Magnetic
6	50	CS-4	For school, hospital, mahila mandal and garden (24 hrs flow)	Electro Magnetic
7	50	CS-5	For training centre and administrative office	Electro Magnetic
8	150	CS-6	Behind Civil	Electro Magnetic
9	150	CS-7	Near ADM Office	Electro Magnetic
10	150	ETP-3	At CCPP-3 ETP	Electro Magnetic
11	50	Vill-1	To smasan bhumi (To village for CSR) 24 hrs flow	Electro Magnetic
12	50	Vill-2	At colony main gate	Electro Magnetic
13	50	Vill-3	Behind Primary school	Electro Magnetic



**SCHEDULE - A (Terms & Conditions)**

1. Bidder shall have to undertake any modification, alteration work required during installation & commissioning of new flow meters including civil related work, welding, cutting. For any queries/clarifications, bidder may visit site.
2. GSECL will provide single point power supply (230 V AC) per flow meter for commissioning as well as operation of new flow meters.
3. You will also be responsible for any damages caused to the GSECL property by your Personnel during the execution of above work. In such cases, you will arrange to repair / rectify or will pay such amount to GSECL as may be decided by the competent authority of GSECL.
4. Bidder shall have to arrange sufficient experienced Engineers / Supervisors / Technicians for carrying out the work in stipulated time with proper co-ordination and as per instruction of Engineer-in-charge.
5. Bidder shall have to comply with factory act, Labour laws and safety laws in force time to time.
6. Bidder shall have to follow the safe practice against hazardous and unsafe working conditions and shall comply with the safety rules to avoid any accidents to any person in force from time to time of GSECL - DGBPS. For any accident, injury fatal or non-fatal to any worker/person during work execution for the compensation Bidder will be held fully responsible in all ways.
7. For any ambiguity and conflict, the decision of the Chief Engineer, GSECL – Dhuvaran GBPS shall be final and binding to you.
8. For successful erection & commissioning of the project, all spares, cables, all necessary tools, connectors, Tubing and Fittings should be in Bidder scope only.



**GENERAL RULES AND DIRECTIONS FOR THE GUIDANCE OF CONTRACTOR  
& LABOUR LAWS**

Notwithstanding anything contained to the contrary in the specifications or tenders in subsequent exchange of correspondence, the conditions of contract shall be binding on the Contractor and any change or variation expressed or implied, however made in the said conditions, shall not be valid or operative unless expressly sanctioned by the Corporation. The Contractor shall be deemed to have fully informed himself and to have special knowledge of the provisions of the conditions of the Contract herein contained.

1. All works proposed to be executed by Contract shall be notified in one of the English and one of the vernacular local daily Newspapers, stating the work to be carried out as well as the date of submitting and opening tenders and time allotted for carrying out the work, also the amount of earnest money to be deposited with the tender and the security deposit to be deposited by the successful Tenderer and the percentage, if any, to be deducted from the bills.
2. Copies of the specifications, designs, drawing, estimated rates, scheduled rates and any other documents required in connection with the work which will be signed by the Engineer-in-charge for the purpose of the identification shall be open for inspection by the Contractors at the Office of the Engineer-in-charge during office hours.
3. Whether the works are proposed to the specifications recommended by the Contractor and approved by the Competent Authority on behalf of the Gujarat State Electricity Corporation Ltd., such specifications with designs and drawings shall form part of the accepted tender.
4. The tenders and receipts for payments made on account of any work, when executed by a firm should be signed by all the partners except where the contractors are described in their tender as a firm, in which case the receipt shall be signed in the name of firm including the partners or some other concern having authority to do so.
5. Tender which propose any alteration in the work specified in the form in invitation to tender or in the time allowed for carrying out the works or which contain any other conditions of any sort, will be liable to rejection.
6. No single tender shall include more than one work, but contractors who wish to tender, for two or more works, shall submit a separate tender for each work. Tender shall have the name and the number of the works of which they pertain, be super scribed on the envelope.
7. The Engineer-in-charge or his duly authorized Assistant will open tenders in the presence of any intending Contractors who may be present at the time and will enter the amount of the several tenders in a comparative statement in a suitable form. In the event of a tender being accepted, the contractor shall thereupon, for the purpose of identification, sign copies of the specifications and other documents. In the event of tender being rejected, the Officer (Executive Engineer) shall authorize the Paying Officer concerned to refund the amount of the Earnest Money deposited, to the Contractor making the tender on his giving a receipt for the return of the money.
8. The Officer competent to dispose of the tenders shall have the right of rejecting all or any of the tenders, without assigning any reasons thereof.
9. No receipt for any payment alleged to have been made by a Contractor in regard to any matter relating to tender of the contract shall be valid and binding on the Corporation unless it is signed by the Engineer-in-Charge.
10. The Memorandum of work to be tendered for and the Schedule of Materials to be supplied by Gujarat State Electricity Corporation Ltd. and their rates shall be filled in and completed by the Office of the Executive Engineer before the tender form is issued, if a form issued, to an intending tenderer has not been so filled in and incomplete: he shall request the said Office to have this done, before he completes and delivers his tender.
11. All works shall be measured, met by standard measure and according to rules and custom and



- usual in the use in Gujarat State Electricity Corporation Ltd., and no proposal to adopt alternative method will be accepted, the Executive Engineer's decision as to what is "the usual method in use in the Gujarat State Electricity Corporation Ltd." shall be final.
12. Every contractor shall, except the registered contractor on the approved list of the Corporation, produce along with his tender a solvency certificate from the contractor of the District within which he resides, a Banker's certificate of his financial stability, if he fails to produce such a certificate, his tender will not be considered.
  13. All corrections and additions on pasted slips should be initiated.
  14. Tenders shall be deemed to have full knowledge of all relevant documents, site conditions etc., whether inspected or not by him.
  15. Submissions of tender by a contractor implies that he has read the instructions and conditions of Contract herein contained and has made himself aware of the scopes and specifications of the work to be done and condition and rates which stores materials etc. will be issued to him and local conditions and other factors bearing on the execution of the work.
  16. Under no circumstances shall any Contractor be entitled to claim enhanced rates for any item of contract without prior sanction of the competent authority.
  17. These Rules and Directions shall form part of the Contract.
  18. **The Labour Codes recently implemented by the Central Government of India shall become applicable to this contract as and when the same are notified and brought into force by the Government of Gujarat, along with the Rules framed thereunder. The Contractor shall ensure full compliance with all such applicable provisions, including any amendments issued from time to time, and shall be solely responsible for adherence to statutory requirements under the said Labour Codes and Rules. Any financial or legal liability arising due to non-compliance shall be borne exclusively by the Contractor, and GSECL shall stand fully indemnified in this regard.**

### **TERMS AND CONDITIONS REGARDING LABOUR LAWS**

During the entire period of the contract, the Contractor and his Sub-Contractors shall at all times comply with all applicable labour laws, rules, regulations, notifications, and bye-laws issued by the Central Government, State Government, or Local Authorities. This includes all existing laws as well as any amendments or new notifications that may come into force during the contract period.

The Contractor and his Sub-Contractors shall, at all times abide by the following Acts/Statutes related to Human Resources:

1. Factories Act, 1948;
2. Contract Labour (Regulation & Abolition) Act, 1970;
3. EPF & MP Act, 1952;
4. Building & Other Construction Workers (Regulation of Employment & Conditions of Service) Act, 1996;
5. ESI Act, 1948;
6. Minimum Wages Act, 1948;
7. Payment of Wages Act, 1936;
8. Payment of Bonus Act, 1965;
9. Payment of Gratuity Act, 1972;
10. Workmen's Compensation Act, 1923;
11. ID Act, 1947;
12. Maternity Benefit Act, 1961;
13. Inter-State Migrant Workmen (Regulation of Employment & Conditions of Service)



Act, 1979;

14. The Building and Other Construction Workers' Welfare Cess Act, 1996

17. The Carriage by Road Act, 2007.

The above list is only indicative and not exhaustive. The Contractor shall remain fully responsible for ensuring compliance with all other applicable labour and welfare legislations, rules, and regulations in force during the contract.

The following are some of the major responsibilities of the contractor, in addition to other obligations prescribed under various labour laws, rules, and regulations issued by statutory authorities such as the State Government or Government of India from time to time, which the contractor shall strictly comply with during the execution of the contract.

### **1) The Factories Act, 1948**

The contractor should not deploy worker below the age of 18 years and above 60 years for the awarded work.

Earn Leave shall be paid to their bonafide contract workers as per the provisions of the Factories Act, 1948.

Payment of Earned Leave should be made monthly together with wages for better compliance of law. The contractor shall maintain Earn Leave Register in Form No. 19 as per the provisions of the said Act and submit the same on demand.

All the written registers, Performa etc. shall be maintained up to date and kept ready for inspection at any time or submitted on-time to the concerned authorities as per applicability of the Acts by contractor.

### **2) The Contract Labour (Regulation and Abolition) Act, 1970**

The Contractor / Agency shall have to obtain the Labour License under Contract Labour (Regulation & Abolition) Act from the appropriate authorities before commencement of work. The contractor shall maintain a valid labour license under the Contract Labour (Regulation and Abolition) Act for employing necessary man power to be required by contractor.

The contractor should not be allowed to engage fifty (50) or more contract labourers without initiating to obtain the labour license under the Contract Labour Act. (The said number i.e., fifty (50) or more includes Supervisor and other staff).

### **3) Minimum Wages Act, 1948**

Contractor shall have to make the payment of wages to the Contract Labours engaged by





them, on or before 7th of every month through nearest Nationalized Bank compulsory, preferably situated in the premises of TPS area in case of all works contract. The Contractor shall supply copy of Bank Statement duly stamped by the Concerned Bank as well as debited entry of amount displayed in the contractors' own bank account as token of proof towards payment of Wages through CLIM/prevaling system at relevant time. Apart from Payment of wages through Bank, Contractors shall have to make all other payments like Advances, Bonus, Leave Encashment etc. to their labours through bank only and cash payment/entry will not be allowed.

Wages rates for contract laborers are applicable as per the terms and conditions of the license. The contractor shall have to pay wages to workers as notified by the Government of Gujarat from time to time.

Any default to pay the minimum wages to the engaged workers and deprived of their right to minimum wages payment on or before 7th of each month shall be dealt as per the provision of labour laws. Recurrence of the same may lead to cancellation of awarded contract.

#### **4) The Provident Fund and Miscellaneous Provisions Act, 1952**

The contractor must possess separate P.F. code on the name of the Firm / Agency / Company itself for the subject work.

It should be ensured that all the contract labours engaged by contractor are covered under the provident fund scheme and employee's pension scheme and their contribution must be remitted regularly to the concerned RPFC. The photocopies of challan along with ECR in this regards should be submitted regularly to the User Department to enable their onward billing clearance.

The contractor shall submit along with his bill (month wise) statement regarding deductions against employees' provident fund and family pension scheme in respect of each concerned employee. Provident fund and family pension scheme at the rate of 12 % of wages (or at the rates made applicable by the Government time to time). The contractor's contribution and his workers contribution towards provident fund and family pension scheme shall deposited by the contractor with concerned PF Authorities.

#### **5) Workmen's Compensation & Employer's Liability Insurance.**

The contractors shall have to obtain Employee Compensation Policy under the Employees Compensation Act before starting the work. Employee Compensation Insurance shall be obtained for all the workers engaged for the execution of awarded contract. If any of the work is sub-letted, the contractor shall



ensure that the sub-contractor take and provide workmen's compensation and Employer's liability insurance for the labours engaged. Contractor is liable to pay compensation in case of accidental injury arising out of and in the course of employment as per the said Act and shall bear medical expenses due to on duty accident.

**6) The Payment of Gratuity Act, 1972**

For better compliance, contractor shall pay amount of gratuity on a monthly basis along with the payment of wages, calculated on a pro-rata basis per month, which is equivalent to 15 days' wages for each completed year of service for every worker. (\* **applicable to ARC / BRC works contract only**)

**7) The Payment of Bonus Act, 1965**

Every worker shall be entitled to be paid by the contractor in an accounting year, bonus, in accordance with the provisions of this Act, For better compliance, the contractor should pay bonus amount on a monthly basis along with wages calculated on a pro-rata basis per month. Contractor has to submit the paid bonus details of its worker in Form No. C as per the provisions of the said Act as and when required by the Govt. Authority as well as by GSECL.

**8) The Maternity Benefit Act, 1961**

Contractor shall ensure that entitled female worker should provide Maternity Leave and other benefits as per the provision of the said Act.

**9) The Building and other Construction Workers' Act, 1996**

For any construction work, fall under the definition of Section 2(1)(d), happening outside / inside the Factory premises the said act will be applicable and the contractor or its sub-contractor shall be liable to comply with the provisions framed there under.

**10)** The contractor shall give preference to existing or local contract workers for engagement in the awarded contract and shall issue appointment orders to each and every workers individually at the time of their engagement during the period of contract and terminate the same at the end of the each contract.

**Follow the mentioned procedure at each milestone for the execution of works contract.**

**11) On Commencement of Contractual Work**

1. Before starting the work, the contractor may contact Labour Welfare Officer / Industrial Relations Officer for all formalities related to labour law compliance



**GUJARAT STATE ELECTRICITY CORPORATION LTD**

Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand – 388610, Ph. 91 2698 242618

Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmail.com Website: [www.gsecl.in](http://www.gsecl.in)

before commencement of the contract and onward Labour Law compliance thereof, so that later no dispute will arise in respect of compliance of labour laws.

2. It is the responsibility of the contractor to ensure that contractor's employees maintain strict discipline as regards security, methods of safe working etc, and not to cause any hindrance to smooth running of power station or in execution of duties by GSECL staff. Any lapse in this regard will be viewed seriously and if lapse found, contract is liable to be terminated. If any of contractor's staff is found unsuitable or not behaving properly, the contractor shall have to remove such worker from the work-site on demand by EIC. To maintain harmonious industrial relations amongst contract labours is solely the responsibility of contractor. Any breach of the same will be viewed seriously.

3. A digital system developed at the request of the agencies working at the premises of GSECL, is to facilitate them for easy, efficient, effective management of data, gate passes, attendances, medical records, Police Verification documents etc related to their employees / workers deployed for various works and services against work order of GSECL.

4. On receipt of LOA and before commencement of work, authorized representatives of the agency shall login in the CLIMS online portal / prevailing system at relevant time and apply for registration of their employees / workers uploading all information with required documents in digital form. Upon completion of due verifications, clearance by EIC and HR departments, contracting agency will obtain gate passes. GSECL will only consider documents like wage sheet duly accepted and signed by individual workers, as per the engagement/deployment duration/hours of individual worker duly certified by the agency, being the employer, for the purpose of payment of bills and HR clearances.

Agency shall be solely responsible for maintaining accurate and up-to-date data of their workers in the portal/ prevailing system at relevant time. All statutory compliances under prevailing laws shall remain the responsibility of the contracting agency. The agency shall indemnify GSECL against any liabilities arising from non-compliance of legal provisions or inaccuracies in the data maintained by them in the digital portal of CLIMS/prevailing system at relevant time.

5. The Contractor who intends to engage labours more than the specified limit under law, then necessary - Form No. V under the Contract Labour (R& A) Act, 1970 or Form No. VI under the Interstate Migrant worker (employment regulation) Act



## **GUJARAT STATE ELECTRICITY CORPORATION LTD**

Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand - 388610, Ph. 91 2698 242618

Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmail.com Website: [www.gsecl.in](http://www.gsecl.in)

1979 as applicable is to be obtained for the purpose of obtaining Labour License from the Licensing Authority.

6. It shall be the duty of the Contractor or his Supervisor to ensure Bio-Metric punching and reporting at the location of work.

7. The contractor shall employ adequate number of experienced staff at site for daily supervision and for maintaining of various registers and records required under the Labour laws and contracts. No payment for such supervision shall be admissible.

8. The gate passes obtained for any specific work order will be valid for that specific work order only and contractor should not divert the man power for any other work order. If any work or part thereof is desired/required to sublet, the contractor shall obtain the necessary permission of EIC in black and white well in advance which is mandatory for considering the statutory documents of agency other than the agency who awarded work order.

### **12) During Contractual Work under the progress:**

1. All Contractors shall have to make the payment of wages to the Contract Labours engaged by them, on or before 7th of every month through Nearest Nationalized Bank compulsory, preferably situated in the premises of power station area. The Contractor shall supply copy of Bank Statement duly stamped by the Concerned Bank as a token of proof towards payment of Wages through CLIMS / prevailing system at relevant time.

2. All Contractors has to comply & maintain statutory documents / registers under the provision of labour laws & E P F Act.

3. In case the contractor having more than one contract in the same TPS, the contractor shall have to obtain work order wise separate Gate Passes and submit the same with the documents of statutory compliance that too work order wise every month to the User Department to enable their onward billing clearance.

### **(13) CONTRACTOR TO INDEMNIFY THE GSECL REGARDING LABOUR LAWS**

The contractor shall indemnify and keep indemnified the GSECL, and every member, officer and employees of the GSECL, also Engineer-in-charge and his staff against all actions, proceedings, claims, demands, costs and expenses whatsoever arising out of or in connection with the matter referred in above clauses and elsewhere and against all actions, claims demands, cost and expenses which may be made against the GSECL by any workman/ employees



## **GUJARAT STATE ELECTRICITY CORPORATION LTD**

Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand – 388610, Ph. 91 2698 242618

Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmail.com Website: [www.gsecl.in](http://www.gsecl.in)

of contractor or any sub-contractor and or from any liability any wise to any workman/employees of the contractor or sub-contractor under any laws, rules or regulation having in force of law including but not limited to claims against the owner under employee compensation Act, 1923. The Employee's Provident Fund Act.1952, and/or the contract labour (Abolition and Regulation) Act, 1970.

The GSECL shall not be liable for or in respect of or in consequence of any accident or injury to any workmen or other person in the employment of the contractor or his sub-contractor, and the contractor shall indemnify and keep indemnified the GSECL against all such damage and compensation and against all claims, demands proceedings costs, charges and expenses whatsoever in respect of or in relation thereto.

The contractor shall at his own expense / risk and cost to comply with all the labour laws as above-mentioned and keep the G.S.E.C.L. indemnified in respect thereof.

GSECL : shall be entitled / empowered to deduct directly from the bills, the amount to be paid to engaged bonafide contract workers or the contract workers engaged by Sub-contractor; any sum or sums payable by main contractor / sub-contractor and which sum/sums the Corporation is required to pay in capacity of Principal Employer on account of the default of contractor in respect of all liabilities incurred out of non-compliance regarding any provisions of Labour Laws and same amount shall be recovered from the pending dues of the contractor with 15% administrative charges.

Any other rules and regulation, conditions, circulars etc., that are in force at present and that may be framed by the GSECL from time to time in connection with contracts will be binding and acceptable to contractor.

The above are some of the major liabilities of the contractor in addition to other liabilities prescribed under the various labour laws in force from time to time from Statutory Authorities like State Government / Government of India, which the contractor shall have to comply with.

The contractor shall provide the name of authorized representative, as provided to other statutory Government authorities and will be notified to Engineer In-Charge time to time.

### **14) Submission of Statutory documents to ensure the compliances:**

The contractor shall upload statutory documents, work order-wise, under Labour Laws and



EPF in CLIMS / prevailing system at relevant time.

Required documents shall be uploaded by the contractor in existing portal /prevailing system at relevant time invariably each month to Engineer In-Charge for onward process and smooth clearance by HR Department.

**List of documents required for gate passes of contract workers through clims /prevailing system**

Sr. No.	Description of documents attached
1	Copy of Work Order
2	Copy of P. F. Code No.
3	Insurance Policy as per subject of work order under the Workmen Compensation Act,1923
4	Contract agreements/ subletting work contract documents with approval copy
5	Copy of Id proof of Aadhar card or Election voting card or driving license or Passport only
6	Copy of Police Verification in respect of each contract workers

**15.** The contractor whose work order value is above Rs. 5 lacs shall have to submit “Declaration cum Indemnity Bond” on Rs. 300/- Non-Judicial stamp paper in prescribed Performa (Annexure- “B”) with Agreement and Indemnity Bond before the commencement of the contract.





**GUJARAT STATE ELECTRICITY CORPORATION LTD**  
Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand - 388610, Ph. 91 2698 242618  
Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmil.com Website: [www.gsecl.in](http://www.gsecl.in)  
CIN: U40100GJ1993SGC019988

**Annexure- "B"**

**DECLARATION CUM INDEMNITY BOND**

***(On Rs.300/- Non Judicial Stamp Paper duly notarised)***

**THIS DECLARATION CUM INDEMNITY BOND** made at -----  
**(mention location)** by **M/S. -----** having its Reg. office at-----  
----- (hereinafter referred to as **"Contractor"**)  
which expression shall unless it be repugnant to the context or meaning thereof,  
be deemed to mean and include their respective assigns, successors, executors,  
subcontractors and / or administrators) of the **ONE PART** in favour of  
**M/S Gujarat State Electricity Corporation Limited** having its power  
Station at .....**Thermal Power Station** (hereinafter referred to as the  
**"Company"** ), which expression shall unless it be repugnant to the context or  
meaning thereof be deemed to mean and include its assigns, successors) of  
the **OTHER PART**.

**WHEREAS** the COMPANY has entered into a contract with the Contractor for the  
work of"-----"  
----- dated-----"hereinafter called the "Contract");

**AND WHEREAS** it is one of the essential conditions of the Contract that the  
Contractor shall comply with all the provisions of the Labour & Industrial  
Laws, as may be applicable from time to time for the discharge and  
completion of the works and completion of the Works and Services covered  
under said Contract Labour (R & A) Act 1970, Child Labour (Prohibition and  
Regulation) Act 1986, The Employees Provident Funds & Miscellaneous  
Provisions Act, 1952, Employees State Insurance Act 1948, Minimum Wages  
Act, 1948, Payment of Bonus Act, 1965, Payment of Wages Act, 1936, Employees  
Compensation Act, 1923, Factories Act, 1948 and other Labour Laws, Rules,  
Notifications and Codes which are at present applicable to the contractor and  
which may be applicable during the tenure of the contract (hereinafter referred as the  
'Laws').

**AND WHEREAS** the Contractor has agreed to execute this Declaration cum  
Indemnity Bond to this effect and has agreed to indemnify and Company, it's  
Directors, Officers and employees and representatives indemnified and hold



**GUJARAT STATE ELECTRICITY CORPORATION LTD**

Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand - 388610, Ph. 91 2698 242618

Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmil.com Website: [www.gsecl.in](http://www.gsecl.in)

CIN: U40100GJ1993SGC019988

harmless against all third party claims, charges, penalties, fines, expenses, losses, damages costs, suits or any other levy against the Company and/or the management due to the failure of the Contractor to observe or follow all applicable laws.

**NOW THIS DEED WITNESSETH AS UNDER**

1. The Contractor hereby declares that all acts, deeds, actions, activities, conduct and lapse, delays, misdeeds, faults, breaches, inactions etc done by his assigns, successors, executors, subcontractor and / or administrators shall be construed to be have been done by the contractor and he alone shall be liable for such acts, inactions etc.
2. In consideration of the Company awarding the Contract to the Contractor subject to the condition of execution of this Declaration cum Indemnity bond, the Contractor declares and represents to the Company that the Contractor has obtained all Statutory registrations, Certificates, licenses and approvals required under the Laws enabling the Contractor to execute the Contract in a legal and lawful manner.
3. That in the event of any liability arising out of non-compliance of any 'Laws' of the land by the Contractor in connection with the Performance of the contract, the Contractor shall bear all the resultant liability (ies) whatsoever, if any and that the company, its Directors, Officers and employees, representatives, shall not be liable for any such liability(ies). The Contractor undertakes to indemnify and keep the Company and its Directors, Officers and employees, representatives indemnifies, defend and hold harmless, against all losses, costs, damages, claims, penalties, interest, expenses, demands, fines, legal liability, causes of action, injury to persons, suits etc., which may be suffered, incurred, undergone and / sustained by the Company including the Costs and expenses that may be incurred in defending any such liability(ies) claim(S), Proceeding (S) etc. that maybe made or taken or taken or arise on the same by any Person, body, authority, government, judicial /quasi - judicial authority due to the failure or non-compliance of any such laws and rules there under (including any amendments in acts, laws, statutes & rules there under) of whatsoever kind and nature arising out of or in any way connected with, whether or not such acts or omissions are actual or alleged, active or passive with regard to the discharge of the said



**GUJARAT STATE ELECTRICITY CORPORATION LTD**

Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand - 388610, Ph. 91 2698 242618

Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmail.com Website: [www.gsecl.in](http://www.gsecl.in)

CIN: U40100GJ1993SGC019988

Contract.

4. The Contractor further declares that in case of any suit / claim / right / damages / compensation / fine / levy / charges / expenses / losses / penalties / costs raised by the third party, including contract labours engaged by the contractor, he shall join such proceedings in such Suit/Court/Tribunal/Authority and effectively defend the same.

5. The Contractor hereby agree and undertakes to make good any loss, damage, claims, suits, demands, decrees, expenses that the Company may suffer to the fullest satisfaction of the Company and if the Contractor fails to make good the same then the Company shall have the right to recover the same from and or any other loss sustained, without any restriction or limitation, together with any other incidental expenses, costs, and all incidental logistic expenses etc that may be suffered by the Company from the Contractor and the Contractor hereby further confirms and declares that this Declaration cum Indemnity Bond is irrevocable and shall be final and binding on him, his heirs, executors, administrators, legal representatives, successors, subcontractors and assigns, wherever the context applies. any claims, demands, shall be adjusted against any amount due and payable to the Contractor and the Company shall have the right to withhold any amounts due and payable to the Contractor, till the settlement of such claims, disputes to the Contractor towards discharge of such claims, obligations etc.

6. This Declaration cum indemnity bond shall be in accordance with the laws of India and any dispute between the parties with regard to this Declaration cum Indemnity Bond shall be resolved through the dispute resolution process mentioned in the General Conditions of the Contract (GCC).

IN WITNESS WHEREOF, the said Contractor has hereunto set their hand the day and year first hereinabove written.

**SIGNED SEALED AND DELIVERED** By the within named "CONTRACTOR"

(Authorised Signatory)

Rubber Stamp of Firm/Company



**GUJARAT STATE ELECTRICITY CORPORATION LTD**

Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand - 388610, Ph. 91 2698 242618

Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmail.com Website: [www.gsecl.in](http://www.gsecl.in)

CIN: U40100GJ1993SGC019988

Full Name:

Designation:

Date:

**In presence of Witness**

**Name & Address of Witness Signature**

1. Full Name :

Residential Address:

Contact No. :

2. Full Name :

Residential Address:

Contact No. :

Contractor's Sign. With Seal.

**Chief Engineer (Gen)**  
**GSECL, DGBPS**

## **“GENERAL SAFETY RULES / NORMS” TO BE OBSERVED BY THE CONTRACTOR**

All the contractors working in Gujarat State Electricity Corporation Limited Factory like Coal/Lignite/Gas/Hydro/Pumping Station shall have to strictly observe the following Safety Rules. Concern principle contractors are responsible for informing & observance of these rules by their supervisors/contract workers as well as the owner/supervisors/ workers of sub-Contractors engaged, if any, by them for the work contract awarded to them. Prior to commencement of the work, Contractor shall have to submit a written assurance on their letterhead to the concerned Sectional Head / Engineer-in-charge that they have thoroughly gone through these Rules, have educated their employees / workers of their sub contractor and will strictly observe the said Rules while execution of work under work contract awarded to them. They will have to indemnify the company for any loss or damage / accident / injury to the company's property / employee or employee of their own in default of non - observing these rules.

1. Contractor should issue photo gate pass for their workers from GSECL Factory Manager as per Gujarat Factories rules, 1963 & details shall be filled up in GSECL gate pass format as per Aadhar card /Election card id proof & to follow the gate pass issue procedure through concern department EE & SE, Security Officer, LWO/IRO/DGM, Factory Medical Officer, Safety Officer/Dy. Safety Officer & Factory Manager.
2. In case of emergency, temporary photo gate pass shall be issued by Security Officer only for three days with prior permission of Factory Manager only. More than three days, Permanent photo gate pass procedure shall be completed by contract agency for their contract workers.
3. Certificate of Fitness of employment in hazardous process & operations in form no.33 of Gujarat Factories rules, 1963 shall be issued by GSECL Factory Medical Officer for all contractor workers before commencement of work & examination responsibility shall be taken by contractor as well as concerned Head of Department .Pre-employment & Periodical medical examination of contractor workers shall be carried out in form no.32 from GSECL Factory Medical Officer after every six (06) months of contractor with their contractor workers. Contractor shall be fulfilled all health requirements before commencement of work. After completion of medical examination in form no.32/33, GSECL Factory Medical Officer shall be signed in contract worker gate pass procedure format.
4. Contract worker gate pass will issue after completion of safety induction 3D animation movie & Training record is to be maintained in IMS/OHSAS training format by TK Office/LWO.
5. As per Gate pass format of GSECL, Safety Officer/Dy. Safety Officer shall be checked the issue PPE to contract workers as per nature of job, Form no.10 of lifting tools and tackles, Driving license, Electrical contractor license, Electrical trade qualifications, Safety induction training, SOP, supervisor qualifications etc. After fulfillment of all Safety compliances, Safety Officer/Dy. Safety Officer shall be signed in Contract worker Gate pass procedure format.
6. Work Contract shall be completed by principle contractor/agency/person who is awarded the work order. Subletting of contract shall be allowed only if prior approval of Power station chief before execution of work. Contractor/agency shall be submitted the entire subletting contract documents with gate pass application through concern department EE & SE, LWO/DGM, Safety Officer/Dy.Safety Officer & Factory Manager.
7. Under The Conditions Framed Under Rule-45 Of The Indian Electricity Rules, 1956, **Valid** Electrical contractor License shall be submitted to concern electrical department EE/SE/Electrical Safety Officer/ Safety Officer/Factory Manager at the



**GUJARAT STATE ELECTRICITY CORPORATION LTD**  
Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand - 388610, Ph. 91 2698 242618  
Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmail.com Website: [www.gsecl.in](http://www.gsecl.in)  
CIN: U40100GJ1993SGC019988

- time of apply gate pass by agency/party with latest renewal from Chief Electrical Inspector, Gandhinagar- Gujarat. Electrical License photocopy shall be checked by Concerned HOD of Electrical Department/Electrical Safety Officer/Dy.Safety Officer/ Safety Officer/Factory Manager.
8. As per nature of job/work, qualified supervisor (Diploma (Electrical/ Mechanical/Civil/C&I) + 3 years experiences or ITI + 10 years) shall be engaged by contract agency & qualification certificate with experience certificate shall be submitted to concern EE/SE/LWO/IRO/DGM/ Dy.Safety Officer /Safety Officer/Factory Manager at the time of apply gate pass.
  9. As per rule 3 of CEA regulation ,2010: **Designating person(s) to operate and carry out the work on electrical lines and Apparatus**, Contract person/worker possesses a certificate of competency or electrical work permit, issued by the Appropriate Government. That means, Electrical trade Qualification of contract worker/person like ITI-wireman/ Electrician, Diploma (Elect), BE/B. TECH (Elect), ME/ M. TECH (Elect) shall be submitted to concern EE/SE/LWO/IRO/DGM, Dy.Safety Officer/ Safety Officer/Factory Manager at the time of apply for photo gate pass procedure.
  10. As per nature of job/work & during capital overhauling work /Annual overhauling work /24X7 round the clock work/major shut down work, Qualified Safety Officer/Manager/Supervisor (BE/Diploma (Elect/Mech/Civil) + PDIS-Post Diploma in Industrial Safety) shall be engaged by contractor during dangerous operations/dangerous works as well as day to day dangerous activities, safety supervision, tool box talk, Safety awareness programme, SOP preparation with hazards & its control measures with each step, checking of lifting tools & tackles, hydra mobile crane, Safety precautions, coordination with Safety Department etc.
  11. License of driver shall be submitted with gate pass issue application as per nature of vehicles & to follow the Motor vehicle Act, 1988, the Central Motor Vehicles (Amendment) Rules,2016 as well as Gujarat Motor Vehicles rules,1989 & driver license shall be checked every day by security shift in charge before entry in the Factory premises.
  12. SOP with JSA (Job Safety Analysis) shall be prepared by contractor through competent person as per GFR, 1963 or Qualified Safety Officer as per GFR, 1963 with 05 years experiences. SOP will review & approve by concern JE/DE/EE/SE/Elect. Safety Officer/Dy. Safety Officer /Safety Officer/Factory Manager before execution of work.
  13. It is compulsory to use standard make Personal Protective Equipments (P.P.Es.) as per the job requirement. Do not work without use of required P.P.Es. Contractor is responsible to provide standard make (ISI/DGMS/CE/EN/ANSI approved) & to checked standard/make in PPE issue format by concern JE/DE/EE/SE/Safety Officer/Factory Manager. Personal Protective Equipments / Safety Gadgets suitable to give sufficient protection against hazards involved in their work / job to their staff, as per the job requirement and insist / enforce their workers to put on the same while at works.
- The ongoing work is liable to be stopped at any time if your contract workers/staffs found working without P.P.Es. Following is the list of various P.P.Es (as per ISI/DGMS/CE/ EN/ ANSI approved only) to be used for various works / worksites.
- In any work, Contractor shall be issued the minimum 05 nos. of PPEs like Safety Shoes, Safety Helmet, Safety goggles, Mask & Reusable Ear plug to their workers/supervisor compulsory & it will check by concern section HOD & Dy. Safety Officer /Safety Officer at the time of gate pass procedure.





**GUJARAT STATE ELECTRICITY CORPORATION LTD**  
Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand – 388610, Ph. 91 2698 242618  
Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmail.com Website: [www.gsecl.in](http://www.gsecl.in)  
CIN: U40100GJ1993SGC019988

<b>List of safety equipments</b>	
Industrial Safety Helmet	For protection of head against falling objects or during fall of person from height. <b>Yellow Colour helmet is used for contract worker with agency logo.</b>
Safety Goggles/welding goggles/chemical splash goggles	For protection of eyes against flying particles / dust, chemical splash, welding spark, arc, flashover etc.
Full Face shield	For protection of face against flying particles / dust, chemical splash, spark, arc, flashover etc.
Reusable Earplug / Ear muffs.	For ear / hearing system protection while working in high noise level area.
Chemical suit/Gas tight suit /Fire proximity suit/FR Boiler Suit	For body protection against chemicals, oils, sharp edged objects, heat, hot objects etc.
Safety Hand Gloves	For protection of hands against chemicals, oils, sharp edged objects, heat, hot metals/objects, electricity etc.
Safety shoes/ Gum Boots with Oil/Chemical/water/heat/ Electrical resistance etc.	For protection of leg/feet against falling objects, sharp edged objects, heat, hot metals/objects, electricity etc..
Safety Belt(full body hardness with double lanyard & shock absorber) / Rope / Life line / Fall arrestor etc.	For fall prevention while working at heights or in depth, working in vessel or in confined space.
Dust Mask/Respirator with valve (FFP2)	Protection of respiratory system against dust.
Chemical Cartridge Respirator with full face mask type A2B2E2K2	Protection against toxic chemical fumes / gases/vapors/dust etc.
Trolley mounted Air line respirators with full face mask	Working in oxygen deficient zone or confine space area
Portable Single gas detector like Chlorine, Ammonia, Hydrogen, etc	Working in hazardous storage/process area
Portable Multi gas Detector (LEL,O <sub>2</sub> ,CO,H <sub>2</sub> S,SO <sub>2</sub> , etc)	Working in oxygen deficient zone & use in entry of confine space & Major fire
Automatic voltage detector	To check the present voltage or induction voltage of electrical equipments/ bus/switch gears from 01 (one) feet distance before starting the any electrical work .



**GUJARAT STATE ELECTRICITY CORPORATION LTD**  
Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand - 388610, Ph. 91 2698 242618  
Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmail.com Website: [www.gsecl.in](http://www.gsecl.in)  
CIN: U40100GJ1993SGC019988

Auto darkening welding helmet (EN 379 & EN 175 Level-B) with PAPR as per EN 12941:1998, class TH2 and AS/NZS 1716	<p>The new auto darkening welding helmet combines legendary Speed glass quality and auto darkening technology with an innovative wide-view grinding visor to give welders an all-in-one solution for more flexibility, precision, and efficiency.</p> <p>Respiratory System is a combined face and breathing protection device, for increased comfort and safety in welding. The unit is equipped with a particle filter which removes particles from the air. The unit provides a constant airflow independent of filter combinations and clogging. The unit can also be equipped with a gas filter (for example A1B1E1). The unit supplies air to the head top via the connecting breathing tube. The airflow creates a slight positive pressure which together with the sealing to the face prevents particles and other contaminants from entering the head top.</p>
---	--

All PPEs (as per ISI/DGMS/CE/EN/ANSI approved only) Should issued by party/agency/contractor to their contractor workers as per nature of job and allotment of PPE list shall be submitted to Safety Officer, Dhuvaran on his letter head as per below mentioned format by Contractor before commencement of work through concerned JE,DE,EE/SE .

Sub: Issue of PEE to Contractor workers  
Sub of work Order:  
Work order no.  
Name of Agency:  
Date of Commencement:  
Time limit for work order:

Sr. no.	Name of workers	Designation	Name of Section under work execution	Name of PPE	IS :Code no. of PPE	Make of PPE	Qty	Unit	Date of issue	Receiving signature
A	B	C	D	E	F	G	H	I	J	K
01				Safety Helmet				Nos .		
				Safety goggles				Nos .		
				Reusable Ear Plug				Pair		
				Dust Mask				Nos .		
				Safety Shoes				Pair		

14. Shift Security Inspector/Security Officer shall be checked Safety Shoes & Safety Helmet of all contractor workers at entry gate of Factory Premises & shall entered



**GUJARAT STATE ELECTRICITY CORPORATION LTD**  
Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand – 388610, Ph. 91 2698 242618  
Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmail.com Website: [www.gsecl.in](http://www.gsecl.in)  
CIN: U40100GJ1993SGC019988

- contractor workers with Safety Shoes & Safety Helmet with photo ID Gate Pass.
15. Shift Security Inspector/Security Officer shall be checked validity of Gate pass of all contractor workers on daily basis.
  16. During the work execution, one trained & competent supervisor of agency should always remain present at work site. Concern JE/DE of GSECL shall be supervised the contract work as per SOP.
  17. Approved NABL laboratory calibration certificates of electrical/mechanical/Civil/C&I/Environment survey/Chemical etc measuring /testing equipments/instruments which are used during contract work shall be submitted before starting the work & shall be checked by concern JE/DE/EE before starting work & it's record shall be maintained in concern section.
  18. The contractor shall take all the required safety measures prior to commencement of work on dangerous substances, machineries or area at which cautionary notice is displayed and obtain "Line Clear" or "Work Permit" through the concern Department / Section JE/DE and shall be informed to concern section JE/DE for closed/ returned after completion of work.
  19. Safety talk/Safety work instructions shall be given to contractor workers by concern JE/DE regarding hazards of specific work, risk & it's control measure (mentioned in HIRA) before starting the job work and records shall be maintained for each & every job works.
  20. Display Safety instructions shall be strictly followed by all workers who are working in factory premises.
  21. Material Safety Data Sheet (MSDS) of each chemical shall be available with Chief Chemist/Control room & work related Chemical information shall be taken by contractor & contractor workers from Concern EE/Chief Chemist before starting of chemical handling work.
  22. The contractor shall be checked & securely covered or securely fenced any opened fixed vessel, sump, tank, pit or opening in ground or in floor which, by reason of its depth, situation, construction or contents ,is or may be a source of danger before starting the work each & every days or after interval/recess. Contractor supervisor shall be informed to concerned HOD regarding any unsafe conditions.
  23. Prohibition of smoking, fires, lights, spontaneous ignition substance, matches; fuses, mobile phone etc are to be strictly followed by all workers who are working in factory premises.
  24. Prior to carrying out welding, gas cutting, furnace heating or any other hot work job, remove all the inflammable material lying at or nearby worksite or cover it properly by suitable protective covering. Also, special care shall be taken before carrying out such job & see that all possible contributing factors to set fire shall be removed / vanished prior to commencement of the work. Advance intimation shall be given to concerned section / fire section to commence the work in fire prone areas. They should also keep ready all the First Aid Fire Extinguishers / equipments & fire extinguishing media / material like sand / water buckets or other appropriate equipment at such place.
  25. While carrying out work in confined space or inside vessel, obtain necessary **"Confined Space / Vessel Entry Permit"** from concerned department prior to commencement of the work. For lighting in such areas, only 24-volt (ISI certified & with proper guard) hand lamp shall be used. For taking care of the persons working inside the confined space / vessel, a supervisor / person capable to keep continuous watch on person(s) working inside, assist them in case of emergency or arrange to get immediate outside help, shall remain present at entry point. Use full body safety



belt without failed.

While working inside sewage, trench or in-depth, a person to warn outsiders / entrants / passers etc shall remain available near entry point or the entry point shall be cordoned by a barricaded tape with a cautionary notice. After completion of the works, all the lids / covers / grills / grits opened, shall be re-fixed / re-placed in the original position as it were prior to commencement of the work and leave the work place in safe condition in all respect, so as to prevent accident to fellow workers.

26. The contractor shall see that he / his persons do not work on or block (by stacking material, spare parts, tools-tackles, equipments etc), any passages / walkways / gangways / aisles / staircases / ladders / lifts or any other approaches / roads leading to plans or its auxiliaries, on which there is traffic movements or possible traffic movements in case of emergency. Such passages are meant for safe escape in the event of emergency. If it is utmost necessary to carry out work in such area with blocking of passage, prior permission of Competent Authority or the Engineer-In-Charge shall be obtained. To demarcate / declare the area as **"UNSAFE"**, cordon it using barricading tape & display suitable caution notice or keep a person to restrict / divert the traffic on this route through other safe passage.
27. The contractor shall see that he / his persons do not work on or block (by stacking material, spare parts, tools-tackles, equipments etc), any passages / walkways / gangways / aisles / staircases / ladders / lifts or any other approaches / roads leading to plans or its auxiliaries, on which there is traffic movements or possible traffic movements in case of emergency. Such passages are meant for safe escape in the event of emergency. If it is utmost necessary to carry out work in such area with blocking of passage, prior permission of Competent Authority or the Engineer-In-Charge shall be obtained. To demarcate / declare the area as **"UNSAFE"**, cordon it using barricading tape & display suitable caution notice or keep a person to restrict / divert the traffic on this route through other safe passage.
28. Prior to use power / electrically operated hand tools / equipments / machines / gadgets like welding machine, hand grinder, hand drill etc, ensure for its safe operation & use it only if it is found safe to use. Do not use defective, unsafe or improperly maintained equipments. The electrical power supply required to run such equipments shall not be taken directly at their own but shall be obtained through concerned Electrical Maintenance Departments or their authorized persons or under their observations / guidance only. The Electrical Section shall provide temporary electrical connection up to contractor's Mains Board on which it is compulsory to install mains switch, ELCB & fuses of adequate capacity. All such equipments shall invariably be earthed adequately to prevent electrical shock, sparking, short circuit etc. Power cord to be used shall be of adequate capacity, without any joint & shall consist of earth wire also. Hence, it is necessary to use adequate capacity 3-wire power cord for single & 5-wire power cord for three phase power connections. The plugs, receptacles, pins, holders etc shall be of adequate capacity & safe to use. All electrical & mechanical equipments / tools-tackles viz. welding machine, cutting machine, Grinder, Drill, Chain Pulley Blocks, Hook chooks etc required to be used during work execution shall be of standard make & bear ISI certification mark on it. The consumables like welding electrodes, grinding wheels / discs etc which has specific prescribed life span shall not be used in any case if its expiry date is over.
29. Non-Sparking Non-Magnetic electrical hand tools and tool kits shall be used by Electrical contractor for safe use in areas where hazardous, flammable, or combustible vapors, liquids, dusts, or residues may be present in Gas Based power plant and list of tools and tackles shall be submitted with technical bid. Non-Sparking



**GUJARAT STATE ELECTRICITY CORPORATION LTD**  
Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand - 388610, Ph. 91 2698 242618  
Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmil.com Website: [www.gsecl.in](http://www.gsecl.in)  
CIN: U40100GJ1993SGC019988

Non-Magnetic electrical hand tools and tool kits shall be checked by JE/DE before commencement of Electrical work.

30. Before using lifting machines / tackles (like C.P.Bs., Hook chooks, winch, forklift, mobile crane, EOT crane etc) & its attachments (like D-shackles, slings, U-clamps, Eye bolts or any fixtures), it shall be checked and used only if found safe to use. Also, ensure that these are tested, examined & certified in form no.10 by Competent Person as per the Factory act-1948 & Gujarat Factories Rules and its validity do not expire. Further, it shall be fixed properly and firmly prior to lifting the weight. **Valid Test certificate of all Lifting machines used by Contractor to be submitted to Dy.Safety Officer/ Safety Officer before commencement of work through concerned EE/SE.**
31. Metal Scaffoldings to be used for working at height shall be of adequate size & capacity. Obtain the work permit when working at height. While climbing on such scaffolding or working on any structure at height, use of full body safety belt /full body hardness with double lanyard & Fall arrestor & Helmet is compulsory. It is also necessary to fasten chinstraps of the helmet.
32. Contractor or their employee shall not interfere in day-to-day routine plant activities / works except the work assigned to them, shall not loiter in the areas other than their work jurisdiction, as well as shall not temper / operate / touch the machineries/equipments/auxiliaries with which they are not concerned. Also, the contractor shall strictly instruct their staff for not to sit or take rest at/near/below running plants, auxiliaries, systems or any place which is risky, hazardous & prone to accident.
33. The cylinders containing poisonous / toxic or inflammable / explosive gas like Oxygen, Acetylene, LPG, Hydrogen, Ammonia, Chlorine, CO2 etc shall be handled safely taking due care. To handle / shift such cylinders a special trolley /cage meant for it must be used but in no case it should be rolled.
34. In Gas Based Power station/Hydrogen storage area /Hydro carbon fumes-vapour generated area, Spark arrestor (as per approved manufacturer of CCOE, Nagpur) shall be provided on each vehicle by party/agency and it will check by shift security in charge before entry of vehicles in the factory premises.
35. No women or young person shall be employed or permitted to work in Lead-compound area like battery room etc. as per schedule VI of GFR 1963.
36. No women or young person shall be allowed to clean, lubricate or adjust any part of a prime mover or of any transmission machinery while the prime mover or transmission machinery is in motion. Examination or operation of motion machinery shall be made or carried out only by a specially trained adult male worker wearing tight fitting clothing as per section 22 of factories act 1948.
37. In all risky job, before start the work, contractor should obtain General Safety Work Permit through concerned section from Shift –in-charge well in advance.
38. In case of noticing smoke or fire during their work execution, they shall make immediate efforts to extinguish / control it and simultaneously inform the Fire Station Mobile No as well as Station Fire Officer or Emergency Control room no which is displayed at prominent place of factory like Main Security Gate, All unit control room, Canteen area, Safe Assembly points, Fire Station, All security gates, Occupational Health Centre.
39. In case of any injury / accident while working, it shall immediately be reported to Safety Department through concerned Sectional Head / Engineer. The prescribed **Form No. 21 & ANNEXURE** may be obtained from concerned section or Dy.Safety Officer/Safety Officer.





40. In case of any electrical accident, it shall immediately be reported to Electrical Safety Officer through concern Sectional Head / Engineer. The prescribed **Electrical accident form no. A as per electricity act-2003 & Form No. 21 & ANNEXURE as per Gujarat Factories rules** shall be filled up by concern department JE/DE with written consent of contractor. The Form may be obtained from concerned Electrical section or Electrical Safety Officer. Electrical accident investigation shall be carried out by Electrical Safety Officer with Factory Manager. After any reportable accident, Contract agency shall be submitted the fitness certificate of injured person with endorsement of GSECL factory Medical Officer to LWO/Dy. Safety Officer/Safety Officer/Electrical Safety Officer then after injured person may allow for work. For any incident occurred but have no injury to any persons should also reported as per GSECL format and informed to Dy. Safety Officer/Safety Officer as **Near Miss Incident**.
41. **Safety penalty** shall be imposed against Offences by contract workers: If any contract worker worked in a factory contravenes any provision of Factories act or any rules or orders made there under, imposing any duty or liability on workers, contractor/agency shall be punishable with fine which mentioned as under.

Sr. No.	Description of penalty	Amount
(i)	Work without PPEs	Rs.300/- per person
(ii)	Work without work Safety permit like working at height, confine space entry, hot work etc.	Rs.1000/- per day
(iii)	License of driver as per type of vehicles not registered.	Rs.750/- per person
(iv)	Welding work without flashback arrestor/double gauge regulator set	Rs.1000/- per set
(v)	Operate Portable power tool without ELCB	Rs.1000/-per equipment
(vi)	Work without qualified Supervisor as per nature of job like mechanical, electrical, civil, C&I, chemical etc.	Rs.1000/-per day
(vii)	Work without SOP & JSA	Rs.2000/-per day
(viii)	Work without test report of lifting machines / tackles (like C.P.Bs., Hook chooks, winch, forklift, mobile crane, EOT crane etc) & its attachments (like D-shackles, slings, U-clamps, Eye bolts or any fixtures) in Form No.10 of Gujarat Factories Rules,1963	Rs.2000/- per equipment
(ix)	Work without Double lynyer Safety belt during working at Height work, work without anchoring in hook/line line	Rs.3000/-per person
(x)	Work without 24 Volt supply in Confine space area	Rs.3000/-per person

Safety Penalty is to be imposed directly by individual Dy. Safety Officer/Safety Officer/Electrical Safety Officer and Factory Manager/Occupier against violation of statutory requirements and penalty will be recovered through RA bill. Photograph/CCTV camera footage is to be put up with penalty note by imposed individual officer.



**GUJARAT STATE ELECTRICITY CORPORATION LTD**  
Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand - 388610, Ph. 91 2698 242618  
Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmil.com Website: [www.gsecl.in](http://www.gsecl.in)  
CIN: U40100GJ1993SGC019988

42. Party will damage any fire equipments or property or machinery in factory during execution of work, total damage cost will be recovered from party RA bill and recovery Office note put up by concern HOD.
43. All the relevant labour and industrial laws shall also be followed compulsorily.
44. After completion of work, cotton waste, grease, oil, unused material, welding rod pieces, scrap etc. are to be removed by contractor and scrap shall be deposited to scrap yard of Main Store.
45. For performance evaluation of contractor, safety factors of work accident, fire incident & near miss accident will be considered. Steps can be taken to review the job assignment up to cancellation for negligence.
46. Over & above these, contractor shall have to follow all the safety requirements /rules & regulations / norms and legal provisions laid down in various statutes. Particularly the provisions of The Factories Act-1948 & the Gujarat State Factories Rules-1963 (Amended up to date), The Electricity Act-2003 & rules, BOCW Act/Rules shall be followed strictly. The contractor shall also obey the rules / regulations / instructions of the local Competent Authority for safety & health requirements.
47. The above rules shall be scrupulously followed and where required, Contractor /contractor workers may contact to the Dy.Safety Officer/Safety Officer/Electrical Safety Officer in case of any ambiguity or needs further guidance in this regard.
48. Contractor performance evaluation shall be carried out by GSECL at every 3 moth interval as per GSECL format.





**GUJARAT STATE ELECTRICITY CORPORATION LTD**  
Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand – 388610, Ph. 91 2698 242618  
Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmil.com Website: [www.gsecl.in](http://www.gsecl.in)  
CIN: U40100GJ1993SGC019988

### **SPECIAL CONDITION FOR CONFLICT OF INTEREST AMONG BIDDERS / AGENTS**

A bidder shall not have conflict of interest with other bidders for particular quoted item. Such conflict of interest can lead to anti-competitive practices to the detriment of Procuring Entity's interests. The bidder found to have a conflict of interest shall be disqualified. A bidder may be considered to have a conflict of interest with one or more parties in this bidding process for particular quoted item, if:

- (a) They have proprietor / partner(s) / Director(s) in common; or
- (b) They receive or have received any direct or indirect subsidy / financial stake from any of them; or
- (c) They have the same legal representative / agent for purposes of this bid; or
- (d) They have relationship with each other, directly or through common third parties, that puts them in a position to have access to information about or influence on the bid of another bidder, or
- (e) Bidder participates in more than one bid in this bidding process. Participation by a bidder in more than one Bid will result in the disqualification of all bids in which the parties are involved. However, this does not limit the inclusion of the any works / components / sub-assembly / assemblies from one bidding contractor / manufacturer in more than one bid.
- (f) In cases of agents quoting in offshore procurements, on behalf of their principal manufacturers, one agent cannot represent two manufacturers or quote on their behalf in a particular tender enquiry. One manufacturer can also authorise only one agent/ dealer. There can be only one bid from the following:
  - 1. The principal manufacturer directly or through one Indian agent on his behalf; and
  - 2. Indian/ foreign agent on behalf of only one principal
- (g) A Bidder or any of its affiliates participated as a consultant in the preparation of the design or technical specifications of the contract that is the subject of the Bid;
- (h) In case of a holding company having more than one independently manufacturing units, or more than one unit having common business ownership / management, only one unit should quote. Similar restrictions would apply to closely related sister companies. Bidders must proactively declare such sister/ common business/ management units in same/ similar line of business.
- (i) Bidder shall not act in contravention/ violation to the provisions of competition act, as amended from time to time.

Every bidder should, at the time of submission of bid, give a declaration, that bidder shall not have conflict of interest with other bidders for particular quoted item, as above.

Note: Remove word “for particular quoted item” from above clause, where bidders are asked to quote rates for all tender items i.e. rates are called on % age basis.

**Chief Engineer (Gen)  
GSECL, DGBPS**



**GUJARAT STATE ELECTRICITY CORPORATION LTD**  
Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand - 388610, Ph. 91 2698 242618  
Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebm.com Website: [www.gsecl.in](http://www.gsecl.in)  
CIN: U40100GJ1993SGC019988

### **INTEGRITY PACT**

<b><u>GSECL's COMMITMENT</u></b>	<b><u>PARTY's COMMITMENT</u></b>
To maintain the highest ethical standers in business and professions.	Not to bring pressure recommendations from outside GSECL to influence its decision.
Ensure maximum transparency to the satisfaction of stakeholders.	Not to use intimidation, threat, inducement or pressure of any kind on GSECL OR ANY OF its employee under any circumstances.
To ensure to fulfill the terms of agreement/contract and to consider objectively the view point.	To be prompt and reasonable in fulfilling the contract, agreement, legal obligations.
To ensure regular and timely release of payments on due dates for work done.	To provides goods and / or service timely as per agreed quality and specifications at minimum cost of GSECL.
To ensure that no improper demand is made by employees or by anyone on our behalf.	To abide by the general discipline to be maintained in our dealings.
To give maximum possible assistance to all the Vendors/Suppliers/service provider and other to enable them to complete the contract in time.	To be true and honest in furnishing information.
To provide all information to suppliers / contractors relating to contract /job which facilitate him to complete the contract / job successfully in time.	Not to divulge any information, business details available during the course of business relationship to others without the written consent to GSECL.
To ensure minimum hurdles to Venders / suppliers / contractors in completion of agreement / contract work order.	Not to enter in to carter / syndicate/ understanding whether formal/ non formal so as to influence the price.
Ensure maximum transparency to the satisfaction of stakeholders.	Not to bring pressure recommendations from outside GSECL to influence its decision.
To ensure to fulfill the terms of agreement/contract and to consider objectively the view point.	Not to use intimidation, threat, inducement or pressure of any kind on GSECL OR ANY OF its employee under any circumstances.
To ensure regular and timely release of payments on due dates for work done.	To be prompt and reasonable in fulfilling the contract, agreement, legal obligations.
To ensure that no improper demand is made by employees or by anyone on our behalf.	To provides goods and / or service timely as per agreed quality and specifications at minimum cost of GSECL.
To give maximum possible assistance to all the Vendors/Suppliers/service provider and other to enable them to complete the contract in time.	To abide by the general discipline to be maintained in our dealings.

### **OUR ENDEAVOUR**

To create an environment where business Confidence is built through Best Business practices and is fostered in an atmosphere of trust and respect between providers of goods and service and their users for the ultimate benefit of society and the nation.

-----  
-----

Seal & Signature  
(GSECL's Authorized Signatory)

-----  
-----  
Seal & Signature  
(Contractor's authorized person)



**GUJARAT STATE ELECTRICITY CORPORATION LTD**  
Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand – 388610, Ph. 91 2698 242618  
Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmail.com Website: [www.gsecl.in](http://www.gsecl.in)  
CIN: U40100GJ1993SGC019988

**GUJARAT STATE ELECTRICITY CORPORATION LIMITED**  
**APPLICATION FORM FOR PHOTO GATE PASSES OF CONTRACTOR & CONTRACT WORKERS**

01	Name And Address of The Firm	
02	Name And Mobile No. Of The Contractor & Site In-charge	
03	Work Order No. & Date	
04	Subject of Work	
05	Name of Section	
06	Duration/period of Work	
07	Date of commencement	
08	Contract agreements/ subletting work contract documents with approval copy	
09	Total No. of Workmen required for this work order (In Figure and words) is to be given on letterhead of contractor	<b>Local:</b> <b>Out State :</b> Male:          Male: Female:       Female: <b>Total:</b>
10	Labour License /IMSW License Obtained for No. of Labours and validity thereof.	
11	BOCW Registration No. and date	
12	Insurance Obtained for No. of Labours and validity thereof	
13	Detail of P.F. Code No.	

**CERTIFICATE**

I, .....Prop./Manager/In-Charge of M/s. ....give assurance that all the details related to labours as per the attached list herewith are true and also give assurance that none of the labours are involved in any anti social activities or having criminal records. I am solely responsible if any dispute will arise in future.

Signature of Sub Contractor with Rubber Stamp      Signature of Contractor with Rubber Stamp  
Name : \_\_\_\_\_ Name : \_\_\_\_\_

**For Office Use Only**

M/s. ....will be issued Gate Pass for the Work Order mentioned in the List attached herewith for the .....Nos. of Labours for the period of ..... to .....(03 months only).Documents are checked & verified as per GSECL photo gate pass procedure.

Executive Engineer (      )  
Signature with Stamp

Superintending Engineer (      )  
Signature with Stamp

Labour welfare Officer/Industrial Relation Officer  
Factory Medical Officer: to maintain record in form no.32 & 33  
Electrical Safety Officer  
Factory Manager/Occupier

Safety Officer/Dy. Safety Officer

**To, Security Officer: To issue gate pass & maintain record of gate pass. If any remark put up by any officer, it will convey to Factory Manager & Occupier.**

[P.T.O]



**GUJARAT STATE ELECTRICITY CORPORATION LTD**  
Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand - 388610, Ph. 91 2698 242618  
Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmail.com Website: [www.gsecl.in](http://www.gsecl.in)  
CIN: U40100GJ1993SGC019988

**Following details shall be provided by Contractor on his Company's letter head**

Work Order No. & Date

Subject of Work:

No. of Labours:

Details of Contractor & Contract Labour

Sr. No.	Full Name of Worker as per id proof	Permanent Address of Worker	Present Address of Worker	Date of Birth / Age	Employees PF Code No.	Identification Mark on Body
1						
2						
3						
4						
5						
6						
7						

**LIST OF DOCUMENTS ARE ATTACHED WITH APPLICATION FOR PHOTO GATEPASSES OF CONTRACTOR & CONTRACT WORKERS**

Sr. No.	Description of documents	Attached YES/NO
1	Copy of Work Order	
2	Copy of P. F. Code No.	
3	Insurance Policy as per subject of work order under the Workmen Compensation Act, 1923	
4	Contract agreements/ subletting work contract documents with approval copy	
5	Filled Gate Pass Application Form and List of Labours in 1 Copy.	
6	Self-attested Copy of Id proof of Aadhar card or Election voting card or driving license or Passport only	
7	List of Indian Standard or International Standard mark PPEs provided to contract worker in prescribe Format as per nature of hazardous process and operations.	
	PPE undertaking of Contract Agency which submitted in work tender.	
8	GSECL 3D animation Safety Induction movie showing attendance sheet copy	
9	Final Safe Operating Procedure -SOP with JSA (Job Safety Analysis) signed documents which submitted in work tender.	
10	Qualification of work Supervisor, Safety supervisor, Safety Officer	
11	Electrical Contractor License, Form-I& Electrical trade person qualifications copy in Electrical work only which submitted in work tender.	
12	Gujarat BOCW registration in Form-II copy if applicable	
13	Form no.10: Prescribed for report of examination of the lifting machines like CPB, winch machine, wire rope slings D-shackles, belt slings, chain slings, eyebolts, polyester web/round sling etc of all capacities if used.	
14	Driver license of LMW, Mobile crane, tractor, fork lift photo copy, RTO Fitness certificate in from no.33, PUC certificate, Vehicle insurance policy, spark arrestor if used.	
15	Approved NABL laboratory calibration certificates of electrical/mechanical/Civil/C&I/Environment survey/Chemical etc. measuring /testing equipment's /instruments if used.	
16	Copy of Police Verification in respect of each contract workers	

Signature of Contractor with Rubber Stamp  
Rubber Stamp  
Name:

Signature of Sub Contractor with  
Name:



**GUJARAT STATE ELECTRICITY CORPORATION LTD**  
Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand - 388610, Ph. 91 2698 242618  
Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmail.com Website: [www.gsecl.in](http://www.gsecl.in)  
CIN: U40100GJ1993SGC019988

## Summary of Salary/ Wages paid Details to be filled up by contractor

Name of  
Work: \_\_\_\_\_

Work Order No: \_\_\_\_\_

Date of Commencement \_\_\_\_\_ Date of completion \_\_\_\_\_

R. A Bill/ Final Bill: \_\_\_\_\_

Sr. No	Month	Total Manpower Engaged	Days worked	Gross Wages	Deduction		Net Wages	Remarks
					PF	Others		
1								
2								
3								
4								
5								
6								

Signature of Contractor: \_\_\_\_\_

Name of Contractor: \_\_\_\_\_ Mob. No. \_\_\_\_\_



**GUJARAT STATE ELECTRICITY CORPORATION LTD**  
Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand - 388610, Ph. 91 2698 242618  
Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmail.com Website: [www.gsecl.in](http://www.gsecl.in)  
CIN: U40100GJ1993SGC019988

**ANNEXURE-C**  
**UNDERTAKING BY CONTRACTOR FOR LABOUR LAWS**

I, \_\_\_\_\_ S/O

\_\_\_\_\_  
In-charge/Manager/Proprietor/Partner/Director/Owner of \_\_\_\_\_,  
do hereby declare and undertake as under:

- (1) That in the capacity of Independent contractor for M/s Gujarat State Electricity Corporation Limited, Dhuvaran I have complied with provision of all laws as applicable. I have paid the wages through either by account payee cheque or by crediting the wages in bank accounts only for the month of \_\_\_\_\_ which are not less than minimum rates applicable, to all my employees and no other dues are payable to any employee engaged at Gujarat State Electricity Corporation Limited, Dhuvaran against the work order / PO awarded.
- (2) That I have covered all the eligible employees under 'Employees Provident Fund and Miscellaneous Provisions Act and deposited the contributions for the following months and as such no amount towards contributions whatsoever is payable of the employees engaged at Gujarat State Electricity Corporation Limited, Dhuvaran against the work awarded .
- (3) I further declare and undertake that in case any liability pertaining to my employees is to be discharged by M/s Gujarat State Electricity Corporation Limited, Dhuvaran due to its lapse, I undertake to reimburse the same. M/s Gujarat State Electricity Corporation Limited, Dhuvaran is also authorised to deduct the same from my dues as payable.

Our Code Numbers are as follows:

ESI/Employee compensation/Workman compensation:

EPF & MP Act \_\_\_\_\_

**Contractor or its authorized Representative's Signature with seal**

**Full Name of contractor:**



**GUJARAT STATE ELECTRICITY CORPORATION LTD**  
Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand - 388610, Ph. 91 2698 242618  
Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmil.com Website: [www.gsecl.in](http://www.gsecl.in)  
CIN: U40100GJ1993SGC019988

**ANNEXURE**

**COMPULSORY UNDERTAKING OF BIDDER REGARDING QUALITY OF PPEs  
(PERSONNEL PROTECTIVE EQUIPMENTS)**

Ref.: Tender no.: \_\_\_\_\_

"I / We \_\_\_\_\_,

Authorized signatory of M/s \_\_\_\_\_

Hereby certify that following mentioned PPEs (as per ISI/DGMS/CE/EN/ANSI approved only) must be issued to our all contract workers as per nature of hazards before execution of work.

Sr. no.	Name of PPE	ISI Code no. of PPE	Make of PPE	Qty	Unit
1	Safety Helmet				Nos.
2	Safety goggles				Nos.
3	Reusable Ear Plug				Pair
4	Dust Mask				Nos.
5	Safety Shoes				Pair
6					
7					
8					
9					
10					

If our company is not provided above mentioned good quality of PPE's, Safety Officer and Factory manager shall be empowered to stop the work without any notice.

**Seal of the Firm**

**Signature of Authorized signatory**

**Date**





**GUJARAT STATE ELECTRICITY CORPORATION LTD**  
Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand - 388610, Ph. 91 2698 242618  
Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmil.com Website: [www.gsecl.in](http://www.gsecl.in)  
CIN: U40100GJ1993SGC019988

**General terms and condition**

- 1) If any additional deviation in specification please clearly mention in separate on this page of Technical Bid, dully signed. In no circumstances price should be quoted on this page
- 2) Party has to accept Payment terms as per GSECL norms
- 3) Bidder should give minimum required validity of offered rate for **120 days** from date of actual opening of Technical bid.
- 4) Party should invariably mentioned **GST, HSN code for each Items & PAN NUMBER** in their technical bid otherwise your offer will be ignored and price bid will not be opened.
- 5) Bidder should confirm delivery period as per GSECL requirement and same should be confirmed in Technical bid.
- 6) **The bidder must submit authorized dealer/distributorship certificate along with tech. bid OR he may produce purchase proof from OEM/Authorized dealer with bulk supply.**
- 7) Party shall have to quote their rates in case of Web tender in Schedule "B" of Price bid and in case of E-tender shall have to submit the rate online only. The details of applicable GST, taxes/duties, service charges, packing & forwarding charges, freight, and insurance, F.O.R. etc. shall be indicated clearly in Price Bid.
- 8) Bidder should keep their commercial terms and conditions similar in both technical Bids as well as in price Bid. They should not differ in any of the bid otherwise offer will be ignored. Only prices should be submitted along with only price Bid and not with the Technical bid.
- 9) Non complying of the above condition of the tender liable to be rejected.
- 10) GSECL reserves the right to prefer the overall lowest party or part order as if deem fit.
- 11) Supplier shall have to submit all the necessary documents like material Test certificate, other required test certificates, guarantee certificate, invoice etc along with supply as per the order terms. Without relevant required documents, further process of payment will not be initiated.
- 12) GST TDS shall be deducted as per notification of Govt. of India.
- 13) GST claim by party in Invoice is retained by GSECL, after verification in GSTR 2A amount will be released.
- 14) TDS as per 194Q applicable as per notification of Govt. of India.
- 15) Repeat order: GSECL reserves right for the placement of repeat order @ 50% of the order quantity / value within 6 [ Six ] months from the date of order .
- 16) Sample shall be submitted with technical bid or deputed your representatives with quoted materials sample after opening of technical bid.
- 17) Company Technical brochures shall be submitted with technical bid.
- 18) Bidder cannot be allowed to withdraw their offer after opening of bid. If withdraw the offer in that case EMD shall be forfeited and bidder will not be allowed to participate in the tenders for the period of one year.



**GUJARAT STATE ELECTRICITY CORPORATION LTD**  
Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand – 388610, Ph. 91 2698 242618  
Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmail.com Website: [www.gsecl.in](http://www.gsecl.in)  
CIN: U40100GJ1993SGC019988

**Payment Guideline for suppliers:-**

1. All suppliers of imported material shall have to submit GST invoice with clearly mentioned quantity and category of plastic used (in microns) for packaging on imported materials. Suppliers are informed to use minimum quantity of plastic for packaging or may use any alternate eco friendly suitable material other than plastic as per central pollution control board (CPCB) guideline.
2. The party must agree to participate in the VMS during the tender process and provide the necessary details to streamline the VMS registration process and to avoid delays in payment for supplies.
3. For registration in GSECL's VENDOR MANAGEMENT SYSTEM (VMS) <https://vms.guvnl.com>, vendor is required to submit details of PAN, GST, official email ID for receiving OTP, bank details, and any other information as required.
4. After successful registration, the vendor will receive a VMS link, along with a login ID and password, to process invoices.
5. Vendor must upload invoice of supplied material in VMS portal to process payment.
6. The SOPs for New Vendor Registration and Invoice Submission are available at the link above.

"I/we hereby have read the above documents and agree for the Conditions vide above documents and accordingly submitted my/our offer."

**Signature of Contractor with Place /  
Date / Firm Seal / Stamp**

**For, Gujarat State Electricity Corporation Ltd.**

**Chief Engineer (Gen.)  
GSECL, DGBPS.**



**GUJARAT STATE ELECTRICITY CORPORATION LTD**  
Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand - 388610, Ph. 91 2698 242618  
Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmail.com Website: [www.gsecl.in](http://www.gsecl.in)  
CIN: U40100GJ1993SGC019988

### DETAILS OF BIDDER

01.	Name of Firm & Contact Person	
02.	Full Postal Address	
	Phone/Fax No.	
	Mobile No.	
	E-mail Address :	
03.	GST No.	
04.	Status of the firm with supporting documents	Proprietary /Partnership /Pvt. /Public Limited.
05.	Name of Agencies/Directors if not prop. Name of owner, if propriety, with phone/Fax Nos.	
06.	SSI/NSIC No. ( Notarized copy)	
07.	PAN No:	

### IMPORTANT NOTE

01. This tender should be submitted duly signed without removing a single page. Otherwise the tender is liable to be rejected.
02. For SUPPLY TENDER, GST number should be invariable mentioned in their technical bid otherwise your offer will be ignored and price bid will not be opened.

**Signature of Contractor with Place /  
Date / Firm Seal / Stamp**



**GUJARAT STATE ELECTRICITY CORPORATION LTD**  
Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand – 388610, Ph. 91 2698 242618  
Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmail.com Website: [www.gsecl.in](http://www.gsecl.in)  
CIN: U40100GJ1993SGC019988

## **ANNEXURE-I**

### **ON FIRM'S LETTER HEAD**

I / We\_\_\_\_\_ Authorized signatory of

M/s.\_\_\_\_\_ here by certify that...

M/s.\_\_\_\_\_ is not related with other firms

who have submitted tenders for the same items under this Tender.

Seal of the Firm :

Place :

Signature of the Tenderer :

Date with Designation:



**GUJARAT STATE ELECTRICITY CORPORATION LTD**  
Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand – 388610, Ph. 91 2698 242618  
Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmail.com Website: [www.gsecl.in](http://www.gsecl.in)  
CIN: U40100GJ1993SGC019988

## **Annexure-II**

### **DEVIATION FROM BIDDER (IF ANY)**

#### **NOTE:-**

1. GSECL does not bind to accept the deviation offered by bidder for evaluation of tender.
2. If there is any deviation from bidder, it should be clearly mentioned on this page.
3. Deviation mentioned on other page should not be considered and order will be placed according to the tender documents.
4. If there is no any deviation from bidder, than it must be clearly mentioned in this page “NO DEVIATION OFFERED”

Signature of the Contractor  
With seal



**GUJARAT STATE ELECTRICITY CORPORATION LTD**  
Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand - 388610, Ph. 91 2698 242618  
Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmail.com Website: [www.gsecl.in](http://www.gsecl.in)  
CIN: U40100GJ1993SGC019988

**UNDERTAKING IN REGARD TO STOP DEAL / BLACK LIST THEREOF**

All bidders will have to furnish the following undertaking duly filled in, signed and stamped for each quoted item of the tender along with the Technical Bid.

I/We \_\_\_\_\_

Authorized signatory of M/s \_\_\_\_\_

\_\_\_\_\_ here by certify that

M/s \_\_\_\_\_

\_\_\_\_\_ is not stop deal/black listed by GUVNL and or their any subsidiary company viz. GSECL/GETCO/DGVCL/MGVCL / UGVCL / PGVCL.

Signature of the Tenderer  
Seal of the Firm



**GUJARAT STATE ELECTRICITY CORPORATION LTD**  
Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand - 388610, Ph. 91 2698 242618  
Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmil.com Website: [www.gsecl.in](http://www.gsecl.in)  
CIN: U40100GJ1993SGC019988

**Third-Party Inspection: ( APPLICABLE FOR THIS TENDER)**

**1. Having estimated cost up to Rs.1.0 Cr. (without tax) shall include following condition.**

"All bidders shall submit the details/documents in support of Technical Qualification Requirements duly certified and verified for authenticity from Specified Third-Party Inspection Agency (TPIA) or Statutory Auditor of their Company or Practicing CA./CA Firm along with a certificate regarding verification of authenticity of documents as per the format placed at Annexur-1. All the documents submitted by the bidder in support of the meeting Technical QR only shall be digitally signed by the Specified Third-Party Inspection Agency (TPIA) or Statutory Auditor of their Company or Practicing CfuCA Firm.

**2. Having estimated cost above Rs.1.0 Cr. (without tax) shall include following condition.**

"All bidders shall submit the details/documents in support of Technical Qualification Requirements duly certified and verified for authenticity from Specified Third-Party Inspection Agency (TPIA) along with a certificate regarding verification of authenticity of documents as per the format placed at Annexur-1. All the documents submitted by the bidder in support of the meeting Technical QR only shall be digitally signed by the Specified Third-Party Inspection Agency (TPIA).

The verification and certification of authenticity of documents is acceptable from any of the following TPIAs:

1. M/s Competent Inspectorate and Consultants Pvt. Ltd, Hyderabad, India
2. M/s Gulf Lloyds Industrial Service India Pvt. Ltd.-Ahmedabad.
3. M/s International Certifications Services.
4. M/s Intertek India Pvt. Ltd.
5. M/s SGS India Pvt. Ltd.
6. M/s Moody International (India) Pvt. Ltd.
7. M/s TUV SUD South Asia (P) Ltd.
8. M/s TUV Rheinland (India) Pvt. Ltd.
9. M/s Bureau Veritas (India) Pvt. Ltd.
10. Hertz Inspection & Services Pvt. Ltd.
11. IRCLASS Systems and Solutions Pvt. Ltd.

Verification for authenticity shall not be applicable in following cases.

- 1: Single tender and Limited tenders as they are issued to preselected bidders.
- 2: Bidders having proven track record or regular suppliers/contractors (i.e. OEM/OES/PSUS)





**GUJARAT STATE ELECTRICITY CORPORATION LTD**  
Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand – 388610, Ph. 91 2698 242618  
Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmail.com Website: [www.gsecl.in](http://www.gsecl.in)  
CIN: U40100GJ1993SGC019988

3: Past order copies of GSECL as these documents can be verified internally.

Bidders shall be responsible for getting their documents/ credentials verified & certified by the Specified Third-Party Inspection Agency (TPIA) or Statutory Auditor of their Company or Practicing CA/CA Firm in support of Technical QR. All the costs pertaining to third party verification and certification (including those by statutory auditors) shall be borne by the Bidder. GSECL shall have no liability (financial or otherwise) towards the same and shall not be liable for any claim/ dispute between the bidder and the Specified Third-Party Inspection Agency (TPIA) or Statutory Auditor of their Company or Practicing CA/CA Firm



**GUJARAT STATE ELECTRICITY CORPORATION LTD**  
Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand – 388610, Ph. 91 2698 242618  
Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmail.com Website: [www.gsecl.in](http://www.gsecl.in)  
CIN: U40100GJ1993SGC019988

**(Appendix 1)**

**( APPLICABLE FOR THIS TENDER)**

**Annexure-1**

Undertaking from Third Party Inspection Agency/Statutory Auditor or Practicing CA/CA Firm

(On letter head digitally signed by a person duly authorized to Sign on behalf of the firm)

Ref:

Date:

To,

GSECL.

Power Station .....

Subject: Authentication of veracity of documents submitted by M/s ..... in support of Meeting the  
Qualifying Requirements

Ref : Tender no. ....

Name of the Package/ Tender: .....

Dear Sir,

M/s. .... (hereinafter called Bidder) having Registered office at .....  
intend to participate in above referred tender of GSECL.

The tender condition stipulates that the bidder shall submit supporting Documents pertaining to  
Qualifying Requirement duly verified and certified by Third-Party Inspection Agency (TPIA) or  
Statutory Auditor of their Company or Practicing CA/CA Firm as per the list mentioned in the  
bidding documents.

In this regard, it is hereby confirmed that we have examined the following documents, which are  
also attached with this letter. The same has been verified from the Original Documents and / or  
Client for authenticity.

We hereby confirm that the following documents are found to be genuine and authentic.

1. Doc ref. no. .... dated ..... (name of Documents)
2. Doc ref. no. .... dated ..... (name of Documents)
3. ....

All the aforesaid documents have been digitally signed by us as a certificate of authenticity.

We further confirm that we neither have any vested interest in aforesaid tender nor have any  
conflict of interest in respect of above tender.

This certificate is issued at the request of M/s ..... (Bidder) for the purpose of  
participating in the subject tender/s.

Thanking you, .....



**GUJARAT STATE ELECTRICITY CORPORATION LTD**  
Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand - 388610, Ph. 91 2698 242618  
Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmail.com Website: [www.gsecl.in](http://www.gsecl.in)  
CIN: U40100GJ1993SGC019988

## **INTEGRITYPACT - OUR ENDEAVOUR**

To create an environment where Business Confidence is built through Best Business Practices and is fostered in an atmosphere of trust and respect between providers of goods and services and their users for the ultimate benefit of society and the nation.

	<b>GSECL'S COMMITMENT</b>		<b>PARTY'S COMMITMENT</b>
%	To maintain the highest ethical standards in business and professions.	%	Not to bring pressure recommendations from outside GSECL to influence its decision.
%	Ensure maximum transparency to the satisfaction of stakeholders.	%	Not to use intimidation, threat, inducement or pressure of any kind on GSECL or any of it's employees under any circumstances.
%	To ensure to fulfill the terms of agreement / contract and to consider objectively the viewpoint of parties.	%	To prompt and reasonable in fulfilling the contract, agreement, legal obligations.
%	To ensure regular and timely release of payments on due dates for work done.	%	To provide goods and / or services timely as per agreed quality and specifications at minimum cost to GSECL.
%	To ensure that no improper demand is made by employees or by any one on our behalf.	%	To abide by the general discipline to be maintained in our dealings.
%	To give maximum possible assistance to all the Vendors / Suppliers / Service Provider and other to enable them to complete the contract in time.	%	To be true and honest in furnishing information.
%	To provide all information to Suppliers / Contractors relating to contract / job which facilitate him to complete the contract / job successfully in time.	%	Not to divulge any information, business details available during the course of business relationship to other without the written consent of GSECL.
%	To ensure minimum hurdles to vendors / suppliers / contractors in completion of agreement / contract / work order.	%	Not to enter in to carter / syndicate / understanding whether formal / non-formal so as to influence the price.

**Seal & Signature**  
**(Party's Authorized Person)**  
**Name:**

**Seal & Signature**  
**(GSECL's Authorized Signatory)**  
**Name :**  
**Designation :**



**GSECL**

**GUJARAT STATE ELECTRICITY CORPORATION LTD**

Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand - 388610, Ph. 91 2698 242618

Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmail.com Website: [www.gsecl.in](http://www.gsecl.in)

CIN: U40100GJ1993SGC019988

On Company's Letter Head]

**ANNEXURE-13**

(Required for price justification, if necessary)  
(UNDERTAKING IN REGARD TO QUOTED PRICE)

(All bidders will have to furnish quoted items/works of the following undertaking duly filled in, for all the of the quoted items/works of the tender along with online Technical Bid)

Ref.: Tender No..... /Gem Bid. No

We, the undersigned, hereby declare and undertake that we have not accepted or executed any Letter of Acceptance (LOA) or Purchase Order (PO) at a unit ex-works price/any work at rate lower than the rate offered in this tender in any station of GSECL/GUVNL & subsidiaries / CSPU/SPU/IPP etc. during the period of six (6) months prior to two (2) months after the bid submission date of this tender.

We also understand that LOA/Purchase Order placed by any station of GSECL/GUVNL subsidiaries / CPSU /SPSU/ IPP etc. on the basis of above undertaking shall not be considered as 'offered' price for the tender items in subsequent tender, if it is not within period mentioned above.

I / We accept above undertaking.

**Seal of the Firm**

**Signature of the Tenderer  
With Designation**

**Place:**

**Date:**



**GUJARAT STATE ELECTRICITY CORPORATION LTD**  
Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand – 388610, Ph. 91 2698 242618  
Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmil.com Website: [www.gsecl.in](http://www.gsecl.in)  
CIN: U40100GJ1993SGC019988

**90060000:DHUVARAN THERMAL POWER STATION - 388610**  
**SCHEDULE-B (Price Bid)**

**Description: SUPPLY OF FLOW METERS FOR CCPP-1, 2, 3 & COLONY AREA FOR GSECL, DGBPS.**  
**Reference No.: DGBPS/TECH/IMD/LP-1260(26)/RFQ-76061/GPSD-0461**  
**E-Urja RFQ No.: 76061**

Sr. No.	Description of materials with details of Specifications	HSN CODE	GST Rate With Cess If Any IN %	Quantity Required	UOM	Quantity Offered by Tenderer	Unit Ex-Works In Rs.	Packaging and Forwarding Charges per Unit in Rs.	GST per unit in Rs	Insurance Charge s per unit in Rs.	Freight Charge s per unit in Rs.	Unit End Cost Price in Rs.	Total End Cost Price in Rs.
1	ELECTROMAGNETIC WATER FLOW METER 150 MM SIZE			3	Number								
2	INTEGRAL TYPE ELECTRO MAGNETIC FLOW METER, SIZE - 100 MM			4	Set								
3	ELECTROMAGNETIC WATER FLOW METER 50 MM SIZE			6	Number								
4	COMPLETE ERECTION AND COMMISSIONING OF SUPPLIED SYSTEM.			1	Set								

Yours Faithfully,

Yours Faithfully

(Signature of the Tenderer)  
(With Company's Round Seal)

Chief Engineer. (Gen)  
GSECL, DGBPS

**Note: Technical & Price bid is required to be submitted in online only, physical submission of the bid will not be considered.**