

TECHNICAL SPECIFICATION FOR SPIRAL EARTH ELECTRODE

1.0 This specification is for Spiral/ Coil earthing for non current carrying parts of DP structures in a distribution system.

2.0 Design & Construction

2.1 The material used shall be No.8 SWG GI Wire or higher size closely wound 115 turns as per drawing SIC/MISC/001 and SIC/DL/004.

----- X -----