



NOTE:-

1. ALL DIMENSIONS ARE IN METERS.
2. THE 66KV SWITCHYARD WITH BOUNDARY 'ABCD' SHALL BE FIXED WITH RESPECT TO THE EXISTING ROAD LEVEL. THE CUTTING AND FILLING QUANTITIES SHALL BE FINALISED BASED ON RL FIXED.
3. LOCATION OF CAPACITOR BANK, LH AND AUX. TRANSFORMERS ARE INDICATIVE ONLY. HOWEVER EXACT LOCATION OF LH MAY BE FINALISED AT THE TIME OF ENGINEERING DRG APPROVAL.
4. FOR SUITABILITY OF EARTH MAT DESIGN, THE SWITCH YARD BOUNDARY 'ABCD' SHALL BE EXTENDED ACCORDINGLY.



KARNATAKA POWER TRANSMISSION CORPORATION LIMITED

LAY OUT DIAGRAM FOR THE PROPOSED 66/11KV SUB STATION
AT NARASIMHAGIRIBELLIGATTAY IN KUDLIGI TALUK, BALLARI DISTRICT

DRGNO/KPTCL/TECH/SS-66/1145-A	DATE-04.06.2025	SCALE- NTS 1 OF 4	SHEET
AE	EE	SEC/TECHD	CEE (P&C)
DRN	CHD	SUB	REC
			APPROVED

57.4

2

3

4

5

6

7

8

