



















MOUNTING HEIGHTS:		
SL NO	SCHEDULE OF FIXTURE / FITTINGS	MOUNTING HTS FROM F.F.L OF TOILET
01	WATER CLOSET	400 mm
02	HEALTH FAUCET	~450mm
03	WASH BASIN	800 mm
04	SOAP DISH	900 mm
05	PAPER HOLDER	400 mm
06	TOWEL RING	1200 mm
07	SHOWER ARM WITH ROSE	2050 mm
08	WASHING MACHINE TAP POINT	750 mm
09	TOWEL RAIL	1800 mm
10	SPOUT FOR DIVERTOR	800 mm
11	AQUAGUARD POINT	1650 mm
12	HEALTH FAUCET FOR WC	450 mm
13	BOTTLE TRAP FOR WASH BASIN	450 mm
14	KITCHEN SINK	800/900mm

<b>NOTES:</b>
CONTROL VALVE TO BE PROVIDED AT ALL ENTRY POINTS OF WATER SUPPLY LINE.
EWQ OUTLET - 1.100 TYPE 'B'
FT OUTLET - 750 TYPE 'B'
WB OUTLET - 400 6Kg/5q.Cm PRESSURE PIPE
KS OUTLET - 500 6Kg/5q.Cm PRESSURE PIPE
WATER SUPPLY LINE TO BE TESTED
FOR 7.5Kg/5q.Cm PRESSURE BEFORE LEAVING THE CHASES; AFTER CHECKING FOR WATER TIGHTNESS, CHASES FILL TO BE DONE.
DRAINAGE LINES TO TEST FOR 1 M WATER HEAD
TYPE 'B' FOR SOIL & WASTE LINE.
TYPE 'X' FOR RAIN WATER PIPES.
M5 ANGLE SUPPORTS TO BE PROVIDED AT EVERY 1.5M CM IN SHAFTS / ON TERRACE.
ALL SUSPENDED FLOOR / P TRAPS TO BE SUPPORTED ON BRACKETS.

- |   |   |
|---|---|
| 1 | CONCEALED WATER SUPPLY LINES IN WALLS SHALL BE LAID AT 450mm ABOVE FFL  |
| 2 | CONCEALED HOT WATER SUPPLY LINES SHALL BE LAID AT 500mm   |
| 3 | HOTWATER LINE TO BE CONNECTED TO LEFTHAND SIDE OF SHOWER.   |
| 4 | ALL INTERNAL PIPE DIA ARE 20mm CPVC-SDR11   |
| 5 | SHOWER MIXER TO SHOWER ROSE 200   |
| 6 | GEYSER LOCATION ABOVE FALSE CEILING SHALL BE AS PER SITE CONDITION ELECTRICAL POINT FOR THE SAME NEEDS TO BE CO-ORDINATED   |
| 7 | MINIMUM AREA REQUIRED FOR SHOWER WASHBASIN*WC SHALL BE MARKED ANY RESIDUE IN DIMENSION SHALL BE UNIFORMLY ADJUSTED  |
| 8 | CORE CUTTING IN SLAB ADJACENT TO ANY STRUCTURAL MEMBER SHALL BE DONE ONLY AFTER OBTAINING APPROVAL FROM THE RESPECTIVE CONSULTANT THE MARKING SHALL BE DONE INCLUDING THE MINIMUM WORKING SPACE |

LEGEND	
	WC WATER CLOSET (WALL / FLOOR MOUNTED WITH FLUSH TANK)
	SINK STAINLESS STEEL SINK
	WB RECTANGULAR WASH BASIN
	FT FLOOR TRAP (1100X750 OUTLET)
	BV BALL VALVE
	IC INSPECTION CHAMBER
	SP SOIL PIPE 1100 PVC
	WP WASTE PIPE 750 PVC
	SH SHOWER
	HF TAP / HEALTH FAUCET FOR WC GEYSER
	SP 1100 PVC SOIL PIPE
	WP 400 PVC WASTE PIPE
	WP 750 PVC WASTE PIPE
	CWS CWS PIPE (FRM)
	FWS FLUSHING WATER SUPPLY PIPE (GRAVITY)
	CWS CWS PIPE (GRAVITY)
	HWS HOT WATER SUPPLY PIPE
	IG INSTANT GEYSER

PRINCIPAL ARCHITECTS:



**PHE CONSULTANTS :**

JR IFRAA CONSULTANT  
MAHALAKSHMI LAYOUT  
BANGALORE

TENDER SANCTION DRAWING

DRAWING TITLE :

TERRACE WATER SUPPLY  
RINGMAIN LAYOUT

FILE NAME :		SCALE
DESIGNED BY : HK	NTS	
CHECKED BY : GH		
DEALT BY : HK		
JOB NO :	DRG NO: PHE 04	REV NO