



### NOTES:

1. ALL DIMENSIONS ARE IN MMS ONLY, UNLESS OTHERWISE SPECIFIED.
2. DONOT SCALEOUT THIS DRG, FOLLOW ONLY THE WRITTEN DIMENSIONS.
3. C/C DISTANCE BETWEEN ADJACENT POST IN END PANEL MAY BE SUITABLY ADJUSTED IN EACH STRAIGHT LENGTH.
4. INCLINED STAY POST SHALL BE PROVIDED AT EVERY CORNER/TENTH POST/ CHANGE IN LEVELS/DIRECTION.
5. ALL STRUCTURAL STEEL FLAT & ANGLE SHALL BE PAINTED WITH SYNTHETIC ENAMEL PAINT 2 COATS OVER ONE COAT OF PRIMER.
6. THE EXPOSED FACES OF SIZE STONE MASONRY SHALL BE POINTED IN CM 1:3.
7. GRADE OF CONCRETE SHALL BE M20 FOR POLES.
8. GRADE OF STEEL SHALL BE Fe 415

KARNATAKA POWER TRANSMISSION CORPN LTD				
RCC STATION SECURITY FENCING DETAILS FOR 220 - 110 & 66KV SUBSTATIONS				SHEET 1 OF 2
DRG NO: CEE (P & C) / SE(C)/06-07/220-110/005				NOT TO SCALE REV (1)
AEE(C)		SE(C)	CHIEF ENGR ELE	
DGN	SUB	REC	P & C	
APPROVED			PLANNING AND CO-ORDINATION	