

**FEROZPUR DIVISION-ELECTRICAL/NORTHERN RLY
TENDER DOCUMENT**

Tender No: 251-Elect-T-02-2026-27

Closing Date/Time: 03/07/2026 15:00

Sr.DEE/G acting for and on behalf of The President of India invites E-Tenders against Tender No **251-Elect-T-02-2026-27** Closing Date/Time 03/07/2026 15:00 Hrs. Bidders will be able to submit their original/revised bids upto closing date and time only. Manual offers are not allowed against this tender, and any such manual offer received shall be ignored.

1. NIT HEADER

Name of Work	Electrical work in c/w Augmentation of Service building for SSE(C&W) office in lieu of old building for C&W Coaching Depot, FZR, Electrical work in c/w General Watering Arrangements at FKA, MOGA & LNK of Ferozpur Division, Electrical work in c/w Provision of 15 bedded male barrack at Attari and Electrical work in c/w Improvement to washing line no. 4 and Sick line / Ac pit at Amritsar Railway Station in the section of ADEN-I/ASR.		
Bidding type	Normal Tender		
Tender Type	Open	Bidding System	Single Packet System
Tender Closing Date Time	03/07/2026 15:00	Date Time Of Uploading Tender	12/06/2026 11:09
Pre-Bid Conference Required	No	Pre-Bid Conference Date Time	Not Applicable
Advertised Value	7673907.22	Tendering Section	POWER
Bidding Style	Single Rate for Each Schedule Item	Bidding Unit	
Earnest Money (Rs.)	153500.00	Validity of Offer (Days)	60
Tender Doc. Cost (Rs.)	0.00	Period of Completion	6 Months
Contract Type	Works - General	Contract Category	Expenditure
Bidding Start Date	19/06/2026		
Are JV allowed to bid	No	Number of JV Member Allowed	0
Are Consortium allowed to bid	No	Number of Consortium Member Allowed	0
Ranking Order For Bids	Lowest to Highest	Expenditure Type	Capital (Works)

2. SCHEDULE

S.No.	Item Code	Item Qty	Qty Unit	Unit Rate	Basic Value	Escl.(%)	Amount	Bidding Unit
Schedule () A-Electrical work in c/w Augmentation of Service building for SSE(C&W) office in lieu of old building for C&W Coaching Depot, FZR, Electrical work in c/w General Watering Arrangements at FKA, MOGA & LNK of Ferozpur Division, Electrical work in c/w Provision of 15 bedded male barrack at Attari and Electrical work in c/w Improvement to washing line no. 4 and Sick line / Ac pit at Amritsar Railway Station in the section of ADEN-I/ASR. Note: - The Unit prices are INCLUSIVE OF GST and all other charges and taxes applicable. Bidder shall quote prices Inclusive of GST and Bidder shall be responsible for deposition of applicable GST to Concerned Authority.								7673907.22
1	1	40.00	Numbers	369.81	14792.40	AT Par	14792.40	Rs.
	Description:- Supply and Erection of modular metal boxes concealed boards with white finish single mounting plate and fixing of switches/plug socket and connection wiring. Make Legrand (Myrius), Schneider (Zencelo), Anchor (Ave) or similar. Metal boxes boards are to be concealed in the wall for 12 Module							
2	2	75.00	Numbers	335.60	25170.00	AT Par	25170.00	Rs.
	Description:- Supply and Erection of modular metal boxes concealed boards with white finish single mounting plate and fixing of switches/plug socket and connection wiring. Make Legrand (Myrius), Schneider (Zencelo), Anchor (Ave) or similar Metal boxes boards are to be concealed in the wall for 8 Module							
3	3	100.00	Numbers	156.00	15600.00	AT Par	15600.00	Rs.
	Description:- Supply and Erection of modular metal boxes concealed boards with white finish single mounting plate and fixing of switches/plug socket and connection wiring. Make Legrand (Myrius), Schneider (Zencelo), Anchor (Ave) or similar Metal boxes boards are to be concealed in the wall for 4 Module							
4	4	50.00	Numbers	170.77	8538.50	AT Par	8538.50	Rs.

**FEROZPUR DIVISION-ELECTRICAL/NORTHERN RLY
TENDER DOCUMENT**

Tender No: 251-Elect-T-02-2026-27

Closing Date/Time: 03/07/2026 15:00

		Description:- Supply and Erection of modular metal boxes concealed boards with white finish single mounting plate and fixing of switches/plug socket and connection wiring. Make Legrand (Myrius), Schneider (Zencelo), Anchor (Ave) or similar Metal boxes boards are to be concealed in the wall for 3 Module						
5	5	1070.00	Numbers	151.62	162233.40	AT Par	162233.40	Rs.
		Description:- Supply, fixing, testing, and commissioning of modular type switch 6/10 Amps as per tech. specification IS/IE rules and site requirement.						
6	6	120.00	Numbers	182.00	21840.00	AT Par	21840.00	Rs.
		Description:- Supply, fixing, testing, and commissioning of modular type switch 16 Amps as per tech. specification IS/IE rules and site requirement.						
7	7	120.00	Numbers	252.30	30276.00	AT Par	30276.00	Rs.
		Description:- Supply, fixing, testing, and commissioning of modular type 6 pin socket 6/15 Amps as per tech. specification IS/IE rules and site requirement.						
8	8	125.00	Numbers	137.10	17137.50	AT Par	17137.50	Rs.
		Description:- Supply, fixing, testing, and commissioning of modular type multi socket 6 Amps 5 pin as per tech. specification IS/IE rules and site requirement.						
9	9	15000.00	Metre	12.13	181950.00	AT Par	181950.00	Rs.
		Description:- Supplying, laying, testing and commissioning of FRLS 1.0 sq mm PVC insulated multistranded copper conductor s/core cable 1100 Volt conforming to IS-694 (latest version), ISI marked, make Finolex, Havells, Polycab, KEI in the recessed PVC conduit pipe 25 mm dia as required at site.						
10	10	12300.00	Metre	14.15	174045.00	AT Par	174045.00	Rs.
		Description:- Wiring for light points with supply and laying of FRLS PVC insulated multistranded copper conductor cable 1100 Volt 1.5 Sq.mm multi stranded confirming to IS-694 latest, ISI marked in the existing PVC pipe.						
11	11	6600.00	Metre	18.10	119460.00	AT Par	119460.00	Rs.
		Description:- Supply, laying, fixing, testing and commissioning of 2.5sq mm FRLS, PVC insulated multistranded copper conductor single core cable 1100 Volts confirming to IS-694(latest version), ISI marked, make Finolex, Havells, Polycab, KEI or equivalent in the existing PVC conduit for wiring of point wiring/circuit wiring/sub main/main as per Tech Spec-I attached, IS & IE rules.						
12	12	4500.00	Metre	26.09	117405.00	AT Par	117405.00	Rs.
		Description:- Supply, laying, fixing,testing and commissioning of 4 sq mm FRLS, PVC insulated multistranded copper conductor single core cable 1100 Volts confirming to IS-694(latest version), ISI marked, make Finolex, Havells, Polycab, KEI or equivalent in the existing PVC conduit for wiring of point wiring/circuit wiring/sub main/main as per Tech Spec-I attached, IS & IE rules.						
13	13	2500.00	Metre	36.95	92375.00	AT Par	92375.00	Rs.
		Description:- Supply and recessing/fixing of 25mm (Medium) PVC conduit pipe conforming to IS 9537/Pt.III/1983 or Latest Version, ISI marked with accessories, junction box, etc including making chase, plastering/clamping etc as per technical specifications.						
14	14	420.00	Numbers	543.20	228144.00	AT Par	228144.00	Rs.
		Description:- "Supply, fixing, testing and commissioning of LED light luminaries, having system wattage 1x 18w (Max.), LED tube and inbuilt LED driver, CRCA body powder coated, complete with all mounting arrangement, accessories. The LED based 4 ft. tube light (lamp) shall be of make Phillips, Bajaj,Havells or similar conforming to CEE/NR's spec. No. CEE/NR/121- Elect/PS/2018 (Rev- '3'), & PCEE/NR's spec. No. PCEE/NR/121- Elect/PS/2019 (Rev- '4') or latest"						
15	15	90.00	Numbers	2774.74	249726.60	AT Par	249726.60	Rs.
		Description:- Supply, fixing, installation, testing and commissioning of energy efficient 230V,50 Hz AC ceiling fan size of 1200 mm sweep having wattage of 28 W, range of voltage operation at various speed-120 to 260 V AC with 5 step speed control electronic regulator, copper winding complete as per IS : 374-1979 or latest IE rule & site requirement. Make Bajaj, Usha, Havells, Crompton, Orient or equivalent.						
16	16	490.00	Numbers	12.77	6257.30	AT Par	6257.30	Rs.
		Description:- Supply, fixing,testing and commissioning of 3-pin ceiling rose 5 Amp capacity on existing MS/PVC conduit junction boxes/casing caping Anchor, Cona, Kinjal, SSK or equivalent as per IS, IE rules and site requirement.						
17	17	25.00	Numbers	3002.49	75062.25	AT Par	75062.25	Rs.
		Description:- Supply, fixing, testing and commissioning of 380mm sweep, 1400 rpm (approx) propeller type exhaust fan complete as per IS, IE rule & site requirement. Make Usha, Orient, Bajaj or equivalent						
18	18	5.00	Numbers	3570.08	17850.40	AT Par	17850.40	Rs.
		Description:- Supply, erection, testing and commissioning of the following Double door wall mounted Pre-fabricated L.T. Distribution Boards of approved make, as per explanatory note & comprising; (i) Incoming MCB 40 A DP 10 KA B/C - 1 No. (ii) Outgoing MCB 16 A. SP 10 KA B/C - 6 Nos.						

**FEROZPUR DIVISION-ELECTRICAL/NORTHERN RLY
TENDER DOCUMENT**

Tender No: 251-Elect-T-02-2026-27

Closing Date/Time: 03/07/2026 15:00

19	19	10.00	Numbers	2024.27	20242.70	AT Par	20242.70	Rs.
	Description:- Supplying and fixing following rating,double pole, (single phase and neutral),240 volts, 40 Amp RCCB having a sensitivity 30ma in the existing MCB DB complete with connections, testing and commissioning etc. as required., 40 amps.							
20	20	6.00	Numbers	13883.13	83298.78	AT Par	83298.78	Rs.
	Description:- Supply, erection, testing and commissioning of the following Double door wall mounted Pre-fabricated L.T. Distribution Boards of approved make, as per explanatory note & comprising; (i) Incoming MCCB 4Pole 63 A 35 KA B/C - 1 No. (ii). Outgoing MCB 6 to 32 A. SP 10 KA B/C (4 Nos. On each Phase) - 12 Nos.							
21	21	2.00	Numbers	166309.44	332618.88	AT Par	332618.88	Rs.
	Description:- Supply, installation and commissioning of Online 2x5 KVA single phase based with isolator, datalogger, transformer online UPS system with SMF/VRLA type battery for an autonomy of 120 Minutes(70AHx15 Nosx12V) as per site requirement (Including battery trolley of iron made)							
22	22	5700.00	Metre	60.14	342798.00	AT Par	342798.00	Rs.
	Description:- Transportation, Laying, underground/road/Railway track, recessing in platform /wall along with Rly. Track/in laid RCC/GI pipe as required 1.1 KV grade LT XLPE insulated armoured, aluminium conductor cable including making chase & plastering after laying of cable/digging of cable trench, sand cushioning, protective covering with second class bricks, provision of cable route marker as per Tech. Specification including end terminations with Aluminium Clamping socket/lugs, testing and commissioning of Above 25 sq.mm							
23	23	3000.00	Metre	59.88	179640.00	AT Par	179640.00	Rs.
	Description:- Transportation, Laying, underground/road/Railway track, recessing in platform /wall along with Rly. Track/in laid RCC/GI pipe as required 1.1 KV grade LT XLPE insulated armoured, aluminium conductor cable including making chase & plastering after laying of cable/digging of cable trench, sand cushioning, protective covering with second class bricks, provision of cable route marker as per Tech. Specification including end terminations with Aluminium Clamping socket/lugs, testing and commissioning of upto 25 sq.mm							
24	24	31.00	Numbers	3807.07	118019.17	AT Par	118019.17	Rs.
	Description:- Design, manufacturing of floor mounted MS feeder post made of MS sheet 16 SWG Die pressed of size 550mm x 450mm x 275mm deep complete with Aluminium bus bars four Nos. having cable glands 2 Nos. duly grouted with cement concrete ratio 1:2:4 duly earthed with earthing terminals.							
25	25	127.00	Numbers	2298.42	291899.34	AT Par	291899.34	Rs.
	Description:- Earthing arrangement by providing earth electrode of GI pipe 50 mm dia (B class) 4.5 meter long with flange including 6 SWG GI earth wire from earth pipe to connecting point on switch board to distribution board/pole etc. as per site requirement including masonry enclosure as per Tech specification at annexure 'A' relevant ISS & IE rules and site requirements. A suitable CI/MS/RCC cover as approved by Rly . Representative, cover with locking arrangement shall be provided.							
26	26	2375.00	Metre	9.21	21873.75	AT Par	21873.75	Rs.
	Description:- Supply & recessing/fixing on surface 6 SWG GI wire for loop earthing as required as mentioned in explanatory note.							
27	27	40.00	Numbers	13134.52	525380.80	AT Par	525380.80	Rs.
	Description:- Supply, installation, testing and commissioning of 150 Watt LED based flood light fitting, operating voltage single phase 230V AC, 50Hz complete with led lamp & all mounting arrangement, accessories & flexible copper wire for connection as per ISS/IR rules & as per CEE/NR Specification No. CEE/NR/121-Elect/PS/2018 (Rev.03) dated 28.06.2018 & CEE/NR/121-Elect/PS /2019 (Rev.4) dated 04.11.2019 respectively or latest							
28	28	6.00	Numbers	44864.39	269186.34	AT Par	269186.34	Rs.
	Description:- Supply & testing : Submersible pump set ISI marked 500 LPM, 90 Mtr head with maxim OD 142 mm submersible cable size length 3 mtr 2900 RPM with coupled motor of capacity 15 HP suitable for operation on 415 Volt +/- 5%, 3 phase, 50Hz conforming to IS 8034-2002 or latest and also having impeller & bush of Brass on metal alloy as per attached technical specification. Make-KSB, Amrut & Sabur or similar. Make.							
29	29	3.00	Numbers	5438.65	16315.95	AT Par	16315.95	Rs.
	Description:- "Lowering of submersible pumps (3 phase) from existing bore upto depth of 300 feet."							
30	30	300.00	Metre	525.64	157692.00	AT Par	157692.00	Rs.
	Description:- Supply and fixing of GI pipe B Class 3 inch dia with MS flanges holding, locking system for safety and checking dropping down of submersible pump upto non return valve and connection with sluice valve to be matched with delivery pipe at ground level.							
31	31	6.00	Numbers	15652.89	93917.34	AT Par	93917.34	Rs.

**FEROZPUR DIVISION-ELECTRICAL/NORTHERN RLY
TENDER DOCUMENT**

Tender No: 251-Elect-T-02-2026-27

Closing Date/Time: 03/07/2026 15:00

	Description:- Supply,fixing,testing and Commossioning of 20 HP fully automatic star-delta starter for submersible pump with overload current range 20-32amp, with single phase protection, Dry run, over voltage , under voltage and phase reversal with all accessories and as per site requirement..							
32	32	3.00	Numbers	5921.27	17763.81	AT Par	17763.81	Rs.
	Description:- Supply, fixing, testing and commissioning Sluice Valve 3 inch dia and Non return Valve 3 inch dia and CI bends complete with connection etc. of make Standard, BEER, or similar conforming to latest version of relevant IS CODE.							
33	33	100.00	Metre	1727.90	172790.00	AT Par	172790.00	Rs.
	Description:- Laying of cable underground through 160mm dia HDPE pipe by MicroTunneling cable laying method including supply and jointing of HDPE pipe.							
34	34	35.00	Numbers	3484.25	121948.75	AT Par	121948.75	Rs.
	Description:- Supply and erection of minimum 45 W LED Street light fitting operating voltage single phase 230 volts AC, 50Hz complete with all accessories as per CEE/NR Specification. No.CEE/NR/121-Elect/PS/2018 (Rev '3') Dated 28.06.2018 & CCE/NR/121-Elect/PS /2019 (Rev.4) dated 04.11.2019 or latest respectively including connection with 2x2.5 sq.mm PVC insulated multi stranded FRLS copper conductor cable, testing, commissioning & earthing required and as per explanatory note.							
35	35	24.00	Numbers	462.68	11104.32	AT Par	11104.32	Rs.
	Description:- Supply and fixing of bracket on pillar or as required made out of GI pipe 1 M 40mm dia class B GI pipewith ISI marked of approved make & shape suitable bracket shall be fixed with double clamp made of 40x5 mm GI clamp & suitable GI nut bolt & washer & as per explanatory note							
36	36	15.00	Numbers	6486.58	97298.70	AT Par	97298.70	Rs.
	Description:- Price shall cover Supply, installation, testing and commissioning of Plastic Body Desert Cooler having: •Powerful Air Flow:1750 Cubic Meter/Hr(Peak) 1200 Cubic Meter/Hr (Average) • Auto Water Level Controller •Humidity Control Valve •Water Tank Capacity: 32 Litres							
37	37	1.00	Numbers	52010.11	52010.11	AT Par	52010.11	Rs.
	Description:- S.I.T.C of contained drinking water cooler capacity 150 LTR with Non CFC refrigerant) energy efficient compressor cooling capacity LTR/HR150, storage type,confirming to IS-1475-1PART 1, of 2001 or latest make blue star, voltas or similar.							
38	38	4.00	Numbers	8051.47	32205.88	AT Par	32205.88	Rs.
	Description:- SITC of 35 Ltrs. water heater geyser BEE 5 star rating 2KW glass coated heating element, CFC free high density PUF insulation, inner tank extreme hard water resistance, suitable for high rise building & pressure pump, suitable for 230V 50Hz AC supply.							
39	39	5.00	Numbers	583.26	2916.30	AT Par	2916.30	Rs.
	Description:- Supply, fixing, testingand commissioning of surface mounted /flush type 25 Amp power unit complete with modular plate, MCB, starter, plug &socket for AC of make Wipro North West (Model -ACPU6MBT/ ACPU6M-FT) or equivalent as per IS & IE rules.							
40	40	1.00	Numbers	117557.67	117557.67	AT Par	117557.67	Rs.
	Description:- Design, manufacturing, supply erection testing &commissioning of outdoor type feeder pillar type panel LT distribution system suitable for 3phase 4 wire 415 V AC supply comprising : i) I/CMCCB 4P 125A with adjustable thermal mangnetic release & 35AKA B/C-1No. ii) Out going MCCB 4P 63 A with 35 KAB/C -2 Nos iii)Out going MCCB 32A 4P with 5KAB/C-6Nos. The feeder pillar shall be complete with copper bus bars 150Amps. for phases and 75Ampsfor neutral as per drawing approved by railways and explanatory Notes.							
41	41	1.00	Numbers	180134.15	180134.15	AT Par	180134.15	Rs.
	Description:- Supply, Erection, Fixing, Testing and commissing of LT panel having incoming 1x250 Amp MCCB 35kA FP with outgoing of 2x125 Amp MCCB 35 kA FP, 1x63 Amp MCCB 35 kA FP and 4x32 Amp 35 KA FP MCCB with Amp meter, volt meter and indicator. Make of MCCB &MCB M/s Legrand, Havells, Schenider							
42	42	16.00	Numbers	17141.55	274264.80	AT Par	274264.80	Rs.
	Description:- Design, manufacturing, supply, erection & commissioning of weather proof, floor mounted, dust & vermin proof as per IS:8623/1993 Pt-I to Pt-III (Latest version) as per Drg No.CEE/NR/Elect/AC/311 outdoor type 415 Volt pre-cooling cum battery charging box as per explanatory note as under: - a) Pre-cooling point portion of the box complete with 200 A Aluminium bus bar for phases & 160 A for neutral MCCB 100 Amp TPN = 1 No., 415 Volt, 63 A, 5 pin socket for operation on 3 phase 415 Volt AC system b) Battery charging point portion of the box complete with Aluminium bus bar 200 Amp, DP MCB 32 A DC = 1 No., 110 Volt 32 A 3 pin socket = 1 No. for operation on 110 DC system.							
43	43	100.00	Numbers	2861.18	286118.00	AT Par	286118.00	Rs.
	Description:- Design Supply, fixing and commissioning of the LED based pit light fitting 18 watt,input voltage 48 V AC as per PCEE Spec. CEE/NR/121 Elect/PS/2018(Rev-03) dt 28/06/18 & CEE/NR/121-Elect/PS/2019(Rev-04) dt 04.11.2019 with correction dt.10.02.2020 or latest , Size of light fitting & fixture should be approved by railway before installation and fixing & grouting work should be done as per site requirement.Gaurantee-05 years from date of commissioning.							

**FEROZPUR DIVISION-ELECTRICAL/NORTHERN RLY
TENDER DOCUMENT**

Tender No: 251-Elect-T-02-2026-27

Closing Date/Time: 03/07/2026 15:00

44	44	200.00	Numbers	2240.71	448142.00	AT Par	448142.00	Rs.
	Description:- Supply, fixing and commissioning of the bulkhead LED based aluminium die cast with power coating grill fitted below cat walk light fitting 22 watt,input voltage 48 V AC as per PCEE Spec. CEE/NR/121- Elect/PS/2018(Rev-03) dt 28/06/18 & CEE/NR/121-Elect/PS/2019(Rev-04) dt 04.11.2019 with correction dt.10.02.2020 or latest , Size of light fitting & fixture should be approved by railway before installation and fixing & grouting work should be done as per site requirement..Gaurantee-05 years from date of commissioning.							
45	45	1.00	Numbers	165032.65	165032.65	AT Par	165032.65	Rs.
	Description:- Design Supply, installation ,testing and commissioning of step down Transformer outdoor 20 KVA with control panel Specifications for transformer Input voltage Range 440 V AC, Output Voltage- 48V AC +/- 5% V,Minimum 4 output terminals, Type cooling-oil cooled, Control card Easy maintenance & service ability, Efficiency more than 95% ,Winding copper Core mitered CRGO notching core material, display -Digital ,Temp rise 45° C above ambient, Frequency 50 Hz ,Protections Low/High voltage , Control panel- size & capacity of control panel should be as per transformer capacity 20 kva & connected load at transformer.Control panel should have 3 phase incoming & required capacity outgoing feeders, Transformer & control panel should be approved by railway before installation as per site requirement.							
46	46	10.00	Numbers	2169.35	21693.50	AT Par	21693.50	Rs.
	Description:- Fabrication, supply, erection, testing and commissioning of welding points suitable for 400 Volt AC supply system in the enclosure made of MS sheet 16 SWG die pressed with powder coated with light grey colour comprising of 2 Nos. cable glands suitable for 2x185 Sq.mm 2 core LT XLPE armoured cable aluminium bus bar of 400 Amps rating, 2 Nos. porcelain shackle insulator fitted on backelite sheet 325x40x12 mm thick interconnection with suitable capacity cable and suitable arrangement for taping connection for welding cables terminals etc. and provision of holes in the busbar for looping 2 Nos. 185 sq.mm 2 core cable as required at site including earthing.							
47	47	1500.00	Metre	62.91	94365.00	AT Par	94365.00	Rs.
	Description:- supplying and recessing/ fixing of 40 mm dia medium regid PVC conduit pipe conforming to IS9537 part- III / 1983 (latest version) with accessories, junction box, bend including making chase, plastering / clamping as approved by railway and as per explanatory notes							
48	48	450.00	Numbers	343.04	154368.00	AT Par	154368.00	Rs.
	Description:- Provision of iron junction box with copper connectors for fixing/looping of wires including finolex sheet at concrete wall.							
49	49	2.00	Numbers	49560.00	99120.00	AT Par	99120.00	Rs.
	Description:- SUPPLY, INSTALLATION,TESTING AND COMMISSIONING, OF DISTILLED WATER PLANT DOUBLE STAG DISTILLATION UNIT WITH DISTILLATION WATER CAPACITY 25 LPH,WITH STAINLESS STEELBODY,230 VOLTS 50 HZ,SINGLE PHASE,PH VALUE:6.9-7.5, TDS 0-5 PPM ,DUTY CYCLE 125 LTR/DAY,WATER PRESSURE 1.5 KG/SQCM WITH 02 NOS FILTER CARTRIDGE ,ELECTRICAL RESISTIVITY MIN 1M OHM-CM.CARBON CONDUCTIVITY MAX 1us/cm .							
50	50	500.00	Metre	2198.46	1099230.00	AT Par	1099230.00	Rs.
	Description:- Supply and fixing(as per site requirment) of MS powder coated perforated cable tray made out of 2 mm thick CRCA sheet of size 300x100x100 mm with cover 2 mm thick.							
51	51	10.00	Numbers	8450.37	84503.70	AT Par	84503.70	Rs.
	Description:- Supply, fixing, testing and commissioning of Air Circulator fans wall mounting 600 mm 24inches make Bajaj, Khaitan, Crompton 230 Volt, 50 Hz AC supply.							
52	52	1.00	Numbers	130593.48	130593.48	AT Par	130593.48	Rs.
	Description:- Supply, erection, testing and commissioning of Silicon Rectifier battery charging set confirming to relevant IS : (Latest Version) suitable for operation on 415 Volt 3 phase 4 wire AC supply system with 125 volts to 150 volts DC output, 200 Amps, capacity.							

3. ITEM BREAKUP

No item break up added	
------------------------	--

4. ELIGIBILITY CONDITIONS

Standard Financial Criteria

S.No.	Description	Confirmation Required	Remarks Allowed	Documents Uploading
-------	-------------	-----------------------	-----------------	---------------------

**FEROZPUR DIVISION-ELECTRICAL/NORTHERN RLY
TENDER DOCUMENT**

Tender No: 251-Elect-T-02-2026-27

Closing Date/Time: 03/07/2026 15:00

1	Only those firms which in their individual capacity, satisfy Standard Financial Criteria(s) need to quote for this tender. :The tenderer must have minimum average annual contractual turnover of V/N or 'V' whichever is less; where V= Advertised value of the tender in crores of Rupees N= Number of years prescribed for completion of work for which bids have been invited. The average annual contractual turnover shall be calculated as an average of "total contractual payments" in the previous three financial years, as per the audited balance sheet. However, in case balance sheet of the previous year is yet to be prepared/ audited, the audited balance sheet of the fourth previous year shall be considered for calculating average annual contractual turnover. The tenderers shall submit requisite information as per Annexure-15, along with copies of Audited Balance Sheets duly certified by the Chartered Accountant/ Certificate from Chartered Accountant duly supported by Audited Balance Sheet. The tenderers shall submit Certificates to this effect which may be an attested Certificate from the concerned department / client and/or Audited Balance Sheet duly certified by the Chartered Accountant etc.	No	No	Allowed (Mandatory)
---	--	----	----	------------------------

Standard Technical Criteria

S.No.	Description	Confirmation Required	Remarks Allowed	Documents Uploading
1	The tenderer should have a valid Electrical Contractor License from the concerned statutory authority. The above said Electrical Contractor License is to be submitted along with the offer otherwise the offer shall be summarily rejected.	No	No	Allowed (Mandatory)
1.1	Defination of Similar Work :- Design, Supply, Installation, Testing & Commissioning of HT/LT network Like HT/LT panel, Overhead distribution network, earthing, laying of HT/LT cable etc. and associated electrical works.	No	No	Not Allowed
1.2	As a proof of Technical Eligibility, the Tenderer(s) have to submit details (Technical Eligibility) as per Annexure-13 Tender Document, indicating that Contractor have completed any of the following during last 07 (seven) years, ending last day of month previous to the one in which tender is invited: Three similar works costing not less than the amount equal to 30% of advertised value of the tender, or Two similar works costing not less than the amount equal to 40% of advertised value of the tender, or One similar work costing not less than the amount equal to 60% of advertised value of the tender. Format of completion certificate to be produced is provided as annexure-18 of tender docuemnts. Work experience certificate from private individual shall not be considered. However, in addition to work experience certificate issued by any Govt. Organization, work experience certificate issue by Public listed company having average annual turnover of Rs. 500 crore and above in last 3 financial years excluding the current financial year, listed on National Stock Exchange or Bombay Stock Exchange, incorporated /registered at least 5 years prior to the date of opening of tender, shall also be considered provided the work experience certificate has been issued by a person authorized by the Public listed company to issue such certificates. In case tenderer submits work experience certificate issued by public listed company, the tenderer shall also submit along with work experience certificate, the relevant copy of work order, bill of quantities, bill wise details of payment received duly certified by Chartered Accountant, TDS certificates for all payments received and copy of final/last bill paid by company in support of above work experience certificate.	No	No	Allowed (Mandatory)

Bidders shall confirm and certify on the behalf of the tenderer including its constituents as under:

S.No.	Description
1	I/we the tenderer (s) am/are signing this document after carefully reading the contents.
2	I/We the tenderer(s) also accept all the conditions of the tender and have signed all the pages in confirmation thereof.
3	I/we hereby declare that I/we have downloaded the tender documents from Indian Railway website www.ireps.gov.in . I/we have verified the content of the document from the website and there is no addition, no deletion or no alteration to the content of the tender document. In case of any discrepancy noticed at any stage i.e. evaluation of tenders, execution of work or final payment of the contract, the master copy available with the railway Administration shall be final and binding upon me/us.

**FEROZPUR DIVISION-ELECTRICAL/NORTHERN RLY
TENDER DOCUMENT**

Tender No: 251-Elect-T-02-2026-27

Closing Date/Time: 03/07/2026 15:00

4	I/we declare and certify that I/we have not made any misleading or false representation in the forms, statements and attachments in proof of the qualification requirements.
5	I/We also understand that my/our offer will be evaluated based on the documents/credentials submitted along with the offer and same shall be binding upon me/us.
6	I/We declare that the information and documents submitted along with the tender by me/us are correct and I/we are fully responsible for the correctness of the information and documents, submitted by us.
7	I/we certify that I/we the tenderer(s) is/are not blacklisted or debarred by Railways or any other Ministry / Department of Govt. of India from participation in tender on the date of submission of bids, either in individual capacity or as a HUF/ member of the partnership firm/LLP/JV/Society/Trust.
8	I/we understand that if the contents of the certificate submitted by us are found to be forged/false at any time during process for evaluation of tenders, it shall lead to forfeiture of the Bid Security and may also lead to any other action provided in the contract including banning of business for a period of upto two year. Further, I/we and all my/our constituents understand that my/our offer shall be summarily rejected.
9	I/we also understand that if the contents of the certificate submitted by us are found to be false/forged at any time after the award of the contract, it will lead to termination of the contract, along with forfeiture of Bid Security/Security Deposit and Performance guarantee and may also lead to any other action provided in the contract including banning of business for a period of upto two year.
10	I/We have read the clause regarding restriction on procurement from a bidder of a country which shares a land border with India and certify that I am/We are not from such a country or, if from such a country, have been registered with the competent Authority. I/We hereby certify that I/we fulfil all the requirements in this regard and am/are eligible to be considered (evidence of valid registration by the competent authority is enclosed)

Partnership firm/Joint Venture (JV) / Hindu Undivided Family (HUF) / Limited Liability Partnership (LLP) etc.

S.No.	Description
1	Partnership firm/Joint Venture (JV) / Hindu Undivided Family (HUF) / Limited Liability Partnership (LLP) etc. Please submit a certificate in the prescribed format (please download the format from the link given below). Non submission of the certificate, or submission of certificate either not properly filled in, or in a format other than the prescribed format shall lead to summary rejection of your offer. (Click here to download the Format of Self Certification)

5. COMPLIANCE

Commercial-Compliance

S.No.	Description	Confirmation Required	Remarks Allowed	Documents Uploading
1	GSTIN number: Bidder shall submit attested or self attested copy of GSTIN certificate.	No	No	Allowed (Mandatory)

**FEROZPUR DIVISION-ELECTRICAL/NORTHERN RLY
TENDER DOCUMENT**

Tender No: 251-Elect-T-02-2026-27

Closing Date/Time: 03/07/2026 15:00

2	<p>Following documents shall be submitted by the tenderer: (A)SOLE PROPRIETOR SHIP FIRM: (i)All other documents in terms of clause 1.1.12 of tender document . (B)HUF: (i) A copy of notarized affidavit on Stamp Paper declaring that he who is submitting the tender on behalf of HUF is in the position of 'Karta' of Hindu Undivided Family (HUF) and he has the authority, power and consent given by other members to act on behalf of HUF. (ii)All other documents in terms of clause 1.1.12 of tender document. (C)PARTNERSHIP FIRM:(i)A notarised copy of the Partnership Deed or a copy of the Partnership deed registered with the Registrar. (ii)A notarised or registered copy of Power of Attorney in favour of the individual to tender for the work, sign the agreement etc. and create liability against the firm.(iii)An undertaking by all partners of the partnership firm that they are not blacklisted or debarred by Railways or any other Ministry / Department of the Govt. of India from participation in tenders / contracts as on the date of submission of bids, either in their individual capacity or in any firm/LLP in which they were / are partners/members. Any Concealment / wrong information in regard to above shall make the bid ineligible or the contract shall be determined under Clause 62 of the Standard General Conditions of Contract.(iv)All other documents in terms of clause 1.1.12 of tender document . (D)JOINT VENTURE (JV): APPLICABLE ONLY FOR WORKS COSTING MORE THAN Rs.10.00 Cr. Not applicable for this tender. (E)Company registered under Companies Act- 2013:(i)The copies of MOA (Memorandum of Association) / AOA (Articles of Association) of the company.(ii)A copy of Certificate of Incorporation.(iii)A copy of Authorization / Power of Attorney issued by the Company (backed by the resolution of Board of Directors) in favour of the individual to sign the tender on behalf of the company and create liability against the company.(iv)All other documents in terms of clause 1.1.12 of tender document. (F)LLP (Limited Liability Partnership) Firm under LLP Act-2008: (i)A copy of LLP Agreement.(ii)A copy of Certificate of Incorporation.(iii)A copy of Power of Attorney / Authorization issued by the LLP in favour of the individual to sign the tender on behalf of the LLP and create liability against the LLP.(iv)An undertaking by all partners of the LLP that they are not blacklisted or debarred by Railways or any other Ministry / Department of the Govt. of India from participation in tenders / contracts as on the date of submission of bids, either in their individual capacity or in any firm/LLP or JV in which they were / are partners/members. Concealment / wrong information in regard to above shall make the contract liable for determination under Clause 62 of the Standard General Conditions of Contract. (G)Registered Society & Registered Trust: The tenderer shall submit: (i)A copy of the Certificate of Registration.(ii)A copy of Memorandum of Association of Society/Trust Deed.(iii)A copy of Power of Attorney in favour of the individual to sign the tender documents and create liability against the Society/Trust.(iv)A copy of Rules & Regulations of the Society.(v)All other documents in terms of clause 1.1.12 of tender document .</p>	No	No	Allowed (Mandatory)
2.1	<p>The tenderer shall submit a copy of certificate (Annexure 19(A)) in case of other than Company/Proprietary firm by each member of a Partnership Firm / Joint Venture (JV) / Hindu Undivided Family (HUF / Limited Liability Partnership (LLP) etc, as the case may be. Non submission of above certificate(s) by the bidder shall result in summarily rejection of his/their bid. It shall be mandatory incumbent upon the tenderer to identify, state and submit the supporting documents duly self attested/digitally signed by which they/he is qualifying the Qualifying Criteria mentioned in the Tender Document. Note:- As per railway board letter No. 2022/CE-I/CT/GCC Correspondence Dated: 14.05.2024 "On IREPS Module, a facility has already been created for online submission of Annexure-V. Therefore, the provision of downloading of Annexure-V of GCC & uploading of physically signed Annexure-V by the tenderer had been discontinued on IREPS".</p>	No	No	Allowed (Mandatory)

**FEROZPUR DIVISION-ELECTRICAL/NORTHERN RLY
TENDER DOCUMENT**

Tender No: 251-Elect-T-02-2026-27

Closing Date/Time: 03/07/2026 15:00

3	Please enter the percentage of local content in the material being offered. Please enter 0 for fully imported items, and 100 for fully indigenous items. The definition and calculation of local content shall be in accordance with the Make in India policy as incorporated in the tender conditions.	No	Yes	Allowed (Optional)
4	Payment of Bid-security in respect of E- tendering will be deposited either in cash through e payment gateway or submitted as Bank Guarantee bond from a scheduled commercial bank of India or as mentioned in tender documents. The Bank Guarantee bond shall be as per Annexure-VIA of GCC Works 2022(Annexure-21 of Tender Document) and shall be valid for a period of 90 days beyond the bid validity period and any offer without the same will be treated as invalid. Details of bank account no. and technical details have been provided for in the software (IREPS) to which prospective registered tenderers will have access at the time of tendering.	No	No	Allowed (Mandatory)
4.1	In case, submission of Bid Security in the form of Bank Guarantee, following shall be ensured: (i) A scanned copy of the Bank Guarantee shall be uploaded on e-Procurement Portal (IREPS) while applying to the tender. (ii) The original Bank Guarantee should be delivered in person to the official nominated as indicated in the tender document before closing date for submission of bids (i.e. excluding the last date of submission of bids). (iii) Non submission of scanned copy of Bank Guarantee with the bid on e-tendering portal (IREPS) and/or non submission of original Bank Guarantee within the specified period shall lead to summary rejection of bid. (iv) The Tender Security shall remain valid for a period of 90 days beyond the validity period for the Tender. (v) The details of the BG, physically submitted should match with the details available in the scanned copy and the data entered during bid submission time, failing which the bid will be rejected. (vi) The Bank Guarantee shall be placed in an envelope, which shall be sealed. The envelope shall clearly bear the identification "Bid for the ***** Project" and shall clearly indicate the name and address of the Bidder. In addition, the Bid Due Date should be indicated on the right hand top corner of the envelope. (vii) The envelope shall be addressed to the officer and address as mentioned in the tender document. (viii) If the envelope is not sealed and marked as instructed above, the Authority assumes no responsibility for the misplacement or premature opening of the contents of the Bid submitted and consequent losses, if any, suffered by the Bidder. (ix) BG/EMD shall be made in the favor of Sr Divisional Finance Manager/FZR.	No	No	Allowed (Optional)
4.1.1	1. Only firm recognized by department of industrial policy and promotion (DIPP) as "Startups" shall be exempted from payment of Bid Security as per GCC 2022. 2. All other firms except described above shall be required to submit the Bid Security as per terms and conditions of tender.	No	No	Allowed (Mandatory)
5	PAN CERTIFICATE : PAN The tenderer shall submit the photocopy of Permanent Account Number (PAN) issued by Income Tax authority attested by Gazetted officer / self attested.	No	No	Allowed (Mandatory)

General Instructions

S.No.	Description	Confirmation Required	Remarks Allowed	Documents Uploading
1	The instructions issued under ACS 1 to ACS 11 and any latest circular/letter of Railway Board of GCC Works 2022 shall prevail over and supersede any conflicting provisions or instructions contained in the Tender Document and Notice Inviting Tender (NIT).	No	No	Not Allowed
2	The tenderer shall study the Northern Railway General Conditions of Contract Regulations for Tenders & Contracts - 2022 or latest along with tender documents before submission of the tender.	No	No	Not Allowed
3	Applicable charges/recoveries/Advance etc. (Deployment of Technical supervisors per attached Annexure XIII) is applicable.	No	No	Not Allowed

**FEROZPUR DIVISION-ELECTRICAL/NORTHERN RLY
TENDER DOCUMENT**

Tender No: 251-Elect-T-02-2026-27

Closing Date/Time: 03/07/2026 15:00

4	There is an option of payment to contractor through a letter of credit (LC) arrangement (Authority Railway Board's letter no. 2018/CE-I/CT/9 dated 04.06.2018) as given in clause 1.3.14 of tender document.	No	No	Not Allowed
5	GCC works 2022(or latest if any) should be the integral part of this tender.	No	No	Not Allowed

Special Conditions

S.No.	Description	Confirmation Required	Remarks Allowed	Documents Uploading
1	Special Conditions of Work & Responsibilities of Contractors	No	No	Not Allowed
1.1	This contract shall be governed by latest version of Indian Electricity Act & Indian Electricity Rules in force.	No	No	Not Allowed
1.2	This contract shall be governed by general condition of contract & regulations of Engg. Deptt. latest edition upto date.	No	No	Not Allowed
1.3	The contractor shall ensure the staff engaged by him possess identity card, entry pass, duty pass signed by the authority designated by Engineer Incharge of contract	No	No	Not Allowed
1.4	The contractor shall be responsible for the execution of contract(work) in accordance with terms and conditions prescribed by Railways.	No	No	Not Allowed
1.5	Railway administration will not be responsible for any compensation to the firm's staffs by any reasons what so ever. Contractor will ensure that the staff is fully insured for any liability in case of accident, strikes, notes, civil commotion etc. The railway will not be liable for any damage caused due to any reason	No	No	Not Allowed
1.6	Charges & expenses in respect of dismantling, moving, Loading and Unloading the equipment or a part there of, if required by firm for installing, repairing the equipment to their working place and back to Railway premises and including dismantling reinstallation testing and commissioning shall be borne by firm.	No	No	Not Allowed
1.7	Permission to work shall be given as per the Railway's convenience. No claim for not giving the permission to work during the odd Hrs. will be accepted.	No	No	Not Allowed
1.8	All work is to be carried out in the presence of Railway's representative.	No	No	Not Allowed
1.9	The Railways Engineer Incharge may at any time terminate the contract without any notice payments in lieu thereof or assigning any reason thereof.	No	No	Not Allowed
1.10	Income tax shall be deducted from the bills of the contractors as applicable and shall be deposited to IT department.	No	No	Not Allowed
1.11	If any minor item under SOR not covered but required for completion of work will be done by the contractor at no extra cost.	No	No	Not Allowed
1.12	The electrical work shall be carried out without interruption of power supply to the residents. Necessary shut down of power supply be arranged by Railway if required	No	No	Not Allowed
1.13	Any modification in technical details suggested by OEM can be accepted with the prior written approval of Sr.DEE/G/FZR	No	No	Not Allowed
1.14	The site can be changed anywhere in the Firozpur division with the approval of competent authority.	No	No	Not Allowed

Undertakings

S.No.	Description	Confirmation Required	Remarks Allowed	Documents Uploading
1	I/We have visited the works site and I/We am/are aware about the site conditions.	No	No	Not Allowed
2	I/We also hereby agree to abide by all the terms and conditions of mentioned in tender document as well as the Indian Railways Standard General Conditions of Contract-2022 corrected up to date to carry out the work.	No	No	Not Allowed

6. Documents attached with tender

**FEROZPUR DIVISION-ELECTRICAL/NORTHERN RLY
TENDER DOCUMENT**

Tender No: 251-Elect-T-02-2026-27

Closing Date/Time: 03/07/2026 15:00

S.No.	Document Name	Document Description
1	Tenderdocumentfinal.pdf	Tender Document
2	RDSOSpecUPS.pdf	RDSO spec UPS
3	LetterofCredit04_06_2018.pdf	Letter of Credit
4	PublicProcurementPolicy.pdf	Public Procurement Policy
5	LEDSpecification.pdf	CEE LED Specification
6	LEDSpec.1.pdf	LED CEE specification 2
7	LEDSpec2.pdf	LED Spec 3
8	GCCCorrectionSlip.pdf	GCC Correction Slip
9	GCC_April-2022_2022_CE-I_CT_GCC-2022_POLICY_27_04_22.pdf	GCC works
10	ACS5.pdf	ACS 4
11	ACS6.pdf	ACS 6
12	ACS4.pdf	ACS 5
13	ACS11.pdf	ACS 11
14	GCCClarificationRegarding.pdf	ACS 10 clarification
15	ACS3.pdf	ASC 3
16	ACS2_1.pdf	ASC 2
17	AnnexureXIII_1.pdf	Annexure XIII
18	ACS7.pdf	ACS 7
19	ACS8.pdf	ASC 8
20	ACS9.pdf	ACS 9
21	ACS10.pdf	ACS 10
22	RewirngSpec-I.pdf	wiring

This tender complies with Public Procurement Policy (Make in India) Order 2017, dated 15/06/2017, issued by Department of Industrial Promotion and Policy, Ministry of Commerce, circulated vide Railway Board letter no. 2015/RS(G)/779/5 dated 03/08/2017 and 27/12/2017 and amendments/ revisions thereof.

As a Tender Inviting Authority, the undersigned has ensured that the issue of this tender does not violate provisions of GFR regarding procurement through GeM.

Signed By: MANISH NARWAL

Designation : Sr.DEE/G/FZR