

TECHNICAL SPECIFICATIONS FOR REWIRING/WIRING

1.0 TECHNICAL SPECIFICATIONS FOR REWIRING / WIRING AND EARTHING:

1.1 All wiring work shall be done as per ISS/IE rules.

1.2 Point wiring includes supply and providing of piano type switch, holder, ceiling rose, MS boxes etc.

1.3 On completion of wiring, the following tests conf. to the relevant ISS/E rules shall be carried etc.

1) Insulation resistance test.

2) Polarity test of switches.

3) Earth continuity test.

4) Earth resistance test.

1.4 The conduit pipe with accessories shall be fixed/ provided in steel trusses/ angle iron/ wall by means by suitable MS clumping arrangement as per site requirement and ISS/IE rules.

1.5 The power and lighting wiring, as the case may be shall be kept separate & distinct each other.