

**IZZATNAGER DIVISION-ELECTRICAL/NORTH EASTERN RLY
TENDER DOCUMENT**

Tender No: IZN-Elect-OT-19-2026

Closing Date/Time: 02/07/2026 11:00

Sr.DEE (G)/IZN acting for and on behalf of The President of India invites E-Tenders against Tender No **IZN-Elect-OT-19-2026** Closing Date/Time 02/07/2026 11:00 Hrs. Bidders will be able to submit their original/revised bids upto closing date and time only. Manual offers are not allowed against this tender, and any such manual offer received shall be ignored.

1. NIT HEADER

Name of Work	General Electrification work in connection with Provision of 16 beded RPF Barrack at Hathras City (HTC), Raising of Medium level PF to High level PF at MEU & MSN stations under ADEN/MRT, Raising of Medium level PF to High level PF at MHA, AUL & RKN stations under ADEN/MRT and Extension of PF-1 & 2 at MRT station of IZN Division.		
Bidding type	Normal Tender		
Tender Type	Open	Bidding System	Single Packet System
Tender Closing Date Time	02/07/2026 11:00	Date Time Of Uploading Tender	10/06/2026 12:22
Pre-Bid Conference Required	No	Pre-Bid Conference Date Time	Not Applicable
Advertised Value	7280543.45	Tendering Section	TENDER
Bidding Style	Single Rate for Each Schedule Item	Bidding Unit	
Earnest Money (Rs.)	145600.00	Validity of Offer (Days)	60
Tender Doc. Cost (Rs.)	0.00	Period of Completion	6 Months
Contract Type	Works - General	Contract Category	Expenditure
Bidding Start Date	18/06/2026		
Are JV allowed to bid	No	Number of JV Member Allowed	0
Are Consortium allowed to bid	No	Number of Consortium Member Allowed	0
Ranking Order For Bids	Lowest to Highest	Expenditure Type	Capital (Works)

2. SCHEDULE

S.No.	Item Code	Item Qty	Qty Unit	Unit Rate	Basic Value	Escl.(%)	Amount	Bidding Unit
Schedule () SS-SUB STATION WORK							419868.00	
01	SS 12	100.00	Numbers	3975.98	397598.00	AT Par	397598.00	Above/ Below/P ar
	Description:- Earthing with G.I. earth pipe 4.5 metre long, 40 mm dia including accessories, and providing masonry enclosure with cover plate having locking arrangement and watering pipe etc. with charcoal/ coke and salt as required and connection with 40mm x 4 mm GI strip/flat instead of GI wire.							
02	SS34	100.00	Metre	188.44	18844.00	AT Par	18844.00	Above/ Below/P ar
	Description:- Providing and fixing 25 mm X 5 mm G.I. strip on surface or in recess for Earthing connection etc. as required.							
03	SS34 a	300.00	Metre	11.42	3426.00	AT Par	3426.00	Above/ Below/P ar
	Description:- Supply and recessing/fixing on surface of 6 SWG GI wire conforming to IS: 280/2006 (latest version) for earthing as required for earthing of installation as per IE Rule.							
S.No.	Item Code	Item Qty	Qty Unit	Unit Rate	Basic Value	Escl.(%)	Amount	Bidding Unit
Schedule () CBL-CABLE LAYING WORK							2303653.50	
01	Please see Item Breakup for details.				750236.00	AT Par	750236.00	Above/ Below/P ar

**IZZATNAGER DIVISION-ELECTRICAL/NORTH EASTERN RLY
TENDER DOCUMENT**

Tender No: IZN-Elect-OT-19-2026

Closing Date/Time: 02/07/2026 11:00

01	Description:- Supply & laying of fire retardant, rodent proof Double walled Corrugated (DWC) pipe confirming to IS:14930 Part-II, along with all accessories (socket/coupler and T joint where ever required), including excavation of 110 cm depth and 40 cm wide cable trench, in all kinds of soil and its refilling with the same excavated soil with laying of DWC pipe of required size, for laying and protection of power cable.							
	CBL 02	3000.00	Metre	219.03	657090.00	AT Par	657090.00	Above/ Below/P ar
02	Description:- Laying of multicore XLPE insulated power LT/HT cable 1100 volt upto 4 core of sizes upto 240 mm sq. direct in ground at a depth of 1M. Below ground level including excavation, sand cushioning, protective brick covering as per IS 1255/1983 (Latest version) and Supply & fixing of stone made Cable route marker at every 70 Mtr interval and all strategic locations track /road crossing & cable route alignment deviation >30 degree, complete in all respect.(Only cable will be supplied by Railway)							
03	CBL 02 i	700.00	Metre	150.83	105581.00	AT Par	105581.00	Above/ Below/P ar
	Description:- Laying of multicore XLPE insulated power LT/HT cable 1100 volt upto 4 core of sizes upto 240 mm sq. direct in ground at a depth of 1M. Below ground level including excavation, sand cushioning, protective brick covering as per IS 1255/1983 (Latest version), complete in all respect. (Only cable will be supplied by Railway)							
04	CBL 03	3700.00	Metre	73.80	273060.00	AT Par	273060.00	Above/ Below/P ar
	Description:- Laying of 1 No. Additional multicore LT/HT XLPE cable up to 11 KV voltage level, upto size 240 sqmm direct in ground in above made trench vide item no 1 at a depth of 1 Meter below ground level including trench widening & excavation to ensure 04-inch cable separation to accommodate this additional cable sand cushioning, protective covering with bricks as per IS: 1255/1983 (Latest version) complete in all respect. (Cable will be supplied by Railway)							
05	CBL 04	10070.00	Metre	18.94	190725.80	AT Par	190725.80	Above/ Below/P ar
	Description:- Laying of LT cable of required size in open air/ along the Pole/ wall /Pucca trench/DWC Pipe with clamping arrangement. Cable laying work shall be governed by IS:1255/1983.(Cable & DWC Pipe will be supplied by Railway)							
06	CBL13 a	200.00	Metre	487.00	97400.00	AT Par	97400.00	Above/ Below/P ar
	Description:- Cutting of RCC foundation, excavation of cable trench of one feet depth & one feet width and refilling trench with excavated soil, ramming, consolidating and bringing the surface to its original level with suitable cement mixer etc as required.							
07	Please see Item Breakup for details.				97249.50	AT Par	97249.50	Above/ Below/P ar
	Description:- Supply of G.I.hot dip power coated perforated type cable tray size 14 SWG (2 mm) with cover, Hardware etc. as per IS:2629/4759 for cabling on wall/pillar/ground or wherever is required complete in all respect. (for proper cabling of existing & new overhead cabling)							
08	CBL 25	280.00	Metre	472.54	132311.20	AT Par	132311.20	Above/ Below/P ar
	Description:- Manual Excavation/ digging of through hole at the under track/platform/Road by Boogie method at the 1.2m-1.5m depth below ground/formation level and supply & erection of 90mm OD/76mm inner dia double wall corrugated DWC pipe confirming to IS 14930 Part-II, for multiple Cable laying. Including , refilling with soil and repairing of surface (DWC pipe shall be supplied by contractor and air laying of Cable will be covered under relevant schedule item)							
	S.No.	Item Code	Item Qty	Qty Unit	Unit Rate	Basic Value	Escl.(%)	Amount
								Bidding Unit
	Schedule () ELE-BUILDING ELECTRIFICATION WORK							1479932.76
01	ELE 01	14.00	Numbers	2189.70	30655.80	AT Par	30655.80	Above/ Below/P ar

**IZZATNAGER DIVISION-ELECTRICAL/NORTH EASTERN RLY
TENDER DOCUMENT**

Tender No: IZN-Elect-OT-19-2026

Closing Date/Time: 02/07/2026 11:00

	Description:- Supply & fixing Prewired segregated sheet steel phosphatised powder coated 8 way SPN MCB, DB's prefitted with incoming 63AMP. 2pole MCB-1 no and outgoing 6/10/16/20 A. single pole MCB -6 Nos.breaking capacity 10KA, bus-bar, neutral link, earth bar, plates. Confirming to IS/IEC 60898-2;2003, and IS:13032/1991 including, drilling holes on the board, its connection, earthing the body etc. complete in all respect.							
02	ELE 02	6.00	Numbers	6647.33	39883.98	AT Par	39883.98	Above/ Below/P ar
	Description:- Supply ,fixing ,Testing & commissioning of Pre wired 4 way TPN MCB DB with 4 pole MCB 63A-1 no and 6/16/32 A MCB single pole-12 nos (4 way in each phase), 63A copper busbar, neutral and earth link etc. conforming to, IS:13032/1991, complete in all respect.							
03	ELE 02 i	1.00	Numbers	9853.75	9853.75	AT Par	9853.75	Above/ Below/P ar
	Description:- Supply ,fixing ,Testing & commissioning of Pre wired 4 way TPN MCB DB with 4 pole MCB 63A-1 no and 63 A, 4 pole RCCB with 300mA sensitivity and 6/16/32 A MCB single pole-12 nos (4 way in each phase), 63A copper busbar, neutral and earth link etc. conforming to, IS:13032/1991, complete in all respect.							
04	ELE03	4.00	Numbers	2077.56	8310.24	AT Par	8310.24	Above/ Below/P ar
	Description:- Supply & fixing of 4 way D.B.Single door 240V, 20 A DP MCB -1 No., 6-10 Amp MCB Single pole - 4 Nos including drilling holes on the board & its connection etc. complete in all respect. (for controlling AT supply & inverter supply)							
05	ELE 06 i	7.00	Numbers	10749.20	75244.40	AT Par	75244.40	Above/ Below/P ar
	Description:- Supplying and fixing surface/ recess mounted ,vertical type, duly powder coated sheet steel made 415 V, TPN distribution board, consisting of 63 A four pole MCCB-1 No,63 A DP MCB- 1 No, 32 A SP,MCB- 2Nos, 16 A SP,MCB- 1 No10 A SP,MCB- 1 No, inclusive of 100A tinned copper bus bar, common neutral link, earth bar, din bar for mounting MCB as required. (for Halt station and Automatic Signalling Relay Hut, and multi story residential complex)							
06	Please see Item Breakup for details.				510810.00	AT Par	510810.00	Above/ Below/P ar
	Description:- Supply & erection of PVC insulated multi stranded copper conductor single core FRLS cable conforming to IS: 694 (Latest version) & its drawing in laid (Recessed/surface) PVC conduit pipe for wiring/sub-main/main as required including connection testing & commissioning. In addition to it suitable size of T-bend socket & other joints which is required provided by contractor. (incl. renovation of wiring of existing PF shelter, FOB, Station building etc.)							
07	Please see Item Breakup for details.				22330.45	AT Par	22330.45	Above/ Below/P ar
	Description:- Supply & fixing GI box along with modular base & cover plate for modular switches conforming to IS:3854/1997 (Latest version)/flush type socket outlet as per IS:1293-1988 (Latest version) including connection, testing & commissioning complete in all respect.							
08	Please see Item Breakup for details.				29014.92	AT Par	29014.92	Above/ Below/P ar
	Description:- Supply, fixing and commissioning of modular type switches, sockets & bell push as per latest IS:1293/2019.							
09	ELE 10	1500.00	Metre	39.85	59775.00	AT Par	59775.00	Above/ Below/P ar
	Description:- Supply & fixing of heavy duty PVC conduit pipe 25 mm dia conforming to IS: 9537/Pt.III/1983 (Latest version) with accessories, Jn. Box etc. including making, chase, plastering/clamping etc.							
10	ELE 11	150.00	Metre	8.12	1218.00	AT Par	1218.00	Above/ Below/P ar
	Description:- Supply & laying of PVC flexible pipe 25 mm dia including suitable fixing by MS flat, clamp etc. at a interval of 1M. along the MS angle/pole/Shed lighting.							
11	ELE 12	5.00	Numbers	325.00	1625.00	AT Par	1625.00	Above/ Below/P ar
	Description:- Making hole in the wall for exhaust fan and finishing properly complete in all respect.							

**IZZATNAGER DIVISION-ELECTRICAL/NORTH EASTERN RLY
TENDER DOCUMENT**

Tender No: IZN-Elect-OT-19-2026

Closing Date/Time: 02/07/2026 11:00

12	ELE 13	250.00	Numbers	592.09	148022.50	AT Par	148022.50	Above/ Below/P ar
	Description:- Supply, installation, testing & energisation of 18-20 watt LED tube light fitting 1200 mm Integrated with Aluminium Extrusion Base with LED & Driver, decorative pin type end caps & copper contacts with Diffuser made of transparent polycarbonate with tube light, operating voltage single phase 230 volt AC, 50 Hz, 5 year warranty, with required size of clamp etc. complete in all respect.							
13	ELE 13 a	100.00	Numbers	824.90	82490.00	AT Par	82490.00	Above/ Below/P ar
	Description:- Supply of LED inverter batten 20 watt, 6500 K tube light polycarbonate body with battery backup of minimum 4 hrs, including fixing of light with supply of flexible wire for connection to the nearest ceiling rose.							
14	ELE 16	70.00	Numbers	3370.56	235939.20	AT Par	235939.20	Above/ Below/P ar
	Description:- Supply, Installing, testing & commissioning of 1400 mm sweep, 5 star rated BLDC ceiling fan as per IS:374/2019 or latest in White Colour with 3 blade, speed control compatible to electronic regulator (covered vide item) along with 12 mm dia 300 mm long suspension rod and clamp fastener etc. and double ball bearing complete in all respect.							
15	ELE 17	5.00	Numbers	2467.50	12337.50	AT Par	12337.50	Above/ Below/P ar
	Description:- Supply, installation, testing & commissioning of Exhaust fan fiber body 300 mm sweep with louver indoor type window/wall Mount, as per IS: 2312 for 230 Volt AC Single.							
16	ELE 19	360.00	Numbers	39.04	14054.40	AT Par	14054.40	Above/ Below/P ar
	Description:- Supply and fixing 3 pin 5 A ceiling rose including connections etc. as required as per IS:371/1999 (Latest version)							
17	ELE 21	4.00	Numbers	10436.00	41744.00	AT Par	41744.00	Above/ Below/P ar
	Description:- Supply& fixing of Geyser of 20 Ltr storage capacity 5 star rated 230 volt AC steel body, material of tank stainless steel conforming to IS:2082:2018 with all accessories complete in all respect.							
18	ELE 24	12.00	Numbers	284.98	3419.76	AT Par	3419.76	Above/ Below/P ar
	Description:- Supply and fixing two module stepped type electronic fan regulator on the existing modular plate switch box including connections but excluding modular plate etc. as required.							
19	ELE 26	8.00	Numbers	14895.00	119160.00	AT Par	119160.00	Above/ Below/P ar
	Description:- Supply & installation of Direct Evaporative Air Cooler of 5000 cubic meter per hour air delivery capacity, having 500 mm sweep sized blower fan driven by 500 watt, 220V, 50 Hz, AC Supply operated single phase induction motor, made of Polyester powder-coated exterior and interior heavy duty galvanized Steel sheet Body, tank capacity 120 Liters and fitted with honey comb pads and suitable water pump and float valve. Steel body cooler confirms to IS 3315 or latest, Galvanized Sheet of cooler shall be ISI marked and confirming to IS 3315 : 2024 with latest amendment.							
20	ELE 27	8.00	Numbers	500.00	4000.00	AT Par	4000.00	Above/ Below/P ar
	Description:- Supply of Iron angle stand of size 22x26x36 inch with roller caster wheel, for mounting of Desert Cooler complete in all respect.							
21	ELE 30	39.00	Numbers	119.99	4679.61	AT Par	4679.61	Above/ Below/P ar
	Description:- Supply of ceiling fan 2.5 feet long 12mm dia M.S. down rod/ flat of suitable size & fastener bolt/Clamps and erecting in concrete slab/roof structure of the Building etc. for hanging ceiling fan complete in all respect.							
	ELE 31	17.00	Numbers	275.25	4679.25	AT Par	4679.25	Above/ Below/P ar

**IZZATNAGER DIVISION-ELECTRICAL/NORTH EASTERN RLY
TENDER DOCUMENT**

Tender No: IZN-Elect-OT-19-2026

Closing Date/Time: 02/07/2026 11:00

22	Description:- Supply, erection, testing & commissioning of Mobile charging board made by hard board 10 mm thick size 205 mm x 215 mm x 60 mm, 04 Nos. socket 3 pins 6 amps. On each board, 1 No. indication lamp on each board, fuse kit kat on each board, fixing of 205 mm x 160 mm x 10 mm thick hard board sheet for supporting of Mobile phone.							
23	ELE 50	20.00	Numbers	1034.25	20685.00	AT Par	20685.00	Above/ Below/P ar
	Description:- Supply, installation, testing & Commissioning of 1x1 feet 18 W, 230V, CRI-90, CCT-2700K, square shaped LED down lighters							
S.No.	Item Code	Item Qty	Qty Unit	Unit Rate	Basic Value	Escl.(%)	Amount	Bidding Unit
Schedule () MIC-MISCELLANEOUS WORK							73059.94	
01	MIC02	1.00	Numbers	6583.08	6583.08	AT Par	6583.08	Above/ Below/P ar
	Description:- KM 370 3.75 Digit Digital Insulation resistance tester with multimeter Function with test voltage:500V/ 1000V/ 2500V with test insulation resistance upto 40 G ohm.							
02	MIC03	5.00	Numbers	6178.40	30892.00	AT Par	30892.00	Above/ Below/P ar
	Description:- Designing of HT/LT distribution system, including various equipments/cable capacity calculation, protection scheme, cable layout. Submission of design calculation report. BOQ and detailed single line diagram and cable route diagram for NSG- 06 level station.							
03	MIC04	1.00	Numbers	7723.00	7723.00	AT Par	7723.00	Above/ Below/P ar
	Description:- Designing of HT/LT distribution system, including various equipments/cable capacity calculation, protection scheme, cable layout. Submission of design calculation report. BOQ and detailed single line diagram and cable route diagram, for NSG- 05 level station.							
04	MIC05	1500.00	Square Foot	6.18	9270.00	AT Par	9270.00	Above/ Below/P ar
	Description:- Designing of wiring, protection and earthing for Electrification of service building /Station buildings and preparation & Submission of building wiring drawings (General Layout drawing and single line diagram in 03 copy on tracing paper.) for station, halt station, Gate Lodge, ABS Hut, Quarters, S&T depot etc.							
05	MIC08	4.00	Numbers	1916.85	7667.40	AT Par	7667.40	Above/ Below/P ar
	Description:- Supply of Stanley Analog electrician Tool Kit with wire strippers, insulated screw drivers, Insulated pliers, Electric Tape, Hacksaws, Cable cutter, Spanner, Voltage tester).							
06	MIC 18	2.00	Numbers	5462.23	10924.46	AT Par	10924.46	Above/ Below/P ar
	Description:- Supply, erection, installation, of digital Micro meter of range 0-25 mm. Model - Mitutoyo 293-821 30 Digimatic LCD Micrometer, Ratchet Stop, 0-25mm Range, 0.001mm Graduation,-0.002mm Accuracy or equivalent.							
S.No.	Item Code	Item Qty	Qty Unit	Unit Rate	Basic Value	Escl.(%)	Amount	Bidding Unit
Schedule () ODL-OUT DOOR ELECTRIFICATION & LIGHTING WORK							3004029.25	
01	ODL 03	202.00	Numbers	3850.52	777805.04	AT Par	777805.04	Above/ Below/P ar
	Description:- Supply, Installation, testing & commissioning of 60 Watt street light LED luminaire fittings with 5 year warranty as per detailed specification attached. Complete in all respect.							
02	ODL 07	7.00	Numbers	8443.56	59104.92	AT Par	59104.92	Above/ Below/P ar
	Description:- Prov.& supply of Timer based semi automatic light control Panel Board consisting with 16 A,4 Pole MCB-5Nos+16 A, 4 Pole contactor inbuilt digital timer switch -2 nos , all assembled inside 1 feet x 2 feet size CRCA Sheet Powder coated box complete.							

**IZZATNAGER DIVISION-ELECTRICAL/NORTH EASTERN RLY
TENDER DOCUMENT**

Tender No: IZN-Elect-OT-19-2026

Closing Date/Time: 02/07/2026 11:00

03	ODL 07 i	7.00	Numbers	9424.01	65968.07	AT Par	65968.07	Above/ Below/P ar
	Description:- Supply, Installation, Testing & commissioning of off delay timer with 0-35 minutes adjustable time delay relay assembly with the following accessories incoming 3 phase 32 Ampere contactor with NO/NC, PCB circuit plate with required electric component complete wiring & power supply control by 6 A SP MCB in MS Box made by 1.6 mm CRCA sheet with powder coated paint system suitable for maximum 6 KW lighting load.							
04	ODL 08	60.00	Numbers	13526.47	811588.20	AT Par	811588.20	Above/ Below/P ar
	Description:- Supply & Erection of 6 mtr Long G.I Octagonal pole with Standard double arm bracket (0.5 mtr long) made up of 48.3mm dia G.I.pipe bracket suitable for road way LED Luminaires fitment at 30 degree from horizontal. Street light Pole shall be pre fitted with FR Bakelite base sheet with TPN connector 6 amp, SP MCB Fitted inside connection chamber having neoprene rubber gasket and 50 cm long examination door cover and 2x1.5 mm sq. FR PVC insulated unsheathed multi strand flexible copper cable, (as per detailed drawing attached) . Street light pole to be fixed on suitable foundation of cement, concrete 1:3:6 (Ratio concrete) foundation. Including excavation & refilling dressing up of the plinth.							
05	ODL 08 ii	15.00	Numbers	9681.74	145226.10	AT Par	145226.10	Above/ Below/P ar
	Description:- Supply, erection and testing of hot dip galvanized tapered octagonal pole of 5.0 Mtrs. long top dia 70 mm, bottom dia 130 mm, sheet thickness 3 mm, base plate dimension (L x B x T) 200 mm x 200 mm x 12 mm & foundation bolts size (No. x dia x length) (4 x M16 x 600 mm), PCD 200 mm, anchor plate thickness 3 mm with hot dip galvanized detachable double arm bracket made by 48.3 mm outer dia pipe 300 mm long with 32 mm outer dia sleeve including erection & fixing on the foundation with 2x1.5 mm sq FR PVC insulated unsheathed multi strand flexible copper cable, Bakelite sheet for connecting testing & commissioning of LED fitting complete in all respect. Street light Pole shall be pre fitted with FR Bakelite base sheet with TPN connector and 8 Nos lugs, 1No SP MCB 6 amps Fitted inside connection chamber having neoprene rubber gasket and 50 cm long examination door cover complete in all respect. (Octagonal pole shall confirm to IS: 2629 or latest.) Including casting of M-15 grade concrete foundation of 300 mm x 300 mm x 1000 mm size and 450 mm long holding down- 4 Nos bolts as per explanatory note. Note:-1. Galvanized thickness of pole should be minimum 65 microns and test report to be submitted by the contractor at the time of supply.							
06	ODL 09	68.00	Numbers	2565.58	174459.44	AT Par	174459.44	Above/ Below/P ar
	Description:- Shifting of existing Octagonal /Tubular pole by its complete digging and re-erection at new alignment in cement concrete 1:3:6 (1 cement: 3 coarse sand: 6 graded stone aggregate 40mm nominal size) foundation, including, excavation & refilling, dressing up of the plinth etc. in all respect as required.							
07	ODL13	20.00	Square Foot	1867.56	37351.20	AT Par	37351.20	Above/ Below/P ar
	Description:- Design, Manufacturing, supply, installation, Testing & commissioning of LED based signage board of different size & single/Double side as required in Hindi/ English /Urdu as required by Railway as per attached Specification, complete in all respect. (for station name board etc.)							
08	ODL 17	7.00	Numbers	35934.34	251540.38	AT Par	251540.38	Above/ Below/P ar
	Description:- Supply, Installation, testing & commissioning of self-contained drinking water cooler of cooling capacity 80 litres per hr, storage capacity 120 litres and suitable for 230 volts/single phase/50 Hz AC supply conforming to IS:1475(Part 1);2001 latest, material will be SS Grade 304 with 0.5 mm thickness and body of PPGI complete in all respect.							
09	ODL 17 a	3.00	Numbers	47281.35	141844.05	AT Par	141844.05	Above/ Below/P ar
	Description:- Supply, Installation, testing & commissioning of water cooler 150 Ltrs capacity with fully stainless steel body suitable for 230 volts/single phase/50 Hz ac supply conforming to IS:1475(Part 1);2001 latest, material will be SS Grade 304 with 0.5 mm thickness and body of PPGI complete in all respect.							
10	ODL 17 b	9.00	Numbers	30715.15	276436.35	AT Par	276436.35	Above/ Below/P ar

**IZZATNAGER DIVISION-ELECTRICAL/NORTH EASTERN RLY
TENDER DOCUMENT**

Tender No: IZN-Elect-OT-19-2026

Closing Date/Time: 02/07/2026 11:00

	Description:- Supply, fabrication & fixing of safety cage for water cooler as per approved drawing complete in all respect, as per direction of engineer incharge at site.							
11	ODL18	30.00	Numbers	930.62	27918.60	AT Par	27918.60	Above/ Below/P ar
	Description:- Dismantling of street light poles embedded in cement concrete foundation etc. duly digging around upto bottom of the pole and then taken out the pole complete in all respect.							
12	ODL 23	1800.00	Metre	35.39	63702.00	AT Par	63702.00	Above/ Below/P ar
	Description:- Supply & fixing of PVC pipe 25 mm dia Conforming to IS: (Latest version) with accessories, Jn. Box etc. including cleating/ clamping/fixing on wall/ pillar at suitable interval etc. as per direction of Engg-In-charge. (for shelter, FOB)							
13	ODL 26	21.00	Numbers	8146.90	171084.90	AT Par	171084.90	Above/ Below/P ar
	Description:- Supply, fabrication, installation, testing & commissioning of out door type bus-bar chamber made of 2 mm thick cold rolled steel sheet, 500mmx300mmx 150mm size Bus-bar chamber, comprising of 125 A, 4 Pole MCCB and alumn. Bus-bar cross section (25mmx5mm) fixed on bus-bar insulator with top cover fixed with hinged & locking arrangement complete with red oxide primer & final painting with metal grey enamelled paint, complete in all respect. Box framing will be done by 40 mmx40mmx3mm angle iron.							

3. ITEM BREAKUP

Schedule	Schedule CBL-CABLE LAYING WORK					
Item- 01	Supply & laying of fire retardant, rodent proof Double walled Corrugated (DWC) pipe confirming to IS:14930 Part-II, along with all accessories (socket/coupler and T joint where ever required), including excavation of 110 cm depth and 40 cm wide cable trench, in all kinds of soil and its refilling with the same excavated soil with laying of DWC pipe of required size, for laying and protection of power cable.					
S No.	Item No	Description of Item	Unit	Qty	Rate	Amount
1	CBL01 i	DWC pipe of 90 mm outer dia and 76 mm nominal inner diameter.	Metre	2400.00	237.39	569736.00
2	CBL01 ii	DWC pipe of 160 mm outer dia and 135 mm nominal inner diameter.	Metre	500.00	361.00	180500.00
					Total	750236.00
Item- 07	Supply of G.I.hot dip power coated perforated type cable tray size 14 SWG (2 mm) with cover, Hardware etc. as per IS:2629/4759 for cabling on wall/pillar/ground or wherever is required complete in all respect. (for proper cabling of existing & new overhead cabling)					
S No.	Item No	Description of Item	Unit	Qty	Rate	Amount
1	CBL 17 iii	size 300 mm (W)X 100 mm (H)	Metre	150.00	648.33	97249.50
					Total	97249.50
Schedule	Schedule ELE-BUILDING ELECTRIFICATION WORK					
Item- 06	Supply & erection of PVC insulated multi stranded copper conductor single core FRLS cable conforming to IS: 694 (Latest version) & its drawing in laid (Recessed/surface) PVC conduit pipe for wiring/sub-main/main as required including connection testing & commissioning. In addition to it suitable size of T-bend socket & other joints which is required provided by contractor. (incl. renovation of wiring of existing PF shelter, FOB, Station building etc.)					
S No.	Item No	Description of Item	Unit	Qty	Rate	Amount
1	ELE 07 a	0.75 mm sq. (incl. earth, green in colour)	Metre	2000.00	10.98	21960.00
2	ELE 07 b	1.0 sq.mm	Metre	2800.00	11.02	30856.00
3	ELE 07 c	1.5 sq. mm .	Metre	3800.00	17.02	64676.00
4	ELE 07 d	2.5 sq.mm	Metre	4400.00	19.40	85360.00
5	ELE 07 e	4 sq.mm	Metre	3000.00	36.30	108900.00

**IZZATNAGER DIVISION-ELECTRICAL/NORTH EASTERN RLY
TENDER DOCUMENT**

Tender No: IZN-Elect-OT-19-2026

Closing Date/Time: 02/07/2026 11:00

6	ELE 07 f	6 sq.mm	Metre	2600.00	62.23	161798.00
7	ELE 07 g	10 sq.mm(For main circuit)	Metre	400.00	93.15	37260.00
Total						510810.00
Item- 07	Supply & fixing GI box along with modular base & cover plate for modular switches conforming to IS:3854/1997 (Latest version)/flush type socket outlet as per IS:1293-1988 (Latest version) including connection, testing & commissioning complete in all respect.					
S No.	Item No	Description of Item	Unit	Qty	Rate	Amount
1	ELE 07 a	(4 Module size 125 mm x75 mm)	Numbers	30.00	245.56	7366.80
2	ELE 07 b	(6 Module size 200 mm x75 mm)	Numbers	15.00	291.91	4378.65
3	ELE 07 c	(8 Module size 125 mm x125 mm)	Numbers	20.00	332.53	6650.60
4	ELE 07 d	(12 Module size 200 mm x150 mm)	Numbers	10.00	393.44	3934.40
Total						22330.45
Item- 08	Supply, fixing and commissioning of modular type switches, sockets & bell push as per latest IS:1293/2019.					
S No.	Item No	Description of Item	Unit	Qty	Rate	Amount
1	ELE 09 a	6 Amp switch	Numbers	196.00	75.97	14890.12
2	ELE 09 b	6 Amp Modular socket with auto closing shutter	Numbers	100.00	96.51	9651.00
3	ELE 09 c	16 Amp switch	Numbers	20.00	90.03	1800.60
4	ELE 09 d	6/16 Amp 06 pin Modular socket with auto closing shutter	Numbers	20.00	130.15	2603.00
5	ELE 09 f	Switch blanking set to fill the blank space.	Numbers	10.00	7.02	70.20
Total						29014.92

4. ELIGIBILITY CONDITIONS

Standard Financial Criteria

S.No.	Description	Confirmation Required	Remarks Allowed	Documents Uploading
1	The tenderer must have minimum average annual contractual turnover of V/N or "V" whichever is less V= Advertised value of the tender in crores of Rupees N= Number of years prescribed for completion of work for which bids have been invited. The average annual contractual turnover shall be calculated as an average of "total contractual payments" in the previous three financial years, as per the audited balance sheet. However, in case balance sheet of the previous year is yet to be prepared/ audited, the audited balance sheet of the fourth previous year shall be considered for calculating average annual contractual turnover.	No	No	Allowed (Mandatory)

Special Technical Criteria

S.No.	Description	Confirmation Required	Remarks Allowed	Documents Uploading
1	Tenderer should have valid "A" class electrical contractor license issued by electrical inspector to state government and submit it along with the Bid offer. If "A" class electrical contractor license has been expired, tenderer should also submit the receipt of renewal electrical contractor license issued by electrical inspector to state government, along with bid offer. At the time of contract agreement, contractor must submit valid "A" class electrical contractor license issued by electrical inspector to state government. If tenderer have not submit the valid "A" class electrical contractor license/receipt of renewal for electrical contractor license, the offer will be summarily rejected."	No	No	Allowed (Mandatory)

**IZZATNAGER DIVISION-ELECTRICAL/NORTH EASTERN RLY
TENDER DOCUMENT**

Tender No: IZN-Elect-OT-19-2026

Closing Date/Time: 02/07/2026 11:00

Standard Technical Criteria

S.No.	Description	Confirmation Required	Remarks Allowed	Documents Uploading
1	Technical Eligibility Criteria, for the tender value above 50 lakh - The tenderer must have successfully completed any of the following during last 07 (seven) years, ending last day of month previous to the one in which tender is invited: Three similar works costing not less than the amount equal to 30% of advertised value of the tender, or Two similar works costing not less than the amount equal to 40% of advertised value of the tender, or One similar work costing not less than the amount equal to 60% of advertised value of the tender. It is mandatory to enclose such work completion certificates duly issued by the competent authority, along with tender bid offer. The contractor not qualifying the above eligibility criteria or not submitting the certificates for the same, the offer will be summarily rejected.	No	No	Allowed (Mandatory)
1.1	Work experience certificate from private individual shall not be considered. However, in addition to work experience certificates issued by any Govt. Organisation, work experience certificate issued by Public listed company having average annual turnover of Rs 500 crore and above in last 3 financial years excluding the current financial year, listed on National Stock Exchange or Bombay Stock Exchange, incorporated/registered at least 5 years prior to the date of opening of tender, shall also be considered provided the work experience certificate has been issued by a person authorized by the Public listed company to issue such certificates.	No	No	Not Allowed
1.1.1	In case tenderer submits work experience certificate issued by public listed company, the tenderer shall also submit along with work experience certificate, the relevant copy of work order, bill of quantities, bill wise details of payment received duly certified by Chartered Accountant, TDS certificates for all payments received and copy of final/last bill paid by company in support of above work experience certificate.	No	No	Not Allowed
1.2	Defination of Similar Work :- i) Electrification of service building. ii)Electrification of staff quarters. iii) Electrification of offices. iv)Electrification of road and colony lighting. v) Rewiring of quarters and service building vi) Earthing arrangement (Plate & pipe earthing) for quarters, service buildings, LT/HT panel etc.vii) Installation, testing & commissioning of electrical Sub-station. viii) Laying of HT cables. ix) Laying of LT cables .	No	No	Not Allowed

Bidders shall confirm and certify on the behalf of the tenderer including its constituents as under:

S.No.	Description
1	I/we the tenderer (s) am/are signing this document after carefully reading the contents.
2	I/We the tenderer(s) also accept all the conditions of the tender and have signed all the pages in confirmation thereof.
3	I/we hereby declare that I/we have downloaded the tender documents from Indian Railway website www.ireps.gov.in . I/we have verified the content of the document from the website and there is no addition, no deletion or no alteration to the content of the tender document. In case of any discrepancy noticed at any stage i.e. evaluation of tenders, execution of work or final payment of the contract, the master copy available with the railway Administration shall be final and binding upon me/us.
4	I/we declare and certify that I/we have not made any misleading or false representation in the forms, statements and attachments in proof of the qualification requirements.
5	I/We also understand that my/our offer will be evaluated based on the documents/credentials submitted along with the offer and same shall be binding upon me/us.
6	I/We declare that the information and documents submitted along with the tender by me/us are correct and I/we are fully responsible for the correctness of the information and documents, submitted by us.
7	I/we certify that I/we the tenderer(s) is/are not blacklisted or debarred by Railways or any other Ministry / Department of Govt. of India from participation in tender on the date of submission of bids, either in individual capacity or as a HUF/ member of the partnership firm/LLP/JV/Society/Trust.
8	I/we understand that if the contents of the certificate submitted by us are found to be forged/false at any time during process for evaluation of tenders, it shall lead to forfeiture of the Bid Security and may also lead to any other action provided in the contract including banning of business for a period of upto two year. Further, I/we and all my/our constituents understand that my/our offer shall be summarily rejected.

**IZZATNAGER DIVISION-ELECTRICAL/NORTH EASTERN RLY
TENDER DOCUMENT**

Tender No: IZN-Elect-OT-19-2026

Closing Date/Time: 02/07/2026 11:00

9	I/we also understand that if the contents of the certificate submitted by us are found to be false/forged at any time after the award of the contract, it will lead to termination of the contract, along with forfeiture of Bid Security/Security Deposit and Performance guarantee and may also lead to any other action provided in the contract including banning of business for a period of upto two year.
10	I/We have read the clause regarding restriction on procurement from a bidder of a country which shares a land border with India and certify that I am/We are not from such a country or, if from such a country, have been registered with the competent Authority. I/We hereby certify that I/we fulfil all the requirements in this regard and am/are eligible to be considered (evidence of valid registration by the competent authority is enclosed)

Partnership firm/Joint Venture (JV) / Hindu Undivided Family (HUF) / Limited Liability Partnership (LLP) etc.

S.No.	Description
1	Partnership firm/Joint Venture (JV) / Hindu Undivided Family (HUF) / Limited Liability Partnership (LLP) etc. Please submit a certificate in the prescribed format (please download the format from the link given below). Non submission of the certificate, or submission of certificate either not properly filled in, or in a format other than the prescribed format shall lead to summary rejection of your offer. (Click here to download the Format of Self Certification)

5. COMPLIANCE

Commercial-Compliance

S.No.	Description	Confirmation Required	Remarks Allowed	Documents Uploading
1	Documents to be Submitted Along with Tender (i) The tenderer shall clearly specify whether the tender is submitted on his own (Proprietary Firm) or on behalf of a Partnership Firm / Company / Joint Venture (JV) / Registered Society / Registered Trust / Hindu Undivided Family (HUF) / Limited Liability Partnership (LLP) etc. The tenderer(s) shall enclose the attested copies of the constitution of their concern, and copy of PAN Card along with their tender. Tender Documents in such cases are to be signed by such persons as may be legally competent to sign them on behalf of the firm, company, association, trust or society, as the case may be. (ii) Following documents shall be submitted by the tenderer:(a) Sole Proprietorship Firm: (i) All documents in terms of Para 10 of the Tender Form (Second Sheet) above. (b) HUF: (i) A copy of notarized affidavit on Stamp Paper declaring that he who is submitting the tender on behalf of HUF is in the position of 'Karta' of Hindu Undivided Family (HUF) and he has the authority, power and consent given by other members to act on behalf of HUF. (ii) All other documents in terms of Para 10 of the Tender Form (Second Sheet) above. (c) Partnership Firm: (i) All documents as mentioned in para18 of the Tender Form (Second Sheet). (d) Joint Venture (JV): All documents as mentioned in para 17 of the Tender Form (Second Sheet). (e) Company registered under Companies Act2013: (i) The copies of MOA (Memorandum of Association) / AOA (Articles of Association) of the company (ii) A copy of Certificate of Incorporation (iii) A copy of Authorization/Power of Attorney issued by the Company (backed by the resolution of Board of Directors) in favour of the individual to sign the tender on behalf of the company and create liability against the company. (iv) All other documents in terms Para 10 of the Tender Form (Second Sheet) above.	No	No	Allowed (Mandatory)

**IZZATNAGER DIVISION-ELECTRICAL/NORTH EASTERN RLY
TENDER DOCUMENT**

Tender No: IZN-Elect-OT-19-2026

Closing Date/Time: 02/07/2026 11:00

2	(f) LLP (Limited Liability Partnership): (i) A copy of LLP Agreement (ii) A copy of Certificate of Incorporation (iii) A copy of Power of Attorney/Authorization issued by the LLP in favour of the individual to sign the tender on behalf of the LLP and create liability against the LLP. (iv) An undertaking by all partners of the LLP that they are not blacklisted or debarred by Railways or any other Ministry / Department of the Govt. of India from participation in tenders / contracts as on the date of submission of bids, either in their individual capacity or in any firm/LLP or JV in which they were / are partners/members. Concealment / wrong information in regard to above shall make the contract liable for determination under Clause 62 of the Standard General Conditions of Contract. (v) All other documents in terms of Para 10 of the Tender Form (Second Sheet). (g) Registered Society & Registered Trust: (i) A copy of Certificate of Registration (ii) A copy of Memorandum of Association of Society/Trust Deed (iii) A copy of Power of Attorney in favour of the individual to sign the tender documents and create liability against the Society/Trust. (iv) A copy of Rules & Regulations of the Society (v) All other documents in terms of Para 10 of the Tender Form (Second Sheet) above.	No	No	Allowed (Mandatory)
3	(iii) If it is NOT mentioned in the submitted tender that tender is being submitted on behalf of a Sole Proprietorship firm / Partnership firm / Joint Venture / Registered Company etc., then the tender shall be treated as having been submitted by the individual who has signed the tender. (iv) After opening of the tender, any document pertaining to the constitution of Sole Proprietorship Firm / Partnership Firm / Registered Company/ Registered Trust / Registered Society / HUF/LLP etc. shall be neither asked nor considered, if submitted. Further, no suo moto cognizance of any document available in public domain (i.e., on internet etc.) or in Railway's record/office files etc. will be taken for consideration of the tender, if no such mention is available in tender offer submitted. (v) A tender from JV shall be considered only where permissible as per the tender conditions. (vi) The Railway will not be bound by any change of power of attorney or in the composition of the firm made subsequent to the submission of tender. Railway may, however, recognize such power of attorney and changes after obtaining proper legal advice, the cost of which will be chargeable to the Contractor.	No	No	Allowed (Mandatory)
4	The tenderer whether sole proprietor / a company or a partnership firm / joint venture (JV) / registered society / registered trust / HUF / LLP etc if they want to act through agent or individual partner(s), should submit along with the tender, a copy of power of attorney duly stamped and authenticated by a Notary Public or by Magistrate in favour of the specific person whether he/they be partner(s) of the firm or any other person, specifically authorizing him/them to sign the tender, submit the tender and further to deal with the Tender/ Contract up to the stage of signing the agreement except in case where such specific person is authorized for above purposes through a provision made in the partnership deed / Memorandum of Understanding / Article of Association /Board resolution, failing which tender shall be summarily rejected. A separate power of attorney duly stamped and authenticated by a Notary Public or by Magistrate in favour of the specific person whether he/they be partner(s) of the firm or any other person, shall be submitted after award of work, specifically authorizing him/them to deal with all other contractual activities subsequent to signing of agreement, if required. Note: A Power of Attorney executed and issued overseas, the document will also have to be legalized by the Indian Embassy and notarized in the jurisdiction where the Power of Attorney is being issued. However, the Power of Attorney provided by Bidders from countries that have signed the Hague Legislation Convention 1961 are not required to be legalized by the Indian Embassy if it carries a conforming Appostille certificate.	No	No	Allowed (Mandatory)
5	Please submit your bank details i.e. Name of the Bank along with Bank Branch Code, Account Number, IFSC Code, and PAN Number.	No	No	Allowed (Mandatory)

**IZZATNAGER DIVISION-ELECTRICAL/NORTH EASTERN RLY
TENDER DOCUMENT**

Tender No: IZN-Elect-OT-19-2026

Closing Date/Time: 02/07/2026 11:00

6	Please furnish list of plant and Machinery available on hand own and proposed to be inducted own and hired to be given separately for the subject work.	No	No	Allowed (Mandatory)
7	Please furnish list of Works on hand indicating Description of Work, Contract Value, Approximate value of balance work yet to be done and Date of award.	No	No	Allowed (Mandatory)
8	Please furnish list of Works completed in last three financial years giving Description of Work, Organization for whom executed, approximate value of contract at time of award, Date of award and Date of Completion. Date of actual Start, Actual Completion and Final value of Contract shall also be given.	No	No	Allowed (Mandatory)
9	Please furnish list of personal, organization available on hand and proposed to be engaged for the subject work.	No	No	Allowed (Mandatory)
10	The tenderer whether sole proprietor / a company or a partnership firm / joint venture (JV) / registered society / registered trust / HUF / LLP etc if they want to act through agent or individual partner(s), should submit along with the tender, a copy of power of attorney duly stamped and authenticated by a Notary Public or by Magistrate in favour of the specific person whether he/they be partner(s) of the firm or any other person, specifically authorizing him/them to sign the tender, submit the tender and further to deal with the Tender/ Contract up to the stage of signing the agreement except in case where such specific person is authorized for above purposes through a provision made in the partnership deed / Memorandum of Understanding / Article of Association /Board resolution, failing which tender shall be summarily rejected. All tenderers ensure that this Para/Clause of GCC should be a part of Board of resolution and Power of attorney.	Yes	Yes	Allowed (Mandatory)
11	Please enter the percentage of local content in the material being offered. Please enter 0 for fully imported items, and 100 for fully indigenous items. The definition and calculation of local content shall be in accordance with the Make in India policy as incorporated in the tender conditions.	No	Yes	Allowed (Optional)

General Instructions

S.No.	Description	Confirmation Required	Remarks Allowed	Documents Uploading
1	Rates are inclusive of all taxes/octroi, license fee, royalty charges etc. legally leviable by State, Central Govt. and/or any other local authority.	No	No	Not Allowed
2	INDIAN RAILWAY STANDARD GERNERAL CONDITION OF CONTRACT is available on the Indian Railways website. Tenderers are requested to visit the website and be aware of the Terms and Conditions of GCC.	No	No	Not Allowed

**IZZATNAGER DIVISION-ELECTRICAL/NORTH EASTERN RLY
TENDER DOCUMENT**

Tender No: IZN-Elect-OT-19-2026

Closing Date/Time: 02/07/2026 11:00

3	<p>Security Deposit: The Security Deposit shall be 5% of the contract value. The Bid Security submitted by the Contractor with his tender will be retained/encashed by the Railways as part of security for the due and faithful fulfillment of the contract by the Contractor. Provided further that, if Contractor submits the Cash or Term Deposit Receipt issued from a Scheduled commercial bank of India or irrevocable Bank Guarantee Bond from a Scheduled commercial bank of India, either towards the Full Security Depositor the Part Security Deposit equal to or more than Bid Security, the Railway shall return the Bid Security, to the Contractor. Balance of Security Deposit may be deposited by the Contractor in cash or Term Deposit Receipt issued from Scheduled commercial bank of India or irrevocable Bank Guarantee bond issued from Scheduled commercial bank of India, or may be recovered at the rate of 6% of the bill amount till the full Security Deposit is recovered. Provided also that in case of defaulting Contractor, the Railway may retain any amount due for payment to the Contractor on the pending "on account bills" so that the amounts so retained (including amount guaranteed through Performance Guarantee) may not exceed 10% of the total value of the contract. The Irrevocable Bank Guarantee submitted towards Security deposit shall be initially valid up to the stipulated date of Maintenance period plus 60 days and shall be extended from time to time, depending upon extension of contract granted in terms of Clause 17A and 17B of the Standard General Conditions of Contract. Note: Security Deposit deposited in cash by the Contractor or recovered from the running bills of a Contractor or submitted by contractor as Term Deposit Receipt(s) can be refunded/returned to the contractor, in lieu of irrevocable Bank Guarantee bond issued from scheduled commercial bank of India, to be submitted by him, for an amount equal to or more than the already available Security Deposit, provided however that, in a contract of value less than Rs. 50 Crore, such refund/ return of the already available Security Deposit is permitted up to two times and in a contract of value equal to or more than Rs. 50 Crore, such refund / return of the already available Security Deposit is permitted up to three times.</p>	No	No	Not Allowed
4	<p>The successful bidder shall have to submit a Performance Guarantee (PG) within 21 (Twenty one) days from the date of issue of Letter of Acceptance (LOA). Extension of time for submission of PG beyond 21 (Twenty one) days and upto 60 days from the date of issue of LOA may be given by the Authority who is competent to sign the contract agreement. However, a penal interest of 12% per annum shall be charged for the delay beyond 21(Twenty one) days, i.e. from 22ndday after the date of issue of LOA. Further, if the 60thday happens to be a declared holiday in the concerned office of the Railway, submission of PG can be accepted on the next working day. In all other cases, if the Contractor fails to submit the requisite PG even after 60 days from the date of issue of LOA, the contract is liable to be terminated. In case contract is terminated railway shall be entitled to forfeit Bid Security and other dues payable to the contractor against that particular contract, subject to maximum of PG amount. In case a tenderer has not submitted Bid Security on the strength of their registration as a Startup recognized by Department of Industrial Policy and Promotion (DIPP) under Ministry of Commerce and Industry, DIPP shall be informed to this effect. The failed Contractor shall be debarred from participating in re-tender for that work.</p>	No	No	Not Allowed

**IZZATNAGER DIVISION-ELECTRICAL/NORTH EASTERN RLY
TENDER DOCUMENT**

Tender No: IZN-Elect-OT-19-2026

Closing Date/Time: 02/07/2026 11:00

5	The successful bidder shall submit the Performance Guarantee (PG) amounting to 5% of the original contract value and 5% Additional Performance Guarantee in case of tenderer's quoted bid is below (-)5% of the tender cost , in any of the following forms:- (i) A deposit of Cash; (ii) Irrevocable Bank Guarantee;(iii) Government Securities including State Loan Bonds at 5% below the market value; (iv) Pay Orders and Demand Drafts tendered by any Scheduled Commercial Bank of India; (v) Guarantee Bonds executed or Deposits Receipts tendered by any Scheduled Commercial Bank of India; (vi) Deposit in the Post Office Saving Bank; (vii) Deposit in the National Savings Certificates; (viii) Twelve years National Defence Certificates; (ix) Ten years Defence Deposits; (x) National Defence Bonds and (xi) Unit Trust Certificates at 5% below market value or at the face value whichever is less. (xii) Insurance surety bonds as per Annexure XVII of GCC-2022. Also, FDR in favour of FA & CAO (free from any encumbrance) may be accepted.	No	No	Not Allowed
6	The following deduction will be done on the time of passing bill for payment: - 1 . 2% Income Tax on the total cost of the contract. 2. TDS: -1% CGST & 1% SGST or 2% IGST whichever applicable. Moreover, any other charges will be deducted from contractor's bill as per Railway board latest guidelines.	No	No	Not Allowed

Technical-Compliances

S.No.	Description	Confirmation Required	Remarks Allowed	Documents Uploading
1	Tenderer should have valid "A" class electrical contractor license issued by electrical inspector to state government and submit it along with the Bid offer. If "A" class electrical contractor license has been expired, tenderer should also submit the receipt of renewal electrical contractor license issued by electrical inspector to state government, along with bid offer. At the time of contract agreement, contractor must submit valid "A" class electrical contractor license issued by electrical inspector to state government. If tenderer have not submit the valid "A" class electrical contractor license/License renewal receipt, the offer will be summarily rejected.	Yes	Yes	Allowed (Mandatory)

Undertakings

S.No.	Description	Confirmation Required	Remarks Allowed	Documents Uploading
1	I/We also hereby agree to abide by the Indian Railways Standard General Conditions Of Contract, with all correction slips up-to-date and to carry out the work according to the Special Conditions of Contract and Specifications of materials and works as laid down by Railway in the annexed Special Conditions/Specifications, Schedule of Rates with all correction slips up-to date for the present contract.	No	No	Not Allowed
2	I/We have read the various conditions to tender attached hereto and agree to abide by the said conditions. I/We also agree to keep this tender open for acceptance for a period of 60 days from the date fixed for opening the same and in default thereof, I/We will be liable for forfeiture of my/our Earnest Money . I/We offer to do the work for North Eastern Railway, at the rates quoted in the attached schedule and hereby bind myself/ourselves to complete the work in all respects within the period of completion stipulated in the tender document, from the date of issue of letter of acceptance of the tender.	No	No	Not Allowed
3	The amount as stipulated in tender document is herewith forwarded as Earnest Money. Full value of the earnest Money shall stand forfeited without prejudice to any other right or remedies in case my/our Tender is accepted and if :	No	No	Not Allowed

**IZZATNAGER DIVISION-ELECTRICAL/NORTH EASTERN RLY
TENDER DOCUMENT**

Tender No: IZN-Elect-OT-19-2026

Closing Date/Time: 02/07/2026 11:00

4	I/We hereby Confirm that the rates, rebates and/or other financial terms, if any, quoted by us in the relevant fields of the Financial Bid page will only be the ruling terms for deciding the inter-se ranking, and any such condition having financial repercussions, if quoted by us anywhere else including attached documents shall not be considered for deciding inter-se ranking. However, Railways shall have the right to incorporate any such condition quoted by us, in the contract, at their discretion, if contract is placed on us.	No	No	Not Allowed
5	I/ We have visited the works site and I / We am / are aware of the site conditions.	No	No	Not Allowed
6	I/We have read the various conditions attached/ referred to in this tender document and agree to abide by the said conditions.	No	No	Not Allowed
7	Until a formal agreement is prepared and executed, acceptance of this tender shall constitute a binding contract between us subject to modifications, as may be mutually agreed to between us and indicated in the letter of acceptance of my/our offer for this work.	No	No	Not Allowed

6. Documents attached with tender

S.No.	Document Name	Document Description
1	TenderBookletMRTSecOT192026_compressed.pdf	Tender Document
2	GCCApril2022correctionslip1to11update.pdf	GCC April 2022 correction slip
3	HQJPO_Digginginthevicinityofcable_20.05.24_compressed.pdf	HQ JPO
4	GCCApril2022.pdf	GCC April 2022

This tender complies with Public Procurement Policy (Make in India) Order 2017, dated 15/06/2017, issued by Department of Industrial Promotion and Policy, Ministry of Commerce, circulated vide Railway Board letter no. 2015/RS(G)/779/5 dated 03/08/2017 and 27/12/2017 and amendments/ revisions thereof.

As a Tender Inviting Authority, the undersigned has ensured that the issue of this tender does not violate provisions of GFR regarding procurement through GeM.

Signed By: SATYENDRA KUMAR YADAV

Designation : Sr.DEE/IZN