

**Annexure-I****Location Details for Replacement of LTUG Cables feeding important Loads Over Erode Section**

Sl.No	Description	Location	Quantity
<b>Erode Section</b>			
1	4Cx16 Sqmm	Erode Junction colony area converting all overhead lines in to UG cables	8000 Mtr
2	4Cx25 Sqmm	Erode(ED),Anangur(ANU),Cauvery(CV),Sangagiri(SGE),Taneerpanthalpalayam(TPM),Ingur(IGR),Perundurai(PY),Vijayamangalam(VZ),Uthukuli(UKL) converting all overhead line cable in to UG Cables.	2000 Mtr
3	4Cx35 Sqmm	Anangur(ANU),Cauvery(CV),Sangagiri(SGE),Taneerpanthalpalayam(TPM), Ingur(IGR), Perundurai(PY), Vijayamangalam(VZ), Uthukuli(UKL),Kodumudi(KMD) cable replacement	1000 Mtr
4	4Cx50 Sqmm	Anangur(ANU),Cauvery(CV),Sangagiri(SGE),Taneerpanthalpalayam(TPM), Ingur(IGR), Perundurai(PY), Vijayamangalam(VZ), Uthukuli(UKL),Kodumudi(KMD) cable replacement	1500 Mtr
5	4Cx70 Sqmm	Erode Station east colony converting overhead power lines into UG Cables	600 Mtr
6	4Cx95 Sqmm	Erode Station replacement of cables	500 Mtr
7	4Cx120 Sqmm	Erode Station Enhancing of exisiting cable capacity	200 Mtr
8	4Cx185 Sqmm	Erode Station Enhancing of exisiting cable capacity	500 Mtr
9	2Cx70 Sqmm	Erode Station replacing of RRI Cabin Cables	500 Mtr