







kamalapur Longitudinal Section Profile



Plan and Section of Wet WELL 3m Dia



Wet Well Plan



Cross Section - A A

- NOTES:**
1. ALL DIMENSIONS ARE IN M AND LEVELS ARE IN M
 2. ALL CONCRETE MIX FOR R.C.C. SHALL BE M 30 UP TO PLINTH LVL. & ABOVE PLINTH M 25 UNLESS SPECIFIED AND P.C.C. M15
 3. 'T' INDICATES F₅₅₀ GRADE H.Y.S.D./TMT BARS CONFIRMING TO IS:1788-2008
 4. NOMINAL/CLEAR COVER TO REINFORCEMENT SHALL BE AS FOLLOWING; FOUNDATION/RAFT :50mm , COLUMN : 40mm , RC WALL : 45 mm , BEAM : 25mm AND SLAB : 20mm
 5. ALL CONCRETE SHALL BE MACHINE MIXED AND MACHINE VIBRATED.
 6. STEEL CHAIRS SHALL BE PROVIDED TO KEEP TOP STEEL IN PROPER POSITION.
 7. ALL DIMENSIONS AND LEVELS SHALL BE VERIFIED AS PER G.A.D DRAWINGS. IF ANY AMBIGUITY FOUND IT SHALL BE BROUGHT TO THE NOTICE BEFORE EXECUTION.
 8. DEVELOPMENT/LAP LENGTH SHALL BE NOT LESS THAN 50 TIMES THE DIAMETER.
 9. CURING OF CONCRETE MEMBERS SHALL BE CARRIED OUT FOR A MINIMUM PERIOD OF 14 DAYS FROM CASTING.
 10. SOIL BEARING CAPACITY IS CONSIDERED AS 120 kN/m² AT THE FOUNDATION LEVEL. AS PER SOIL STRATA
 11. IS 3784-1992 SHALL BE FOLLOWED AS A SAFETY CODE FOR EXCAVATION WORK.
 12. IF THE WATER TABLE IS ENCOUNTERED AT THE FOUNDATION LEVEL A SUITABLE DEWATERING TECHNIQUE SHOULD BE USED FOR CONSTRUCTION.

REFERENCE DRAWINGS			
SR.NO	DRG/DOC. NO.	REV NO.	TITLE



CONSULTANT:					
GREEN DESIGN & ENGINEERING SERVICES PVT.LTD					
CLIENT :					SHEET SIZE : A3
GOVERNMENT OF KARNATAKA URBAN DEVELOPMENT DEPARTMENT					
PROJECT TITLE :			DRN.	CHK.	APP.
SBM 2.0 INTERCEPTION & DIVERSION WORKS					
DRAWING TITLE :			DRAWING NUMBER		
PLAN AND SECTION VIEW OF WET WELL KAMALAPURA (KALABURGI DISTRICT)			DMA/SWM/SB2/KAM/KAL/WET/002		

